

BIG CARLOS PASS, FL, USA

WMO: 994006

Lat: 26.404N

Lon: 81.881W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 7.7	(c) 9.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.1	(k) 11.7	(l) 10.3	(m) 11.7	(n) 5.7	(o) 10	(p) 0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.3	(c) 32.7	(d) N/A	(e) 31.9	(f) N/A	(g) 31.3	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.7	(p) 70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.4	(b) 8.4	(c) 7.6	(e) 4.7	(f) 34.4	(g) 3.0	(h) 0.5	(i) 2.6	(j) 34.8	(k) 0.8	(l) 35.1	(m) -0.9	(n) 35.3	(o) -3.1	(p) 35.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	18.2	18.9	20.6	23.5	25.9	27.7	28.2	28.6	28.0	25.8	21.9	20.2		
	DBStd	4.49	3.99	3.51	3.04	1.97	1.51	1.25	1.03	0.89	1.00	2.32	3.07	3.74		
	HDD10.0	5	3	1	0	0	0	0	0	0	0	0	0	1		
	HDD18.3	138	51	33	16	1	0	0	0	0	0	1	8	27		
	CDD10.0	5113	258	250	328	407	493	531	565	577	541	490	356	317		
	CDD18.3	2203	47	49	86	157	235	281	307	318	291	232	114	84		
	CDH23.3	19994	91	86	276	941	2071	3125	3548	3802	3123	2083	573	277		
	CDH26.7	6154	3	2	14	102	468	1079	1322	1477	1064	540	69	14		
(14) Wind	WSAvg	4.0	4.2	4.0	4.3	4.3	3.9	3.7	3.4	3.5	3.6	4.1	4.4	4.1		
(15) Precipitation	PrecAvg	1254	45	42	42	57	78	210	205	205	205	92	36	35		
	PrecMax	1720	199	150	152	164	225	485	337	343	437	388	148	173		
	PrecMin	849	2	0	1	9	16	94	75	130	126	10	1	1		
	PrecStd	259	50	32	36	36	43	87	63	51	77	76	37	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.9	26.8	28.2	30.1	32.1	33.4	33.5	33.6	33.0	31.8	29.9	28.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	25.4	25.3	26.9	28.7	30.8	31.9	32.1	32.5	32.0	30.8	28.5	26.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	24.3	24.4	25.7	27.8	29.7	31.1	31.3	31.6	31.4	30.0	27.4	25.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	23.3	23.6	25.0	27.0	28.9	30.4	30.7	31.0	30.7	29.3	26.4	25.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	6.6	6.7	6.0	5.7	5.2	5.3	5.3	5.8	6.1	6.9	6.7		
		MCDBR	7.4	6.5	7.5	7.2	7.1	6.4	6.2	6.2	6.6	6.5	6.8	6.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.351	0.367	0.379	0.393	0.420	0.443	0.459	0.448	0.421	0.400	0.364	0.354		
	taud		2.525	2.487	2.440	2.376	2.355	2.367	2.315	2.375	2.432	2.459	2.506	2.539		
	Ebn at Noon		901	911	916	906	875	849	835	845	863	864	879	881		
	Edh at Noon		92	103	113	124	126	124	130	122	113	104	93	88		
(44) All-Sky Solar Radiation	RadAvg		3.74	4.59	5.58	6.46	6.64	5.99	5.88	5.67	5.10	4.76	4.04	3.46		
	RadStd		0.27	0.28	0.35	0.27	0.45	0.53	0.38	0.27	0.33	0.27	0.22	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.42	+0.89	N/A	N/A	N/A	N/A	-1	-25	+154	+117

Nomenclature: See separate page