

SOUTHWEST PASS, LA, USA

WMO: 994010

Lat: 28.9059N

Lon: 89.4287W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 38.9	(c) 42.2	(d) 25.0	(e) 19.1	(f) 42.5	(g) 29.0	(h) 23.0	(i) 46.0	(j) 51.8	(k) 47.1	(l) 41.4	(m) 56.5	(n) 23.8	(o) 20	(p) 0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.2	(c) 88.5	(d) 78.3	(e) 87.4	(f) 78.0	(g) 86.6	(h) 77.8	(i) 81.0	(j) 85.5	(k) 80.2	(l) 85.0	(m) 79.5	(n) 84.6	(o) 7.2	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.2	84.3	78.6	148.7	83.8	77.9	145.1	83.6	44.5	85.4	43.6	84.9	42.9	84.7	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 43.1	(b) 35.9	(c) 31.3	(e) 34.8	(f) 91.8	(g) 4.3	(h) 2.1	(i) 31.8	(j) 93.4	(k) 29.3	(l) 94.6	(m) 26.9	(n) 95.8	(o) 23.8	(p) 97.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.0	56.2	58.1	62.5	69.0	75.8	81.2	83.2	83.9	81.3	74.6	66.4	59.3
	DBStd	11.17	7.75	6.94	6.05	4.40	3.46	2.29	2.13	2.45	2.76	4.86	6.20	7.43
	HDD50	67	34	14	4	0	0	0	0	0	0	0	1	14
	HDD65	886	282	205	117	16	0	0	0	0	0	5	57	204
	CDD50	7738	226	242	390	570	799	937	1028	1051	939	762	493	301
	CDD65	3082	8	13	39	136	334	487	563	586	489	302	99	26
	CDH74	29385	0	1	4	162	1967	5327	7007	7497	5417	1844	158	1
	CDH80	8887	0	0	0	0	100	1337	2631	3116	1555	147	1	0
Wind	WSAvg	15.1	17.9	17.5	16.6	16.4	14.1	12.1	11.1	10.8	14.0	16.1	17.1	18.0
Precipitation	PrecAvg	57.8	4.7	3.8	4.8	4.8	3.9	5.1	6.5	6.5	5.9	4.1	3.5	4.2
	PrecMax	85.0	14.7	8.4	13.1	18.2	10.3	15.9	10.3	12.3	15.1	11.7	14.4	10.7
	PrecMin	35.2	0.1	0.7	0.6	0.5	0.4	1.1	3.0	2.5	1.8	0.7	0.4	1.1
	PrecStd	10.4	3.3	2.0	2.7	3.5	2.5	3.0	2.0	2.6	2.9	2.8	2.8	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.5	73.8	74.6	78.3	84.3	88.3	89.6	90.9	88.1	84.5	79.5	74.1
		MCWB	70.2	70.9	70.0	73.8	75.4	77.5	79.3	78.7	78.0	78.0	75.1	69.9
	2%	DB	70.1	71.3	73.3	77.2	82.2	86.4	87.7	89.1	86.4	82.9	77.3	72.9
		MCWB	68.5	69.4	69.8	73.0	75.5	77.2	78.6	78.3	77.5	76.7	71.6	69.4
	5%	DB	68.7	69.7	71.9	76.1	81.1	85.4	86.8	88.0	85.5	81.7	75.9	71.4
		MCWB	66.8	68.3	69.3	72.5	75.3	77.1	78.2	78.0	77.0	75.4	70.9	68.8
	10%	DB	67.2	68.1	70.5	74.8	80.2	84.4	86.1	87.1	84.8	80.6	74.6	69.9
		MCWB	65.1	66.7	68.1	71.6	75.0	76.9	78.0	77.9	76.8	74.3	70.0	67.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	71.6	72.2	75.8	78.5	81.1	82.9	82.0	80.5	79.8	76.2	72.3
		MCDB	71.3	72.9	73.2	76.6	81.2	84.5	86.5	87.4	84.9	83.1	78.4	73.0
	2%	WB	69.6	70.3	71.1	74.4	77.5	80.0	81.3	80.6	79.5	78.5	73.9	71.2
		MCDB	70.1	71.3	72.3	75.7	80.1	83.6	85.2	86.4	84.1	81.9	75.9	72.1
	5%	WB	68.1	69.1	70.1	73.4	76.8	79.2	80.3	80.0	78.7	77.4	72.4	69.7
		MCDB	68.8	69.9	71.5	75.2	79.6	83.1	84.9	86.1	83.8	80.8	74.6	71.2
	10%	WB	66.2	67.7	69.0	72.6	76.0	78.4	79.4	79.3	78.2	75.7	70.8	68.1
		MCDB	67.3	68.5	70.5	74.5	79.1	82.9	84.6	85.7	83.6	79.7	73.7	69.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.7	7.6	6.0	4.9	5.0	5.0	5.2	4.9	5.4	7.0	8.4
		MCDBR	8.8	8.5	7.2	5.6	5.7	5.8	5.5	5.7	5.2	5.4	6.2	8.3
		MCWBR	9.0	8.4	6.1	4.5	3.6	4.0	3.8	3.6	3.7	4.5	6.0	8.8
	5% WB	MCDBR	8.8	8.6	6.9	5.5	4.6	4.9	5.6	5.3	5.5	5.6	7.0	8.5
		MCWBR	9.7	8.8	6.9	5.1	3.9	4.0	4.6	4.0	4.3	5.5	7.9	9.5
Clear-Sky Solar Irradiance	taub	0.354	0.368	0.379	0.418	0.440	0.455	0.480	0.480	0.442	0.394	0.368	0.358	
	taud	2.528	2.500	2.452	2.332	2.316	2.325	2.276	2.280	2.344	2.473	2.492	2.523	
	Ebn at Noon	281	286	289	279	272	266	259	258	266	273	273	273	
	Edh at Noon	28	31	35	41	42	41	43	43	39	32	29	27	
All-Sky Solar Radiation	RadAvg	980	1199	1603	1914	2135	2030	1869	1741	1645	1474	1124	889	
	RadStd	79	143	142	187	102	137	123	129	122	128	110	72	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+243	+167

Nomenclature: See separate page