

SOUTHWEST PASS, LA, USA

WMO: 994010

Lat: 28.9059N

Lon: 89.4287W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.8	(c) 5.7	(d) -3.9	(e) 2.7	(f) 5.8	(g) -1.6	(h) 3.3	(i) 7.8	(j) 23.2	(k) 8.4	(l) 18.5	(m) 13.6	(n) 10.6	(o) 20	(p) 0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.9	(c) 31.4	(d) 25.7	(e) 30.8	(f) 25.5	(g) 30.3	(h) 25.4	(i) 27.2	(j) 29.7	(k) 26.8	(l) 29.5	(m) 26.4	(n) 29.2	(o) 3.2	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.0	29.1	25.9	21.2	28.8	25.5	20.7	28.7	85.6	29.7	83.5	29.4	81.8	29.3	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.3	(b) 16.1	(c) 14.0	(e) 1.6	(f) 33.2	(g) 2.4	(h) 1.2	(i) -0.1	(j) 34.1	(k) -1.5	(l) 34.8	(m) -2.8	(n) 35.5	(o) -4.6	(p) 36.3		
(a) 19.3	(b) 16.1	(c) 14.0	(e) -1.1	(f) 27.2	(g) 1.9	(h) 0.7	(i) -2.4	(j) 27.8	(k) -3.5	(l) 28.2	(m) -4.5	(n) 28.6	(o) -5.9	(p) 29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	13.4	14.5	16.9	20.5	24.3	27.3	28.4	28.8	27.4	23.7	19.1	15.2	(6)
(7)		DBStd	6.20	4.30	3.85	3.36	2.44	1.92	1.27	1.18	1.36	1.53	2.70	3.44	4.13	(7)
(8)		HDD10.0	37	19	8	2	0	0	0	0	0	0	0	1	8	(8)
(9)		HDD18.3	492	157	114	65	9	0	0	0	0	0	3	32	113	(9)
(10)		CDD10.0	4299	126	134	217	317	444	521	571	584	522	423	274	167	(10)
(11)		CDD18.3	1712	4	7	22	76	186	271	313	326	272	168	55	14	(11)
(12)		CDH23.3	16325	0	1	2	90	1093	2959	3893	4165	3009	1024	88	1	(12)
(13)		CDH26.7	4937	0	0	0	0	56	743	1462	1731	864	82	1	0	(13)
(14)	Wind	WSAvg	6.8	8.0	7.8	7.4	7.3	6.3	5.4	5.0	4.8	6.3	7.2	7.6	8.0	(14)
(15)	Precipitation	PrecAvg	1469	120	96	122	123	98	129	165	166	149	104	89	107	(15)
(16)		PrecMax	2160	374	213	333	462	261	403	261	312	384	297	366	272	(16)
(17)		PrecMin	894	3	18	16	13	11	27	75	64	45	19	9	27	(17)
(18)		PrecStd	265	85	52	68	90	63	75	52	65	74	72	72	56	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	23.2	23.7	25.7	29.1	31.3	32.0	32.7	31.2	29.2	26.4	23.4	(19)
(20)			MCWB	21.2	21.6	21.1	23.2	24.1	25.3	26.3	25.9	25.5	25.6	23.9	21.1	(20)
(21)		2%	DB	21.2	21.8	22.9	25.1	27.9	30.2	31.0	31.7	30.2	28.3	25.1	22.7	(21)
(22)			MCWB	20.3	20.8	21.0	22.8	24.2	25.1	25.9	25.7	25.3	24.8	22.0	20.8	(22)
(23)		5%	DB	20.4	20.9	22.2	24.5	27.3	29.6	30.4	31.1	29.7	27.6	24.4	21.9	(23)
(24)			MCWB	19.3	20.1	20.7	22.5	24.1	25.0	25.7	25.6	25.0	24.1	21.6	20.5	(24)
(25)		10%	DB	19.6	20.1	21.4	23.8	26.8	29.1	30.1	30.6	29.3	27.0	23.6	21.1	(25)
(26)			MCWB	18.4	19.3	20.1	22.0	23.9	24.9	25.5	25.5	24.9	23.5	21.1	19.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	22.0	22.4	24.4	25.8	27.3	28.3	27.8	26.9	26.5	24.5	22.4	(27)
(28)			MCD B	21.8	22.7	22.9	24.8	27.3	29.2	30.3	30.8	29.4	28.4	25.8	22.8	(28)
(29)		2%	WB	20.9	21.3	21.7	23.5	25.3	26.7	27.4	27.0	26.4	25.9	23.3	21.8	(29)
(30)			MCD B	21.2	21.8	22.4	24.3	26.7	28.7	29.6	30.2	29.0	27.7	24.4	22.3	(30)
(31)		5%	WB	20.0	20.6	21.2	23.0	24.9	26.2	26.8	26.7	25.9	25.2	22.4	21.0	(31)
(32)			MCD B	20.4	21.1	21.9	24.0	26.5	28.4	29.4	30.0	28.8	27.1	23.7	21.8	(32)
(33)		10%	WB	19.0	19.8	20.5	22.6	24.4	25.8	26.3	26.3	25.6	24.3	21.6	20.1	(33)
(34)			MCD B	19.6	20.3	21.4	23.6	26.1	28.3	29.2	29.8	28.6	26.5	23.1	21.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	4.9	4.2	3.3	2.7	2.8	2.8	2.9	2.7	3.0	3.9	4.7	(35)
(36)			MCDBR	4.9	4.7	4.0	3.1	3.2	3.2	3.0	3.2	2.9	3.0	3.4	4.6	(36)
(37)			MCWBR	5.0	4.7	3.4	2.5	2.0	2.2	2.1	2.0	2.0	2.5	3.3	4.9	(37)
(38)		5% WB	MCD BR	4.9	4.8	3.9	3.0	2.5	2.7	3.1	3.0	3.0	3.1	3.9	4.7	(38)
(39)			MCWBR	5.4	4.9	3.8	2.9	2.2	2.2	2.5	2.2	2.4	3.0	4.4	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.354	0.368	0.379	0.418	0.440	0.455	0.480	0.480	0.442	0.394	0.368	0.358	(40)	
(41)		taud	2.528	2.500	2.452	2.332	2.316	2.325	2.276	2.280	2.344	2.473	2.492	2.523	(41)	
(42)		Ebn at Noon	885	901	910	880	857	839	817	814	837	861	861	862	(42)	
(43)		Edh at Noon	89	99	110	128	131	129	135	134	122	101	92	86	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.09	3.78	5.05	6.04	6.73	6.40	5.89	5.49	5.19	4.65	3.54	2.80	(44)	
(45)		RadStd	0.25	0.45	0.45	0.59	0.32	0.43	0.39	0.41	0.38	0.40	0.35	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	+93

Nomenclature: See separate page