

NEWPORT SOUTH BEACH HARBOR, OR, USA

WMO: 994026

Lat: 44.6256N

Lon: 124.0450W

Elev: 7

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.7	34.6	N/A	N/A	N/A	N/A	N/A	N/A	28.0	52.4	25.3	51.3	9.6	90	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.2	69.6	N/A	65.8	N/A	63.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
23.3	20.3	18.2	DB	26.7	83.8	4.2	4.8	23.6	87.2	21.2	90.0	18.8	92.7	15.7	96.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	46.9	45.7	46.9	48.4	51.7	54.8	57.5	58.0	57.4	53.9	49.4	45.6
	DBStd	6.14	4.57	5.14	4.18	3.62	3.82	2.66	2.58	2.54	3.91	4.04	4.84	5.62
	HDD50	686	114	135	114	69	18	0	0	0	1	10	67	158
	HDD65	4979	561	541	560	500	414	305	234	217	232	345	468	602
	CDD50	1189	18	14	18	20	71	145	232	249	222	131	49	20
	CDD65	7	0	0	0	1	2	0	0	1	3	0	0	0
	CDH74	86	0	0	0	7	27	2	1	7	41	1	0	0
	CDH80	21	0	0	0	2	6	0	0	2	11	0	0	0
Wind	WSAvg	8.0	9.6	8.4	8.4	7.8	7.6	7.5	7.6	6.7	6.5	7.0	8.9	9.8
Precipitation	PrecAvg	68.2	10.7	7.8	7.3	4.8	3.3	2.6	0.9	1.1	2.2	5.2	10.4	11.7
	PrecMax	102.9	21.3	16.8	13.1	9.6	7.2	6.2	3.2	7.0	6.3	10.6	20.3	22.4
	PrecMin	46.3	0.7	1.6	1.2	1.1	0.4	0.4	0.0	0.0	0.1	1.9	2.8	
	PrecStd	13.1	4.7	3.9	3.1	2.0	1.6	1.6	0.7	1.3	1.7	2.7	4.6	5.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.5	60.3	63.6	68.7	79.1	67.5	68.6	68.7	79.4	70.2	63.1	61.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	57.0	57.0	57.3	58.9	65.1	62.8	64.8	65.6	68.9	64.6	59.7	57.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	54.5	54.5	54.8	55.1	58.4	60.4	63.3	64.1	65.0	61.6	57.6	55.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	52.8	52.4	53.0	53.2	56.4	59.2	62.2	62.7	62.9	59.4	56.0	53.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	8.8	8.8	9.0	8.7	7.7	7.0	7.4	8.2	9.9	9.9	9.2	8.3
		MCDBR	10.8	11.6	11.8	12.9	13.5	9.4	9.0	10.6	14.5	13.0	10.0	8.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.325	0.324	0.337	0.370	0.377	0.362	0.349	0.356	0.348	0.337	0.332	0.332	
	taud	2.526	2.548	2.525	2.390	2.400	2.458	2.514	2.508	2.524	2.555	2.523	2.469	
	Ebn at Noon	253	276	286	283	283	287	290	284	279	267	247	235	
	Edh at Noon	22	25	29	36	36	35	32	31	29	24	21	21	
All-Sky Solar Radiation	RadAvg	418	680	1010	1448	1802	1959	2121	1796	1409	854	477	344	
	RadStd	59	76	113	108	149	147	142	139	111	90	60	47	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+31

Nomenclature: See separate page