

NEWPORT SOUTH BEACH HARBOR, OR, USA

WMO: 994026

Lat: 44.6256N

Lon: 124.0450W

Elev: 2

StdP: 101.30

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.2	1.4	N/A	N/A	N/A	N/A	N/A	N/A	12.5	11.3	11.3	10.7	4.3	90	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	20.9	N/A	18.8	N/A	17.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.1	8.1	DB	-3.0	28.8	2.3	2.7	-4.7	30.7	-6.0	32.2	-7.3	33.7	-9.1	35.7	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	8.3	7.6	8.3	9.1	11.0	12.7	14.2	14.5	14.1	12.2	9.7	7.5
	DBStd	3.41	2.54	2.86	2.32	2.01	2.12	1.48	1.44	1.41	2.17	2.24	2.69	3.12
	HDD10.0	381	63	75	63	38	10	0	0	0	1	6	37	88
	HDD18.3	2766	312	301	311	278	230	169	130	121	129	192	260	334
	CDD10.0	661	10	8	10	11	39	81	129	138	123	73	27	11
	CDD18.3	4	0	0	0	1	1	0	0	1	2	0	0	0
	CDH23.3	48	0	0	0	4	15	1	1	4	23	1	0	0
	CDH26.7	12	0	0	0	1	3	0	0	1	6	0	0	0
Wind	WSAvg	3.6	4.3	3.8	3.7	3.5	3.4	3.4	3.4	3.0	2.9	3.1	4.0	4.4
Precipitation	PrecAvg	1733	272	198	186	122	85	65	22	29	57	131	264	296
	PrecMax	2613	540	427	332	243	183	158	82	177	159	269	516	570
	PrecMin	1175	17	40	31	27	9	10	0	1	1	3	48	70
	PrecStd	332	120	98	79	52	41	40	19	32	42	69	116	128
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.4	15.7	17.5	20.4	26.2	19.7	20.3	20.4	26.4	21.2	17.3	16.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	13.9	13.9	14.1	15.0	18.4	17.1	18.2	18.7	20.5	18.1	15.4	14.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	12.5	12.5	12.6	12.8	14.7	15.8	17.4	17.8	18.3	16.4	14.2	12.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	11.6	11.3	11.7	11.8	13.6	15.1	16.8	17.1	17.2	15.2	13.3	11.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	5.0	4.9	4.3	3.9	4.1	4.5	5.5	5.5	5.1	4.6
		MCDBR	6.0	6.5	6.6	7.2	7.5	5.2	5.0	5.9	8.1	7.2	5.6	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.325	0.324	0.337	0.370	0.377	0.362	0.349	0.356	0.348	0.337	0.332	0.332
	taud		2.526	2.548	2.525	2.390	2.400	2.458	2.514	2.508	2.524	2.555	2.523	2.469
	Ebn at Noon		797	871	903	892	893	906	914	896	878	842	780	742
	Edh at Noon		68	78	91	113	115	109	102	99	90	77	67	66
All-Sky Solar Radiation	RadAvg		1.32	2.14	3.18	4.56	5.68	6.18	6.68	5.66	4.44	2.69	1.50	1.08
	RadStd		0.19	0.24	0.35	0.34	0.47	0.46	0.45	0.44	0.35	0.28	0.19	0.15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+17

Nomenclature: See separate page