

TOKE POINT, WA, USA

WMO: 994029

Lat: 46.7070N

Lon: 123.9670W

Elev: 16

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	30.5	33.3	N/A	N/A	N/A	N/A	N/A	N/A	37.8	53.8	33.2	49.9	12.5	70	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	76.7	N/A	72.2	N/A	68.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.0	20.4	DB	26.6	85.6	4.0	4.1	23.7	88.6	21.4	91.0	19.2	93.3	16.3	96.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	44.6	44.3	46.2	48.6	54.4	56.7	59.7	60.9	59.6	53.8	47.4	43.4
	DBStd	7.69	4.20	4.75	4.19	3.93	6.24	3.68	3.51	3.24	4.10	3.88	4.73	5.24
	HDD50	868	172	162	133	70	10	0	0	0	0	10	102	209
	HDD65	4905	633	579	584	494	343	253	170	137	169	346	529	668
	CDD50	1480	4	4	14	26	146	201	300	336	290	130	23	6
	CDD65	39	0	0	0	0	14	4	5	8	8	0	0	0
	CDH74	245	0	0	0	2	88	29	45	38	42	1	0	0
	CDH80	58	0	0	0	0	32	5	13	4	4	0	0	0
Wind	WSAvg	9.3	11.2	10.3	10.6	9.3	8.0	8.2	7.8	6.8	7.9	9.4	11.1	11.4
Precipitation	PrecAvg	84.9	13.7	8.5	9.6	6.2	3.5	2.6	1.0	1.7	2.9	8.5	13.0	13.6
	PrecMax	107.9	27.4	24.1	20.1	11.6	6.2	5.2	2.8	5.2	9.1	17.0	26.4	23.5
	PrecMin	60.9	6.8	0.9	1.7	2.5	0.5	0.6	0.2	0.1	0.3	1.2	3.7	6.0
	PrecStd	13.9	4.1	4.6	4.1	2.4	1.6	1.2	0.7	1.4	2.2	3.9	5.6	4.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	56.8	64.5	67.7	82.8	78.4	80.9	79.3	80.1	69.8	58.9	56.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	53.2	54.5	57.2	60.4	74.6	69.0	72.3	73.3	73.4	63.7	56.9	53.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	51.6	52.2	53.8	56.0	68.5	64.4	67.6	68.9	68.4	60.5	55.4	52.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.4	50.4	51.9	53.3	64.1	61.6	64.7	65.7	64.7	59.1	53.9	50.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.5	7.8	8.3	8.5	8.5	8.0	8.4	9.4	9.8	9.1	8.2	6.6
		MCDBR	9.6	10.5	12.3	14.7	16.7	15.4	16.0	17.5	18.1	12.2	8.7	6.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.331	0.321	0.338	0.370	0.399	0.373	0.353	0.357	0.347	0.339	0.331	0.322	
	taud	2.471	2.543	2.508	2.385	2.310	2.418	2.507	2.494	2.526	2.540	2.495	2.483	
	Ebn at Noon	241	272	283	281	275	283	287	282	276	261	239	230	
	Edh at Noon	22	24	29	36	40	36	32	31	28	24	21	19	
All-Sky Solar Radiation	RadAvg	341	615	931	1355	1663	1814	1913	1648	1279	752	406	286	
	RadStd	49	77	104	119	144	154	152	132	108	82	51	38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page