

PORT CHICAGO, CA, USA

WMO: 994034

Lat: 38.056N

Lon: 122.039W

Elev: 2

StdP: 101.30

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.9	(c) 4.0	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.4	(k) 8.8	(l) 9.0	(m) 10.4	(n) 2.4	(o) 190	(p) 0.571

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 10.9	(c) 31.8	(d) N/A	(e) 29.7	(f) N/A	(g) 27.9	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.3	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 12.3	(b) 10.8	(c) 9.5	(e) 0.6	(f) 35.8	(g) 1.6	(h) 1.9	(i) -0.5	(j) 37.2	(k) -1.4	(l) 38.3	(m) -2.3	(n) 39.3	(o) -3.4	(p) 40.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	9.7	11.1	12.7	14.5	16.4	19.2	20.2	20.3	20.2	17.5	13.2	9.6		
	DBStd	4.79	2.34	2.56	2.61	3.00	2.83	2.88	2.50	2.22	2.70	2.69	2.80	2.69		
	HDD10.0	103	34	17	5	1	0	0	0	0	0	0	6	41		
	HDD18.3	1361	269	203	173	123	74	21	6	5	9	48	156	272		
	CDD10.0	2078	24	47	91	135	199	276	317	320	307	234	101	27		
	CDD18.3	293	0	0	1	7	16	47	66	67	66	24	1	0		
	CDH23.3	2173	0	0	5	67	143	418	493	421	469	153	3	0		
	CDH26.7	655	0	0	0	12	39	136	160	118	159	31	0	0		
(14) Wind	WSAvg	4.7	3.1	3.5	3.8	4.8	5.7	6.2	7.2	6.8	5.3	3.8	3.1	2.9		
(15) Precipitation	PrecAvg	538	115	103	60	35	24	6	0	1	1	28	53	112		
	PrecMax	874	291	319	244	116	79	30	1	14	5	115	164	280		
	PrecMin	281	0	0	0	5	0	0	0	0	0	1	0	9		
	PrecStd	159	82	71	64	29	23	8	0	3	2	28	43	83		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	21.5	24.0	28.2	30.7	33.5	34.2	33.1	33.0	30.1	23.6	17.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	16.5	19.1	21.5	25.4	27.3	30.5	30.5	30.0	30.9	26.8	21.3	16.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	14.8	17.0	19.3	22.5	24.3	28.0	28.1	27.6	28.4	25.0	19.4	14.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	13.5	15.5	17.6	19.9	22.0	25.6	25.9	25.6	25.9	22.8	17.7	13.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	7.0	7.5	8.3	8.8	9.2	10.7	11.0	10.7	10.9	9.6	7.9	6.2		
		MCWBR	9.3	10.2	11.3	13.4	13.4	14.8	14.4	13.6	15.1	13.0	10.4	7.2		
(40) Clear-Sky Solar Irradiance	taub	taud	0.323	0.325	0.339	0.359	0.364	0.361	0.365	0.349	0.348	0.332	0.324	0.326		
		Ebn at Noon	2.534	2.529	2.475	2.395	2.407	2.420	2.406	2.443	2.446	2.526	2.528	2.525		
	Edh at Noon		862	908	924	920	916	915	908	917	901	887	851	829		
			77	87	101	116	117	116	116	109	103	86	77	73		
(44) All-Sky Solar Radiation	RadAvg		2.31	3.29	4.66	6.12	7.25	8.01	7.79	6.96	5.77	4.15	2.78	2.04		
	RadStd		0.36	0.41	0.45	0.51	0.44	0.33	0.23	0.24	0.20	0.27	0.18	0.32		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)		+0.37	N/A	-1.15	N/A	N/A	N/A	N/A	-115	+133	N/A

Nomenclature: See separate page