

REDWOOD CITY, CA, USA

WMO: 994041

Lat: 37.5068N

Lon: 122.2119W

Elev: 6

StdP: 101.25

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 3.7	(c) 4.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.3	(k) 11.9	(l) 8.8	(m) 11.9	(n) 1.1	(o) 150	(p) 0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 7.9	(c) 28.9	(d) N/A	(e) 26.5	(f) N/A	(g) 24.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.2	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.1	(b) 8.6	(c) 7.7	(e) 1.4	(f) 33.5	(g) 1.3	(h) 1.7	(i) 0.5	(j) 34.7	(k) -0.3	(l) 35.8	(m) -1.0	(n) 36.7	(o) -1.9	(p) 38.0		
			DB													
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	10.7	11.5	12.8	13.9	15.3	17.4	18.2	18.4	18.5	16.8	13.3	10.5
	DBStd	3.82	2.25	2.55	2.52	2.76	2.54	2.58	2.02	2.02	2.51	2.50	2.52	2.59
	HDD10.0	66	19	13	4	1	0	0	0	0	0	0	4	25
	HDD18.3	1420	236	192	172	137	102	48	26	24	26	62	153	243
	CDD10.0	1814	41	54	91	118	164	222	256	259	256	211	102	41
	CDD18.3	128	0	0	1	4	8	20	23	25	32	14	1	0
	CDH23.3	689	0	0	7	46	76	130	84	92	166	86	3	0
	CDH26.7	183	0	0	0	7	21	39	22	27	51	16	0	0
Wind	WSAvg	2.9	1.8	2.5	2.9	3.7	4.2	4.0	3.7	3.3	2.9	2.2	1.9	1.9
Precipitation	PrecAvg	499	99	91	68	33	17	4	0	1	2	26	55	102
	PrecMax	859	240	323	194	104	67	40	2	20	11	94	167	246
	PrecMin	198	7	0	2	3	0	0	0	0	0	0	1	4
	PrecStd	141	67	64	55	26	19	9	0	4	3	25	40	69
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	21.9	24.3	28.0	29.3	31.5	29.8	30.8	31.4	28.9	23.6	18.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	17.6	19.4	20.8	24.4	25.3	27.2	25.4	25.6	27.9	25.6	20.9	16.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	15.9	17.4	18.6	20.7	21.6	24.0	23.0	23.4	24.8	23.4	19.0	15.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	14.6	15.7	17.0	18.1	19.1	21.5	21.6	21.7	22.6	21.2	17.4	14.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.1	6.9	7.4	7.4	7.0	7.8	7.1	7.1	7.9	8.2	7.4	6.5
		MCDBR	9.5	10.1	10.3	12.1	11.9	12.5	9.5	9.8	12.4	12.3	10.2	7.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.324	0.333	0.339	0.357	0.367	0.360	0.366	0.345	0.350	0.337	0.321	0.324
	taud		2.553	2.525	2.499	2.417	2.412	2.438	2.430	2.484	2.456	2.535	2.561	2.558
	Ebn at Noon		866	902	927	923	914	917	908	923	901	884	862	840
	Edh at Noon		77	89	99	114	117	114	114	105	102	86	75	72
All-Sky Solar Radiation	RadAvg		2.42	3.35	4.74	6.18	7.05	7.67	7.18	6.41	5.47	4.08	2.84	2.12
	RadStd		0.32	0.40	0.41	0.48	0.46	0.32	0.25	0.30	0.21	0.25	0.18	0.30

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	-1.17	N/A	N/A	N/A	N/A	-110	+135	N/A

Nomenclature: See separate page