

ARENA COVE, CA, USA

WMO: 994044

Lat: 38.9150N

Lon: 123.7110W

Elev: 7

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	37.0	39.0	N/A	N/A	N/A	N/A	N/A	N/A	24.8	53.2	21.8	52.8	7.2	100	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	8.0	66.8	N/A	64.5	N/A	62.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.1	12.4	DB	32.6	76.7	2.0	4.4	31.2	79.9	30.1	82.5	28.9	84.9	27.5	88.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	49.7	49.0	49.3	50.2	51.9	54.1	55.1	56.2	56.6	55.6	52.4	49.3
	DBStd	4.44	3.86	3.93	3.27	2.82	2.57	2.52	2.60	3.02	3.43	3.72	3.90	4.65
	HDD50	295	53	60	53	30	5	1	0	0	0	3	20	70
	HDD65	4575	475	447	488	445	406	327	306	271	253	293	377	487
	CDD50	1199	43	33	30	35	65	125	160	194	198	175	92	49
	CDD65	2	0	0	0	0	0	1	0	0	0	1	0	0
	CDH74	11	0	0	0	0	2	6	0	0	1	2	0	0
	CDH80	1	0	0	0	0	0	1	0	0	0	0	0	0
Wind	WSAvg	5.4	5.9	6.3	6.0	5.7	5.6	5.4	5.0	4.6	4.2	4.4	5.1	6.4
Precipitation	PrecAvg	48.5	9.3	8.8	5.6	3.1	2.0	0.5	0.0	0.1	0.1	2.1	4.9	10.9
	PrecMax	75.2	28.3	27.0	17.2	10.5	7.0	2.5	0.2	1.3	0.5	5.7	12.6	24.6
	PrecMin	27.0	0.1	0.5	0.2	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.5
	PrecStd	14.4	6.7	6.5	5.0	2.6	2.2	0.7	0.0	0.3	0.1	1.6	3.6	7.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.7	63.1	60.4	62.9	68.5	67.5	64.9	67.9	67.6	71.2	66.8	62.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	59.5	59.3	57.2	57.4	59.5	61.0	62.7	64.4	65.4	65.5	62.0	60.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	57.3	56.9	55.6	55.5	57.2	59.3	61.0	62.7	63.7	63.1	59.8	58.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.8	55.1	54.5	54.4	55.5	58.1	59.5	61.1	62.0	61.3	58.4	56.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	10.2	8.8	8.2	7.5	6.5	6.5	5.9	6.4	8.0	9.6	9.3	9.5
		MCDBR	13.0	11.4	9.4	8.7	9.3	8.5	8.0	9.1	10.4	14.1	10.6	8.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.326	0.332	0.335	0.360	0.358	0.354	0.355	0.344	0.338	0.335	0.318	0.326	
	taud	2.555	2.539	2.549	2.437	2.481	2.495	2.501	2.530	2.525	2.573	2.596	2.553	
	Ebn at Noon	271	284	294	291	292	292	291	292	289	279	272	261	
	Edh at Noon	24	27	30	35	34	34	34	32	30	26	23	22	
All-Sky Solar Radiation	RadAvg	688	974	1388	1849	2174	2390	2196	1909	1647	1201	808	585	
	RadStd	104	134	127	140	153	122	117	104	98	88	72	96	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (28 neighbors)		N/A	N/A	-2.38	N/A	N/A	N/A	N/A	N/A	+223	N/A

Nomenclature: See separate page