

ARENA COVE, CA, USA

WMO: 994044

Lat: 38.9150N

Lon: 123.7110W

Elev: 2

StdP: 101.30

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.8	3.9	N/A	N/A	N/A	N/A	N/A	N/A	11.1	11.8	9.8	11.5	3.2	100	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	4.4	19.3	N/A	18.0	N/A	17.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.1	6.7	5.5	DB	0.4	24.8	1.1	2.5	-0.4	26.6	-1.1	28.0	-1.7	29.4	-2.5	31.2	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	9.8	9.5	9.6	10.1	11.1	12.3	12.9	13.5	13.7	13.1	11.3	9.6
	DBStd	2.46	2.15	2.19	1.82	1.57	1.43	1.40	1.44	1.68	1.91	2.07	2.17	2.58
	HDD10.0	164	29	33	29	17	3	1	0	0	0	2	11	39
	HDD18.3	2542	264	248	271	247	226	182	170	151	141	163	209	271
	CDD10.0	666	24	18	17	19	36	69	89	108	110	97	51	27
	CDD18.3	1	0	0	0	0	0	1	0	0	0	1	0	0
	CDH23.3	6	0	0	0	0	1	3	0	0	1	1	0	0
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0
(14) Wind	WSAvg	2.4	2.6	2.8	2.7	2.5	2.5	2.4	2.2	2.1	1.9	2.0	2.3	2.9
(15) Precipitation	PrecAvg	1232	236	223	142	78	50	12	1	3	2	53	125	277
	PrecMax	1911	719	685	436	266	178	64	4	33	13	145	321	625
	PrecMin	686	3	12	4	12	0	0	0	0	0	0	1	63
	PrecStd	367	170	164	126	67	56	17	1	7	3	41	92	195
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	17.3	15.8	17.1	20.3	19.7	18.3	19.9	19.8	21.8	19.3	16.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	15.3	15.1	14.0	14.1	15.3	16.1	17.1	18.0	18.6	18.6	16.7	15.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.1	13.8	13.1	13.0	14.0	15.2	16.1	17.1	17.6	17.3	15.5	14.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.2	12.8	12.5	12.4	13.1	14.5	15.3	16.2	16.7	16.3	14.7	13.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	4.9	4.6	4.1	3.6	3.6	3.3	3.6	4.4	5.3	5.2	5.3
		MCDBR	7.2	6.3	5.2	4.9	5.2	4.7	4.4	5.0	5.8	7.8	5.9	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.326	0.332	0.335	0.360	0.358	0.354	0.355	0.344	0.338	0.335	0.318	0.326
	taud		2.555	2.539	2.549	2.437	2.481	2.495	2.501	2.530	2.525	2.573	2.596	2.553
	Ebn at Noon		853	896	928	917	921	921	917	921	910	881	857	823
	Edh at Noon		75	86	94	111	108	107	106	100	95	82	71	70
(44) All-Sky Solar Radiation	RadAvg		2.17	3.07	4.38	5.83	6.85	7.53	6.92	6.02	5.19	3.79	2.55	1.84
	RadStd		0.33	0.42	0.40	0.44	0.48	0.39	0.37	0.33	0.31	0.28	0.23	0.30

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	-1.32	N/A	N/A	N/A	N/A	N/A	+124	N/A

Nomenclature: See separate page