

LAKE WORTH PIER, FL, USA

WMO: 994050

Lat: 26.6130N

Lon: 80.0340W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.6	51.7	N/A	N/A	N/A	N/A	N/A	N/A	31.7	69.3	28.6	69.3	11.6	310	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	87.1	N/A	86.2	N/A	85.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.4	230

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB	
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
31.7	26.1	23.4	DB	41.6	91.0	4.3	1.4	38.5	92.1	36.0	92.9	33.6	93.7	30.5	94.7	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.6	67.0	69.5	71.0	74.4	77.7	80.2	81.7	82.2	81.4	78.9	72.9	70.0
	DBStd	6.80	6.90	6.22	5.00	3.52	2.13	1.98	1.80	1.72	1.84	3.29	5.48	7.02
	HDD50	5	2	1	0	0	0	0	0	0	0	0	0	2
	HDD65	169	65	32	17	2	0	0	0	0	0	1	10	42
	CDD50	9352	528	547	651	733	859	907	984	997	943	894	686	623
	CDD65	4042	126	158	203	286	394	457	519	532	493	430	246	198
	CDH74	35162	256	386	557	1454	3110	4768	6016	6436	5665	4209	1497	808
	CDH80	7746	2	12	26	35	195	1004	1878	2212	1655	659	65	3
Wind	WSAvg	11.3	12.0	11.8	13.7	13.2	11.5	9.3	8.3	9.4	10.6	11.3	11.8	12.6
Precipitation	PrecAvg	60.3	2.9	2.4	3.5	3.7	4.5	8.5	6.1	8.0	8.8	5.9	2.8	3.1
	PrecMax	82.9	9.1	6.6	9.3	9.2	13.4	18.9	10.3	19.2	23.8	13.6	11.0	9.6
	PrecMin	43.6	0.3	0.1	0.6	0.7	1.1	2.3	2.2	3.2	3.9	1.3	0.3	1.1
	PrecStd	8.7	2.9	1.7	2.5	2.2	3.5	4.3	2.0	3.7	3.8	3.8	2.6	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	82.0	83.6	84.2	86.9	87.7	87.8	89.3	88.4	86.1	82.5	80.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	77.5	78.3	79.2	80.3	83.0	85.5	86.3	87.0	86.0	84.3	81.8	79.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	76.7	77.1	77.8	79.3	81.8	84.3	85.4	86.2	85.2	83.4	80.9	78.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	75.5	76.3	76.9	78.5	80.9	83.6	84.9	85.5	84.5	82.7	79.9	77.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	9.6	8.4	7.5	6.0	5.2	6.1	6.0	6.6	5.7	5.7	8.1	8.3
		MCDBR	7.3	7.6	8.8	7.4	7.8	7.6	6.7	8.0	6.5	6.0	6.2	6.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.360	0.370	0.386	0.402	0.431	0.460	0.473	0.463	0.432	0.413	0.380	0.369
	taud		2.520	2.509	2.447	2.389	2.345	2.327	2.285	2.337	2.428	2.439	2.484	2.517
	Ebn at Noon		282	288	288	285	274	265	261	264	271	270	273	274
	Edh at Noon		29	32	36	39	41	41	43	40	36	34	30	29
All-Sky Solar Radiation	RadAvg		1126	1381	1687	1942	1982	1837	1848	1782	1561	1430	1202	1038
	RadStd		78	89	98	90	168	171	103	100	84	104	63	74

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	+0.70	+1.53	N/A	N/A	N/A	N/A	N/A	N/A	-38	+248	+202

Nomenclature: See separate page