

MT DESERT ROCK, ME, USA

WMO: 994060

Lat: 43.9690N

Lon: 68.1280W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-11.3	-19.3	0.7	-10.7	-17.5	0.8	-9.4	22.7	3.1	21.2	-0.3	10.4	320	0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	19.6	17.8	18.7	17.4	18.0	17.0	18.6	18.8	17.8	18.1	17.1	17.4	5.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.3	18.7	17.7	12.7	17.9	17.0	12.1	17.2	52.5	18.9	50.1	17.9	48.2	17.5	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	18.7	16.3	DB	-17.3	22.5	2.4	1.7	-19.1	23.8	-20.5	24.8	-21.8	25.7	-23.5	27.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-1.7	-1.5	0.9	4.9	8.4	12.0	15.4	16.2	14.3	10.7	6.8	2.0	(6)
(7)		DBStd	6.95	5.43	4.51	3.43	2.12	1.87	1.90	1.59	1.39	1.62	2.39	3.53	4.44	(7)
(8)		HDD10.0	1553	363	323	281	153	57	4	0	0	0	21	104	247	(8)
(9)		HDD18.3	3984	622	556	539	403	308	189	91	67	121	236	347	506	(9)
(10)		CDD10.0	613	0	0	0	0	8	66	168	192	129	43	7	0	(10)
(11)		CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0	(11)
(12)		CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.7	9.0	9.3	8.5	8.1	7.2	6.0	5.9	6.3	6.5	8.3	8.6	8.7	(14)
(15)	Precipitation	PrecAvg	1544	144	122	134	124	111	124	96	97	120	150	145	177	(15)
(16)		PrecMax	2087	266	262	227	249	222	254	192	234	251	420	248	295	(16)
(17)		PrecMin	963	31	51	41	16	21	62	45	27	41	39	55	67	(17)
(18)		PrecStd	219	53	41	49	51	47	52	39	51	53	73	43	56	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	8.0	8.9	10.7	15.5	18.9	21.1	21.3	19.1	16.3	13.7	11.8	(19)
(20)			MCWB	9.8	7.7	8.1	8.7	12.0	15.1	18.3	18.9	17.3	13.3	13.2	11.3	(20)
(21)		2%	DB	8.8	6.4	7.1	9.1	13.1	16.5	19.4	19.8	18.0	15.1	12.7	10.3	(21)
(22)			MCWB	8.1	5.8	6.5	7.8	10.5	14.3	17.2	18.5	16.6	13.9	11.9	9.9	(22)
(23)		5%	DB	7.5	5.6	6.1	8.3	11.7	15.4	18.4	19.0	17.2	14.4	11.9	9.5	(23)
(24)			MCWB	6.7	4.8	5.3	7.2	9.7	13.7	17.3	17.9	16.1	13.4	11.1	8.8	(24)
(25)		10%	DB	5.9	4.6	5.1	7.5	10.7	14.5	17.7	18.3	16.4	13.7	11.4	8.6	(25)
(26)			MCWB	4.6	3.5	4.1	6.5	9.2	13.2	16.9	17.4	15.7	12.9	10.6	7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	8.0	8.9	10.2	13.7	17.0	19.3	19.7	18.7	15.1	13.7	11.6	(27)
(28)			MCD B	10.1	8.1	9.0	10.5	14.8	17.2	20.0	20.0	19.3	15.5	13.8	11.8	(28)
(29)		2%	WB	8.4	6.5	7.3	8.7	11.4	15.2	18.2	18.8	17.4	14.2	12.2	10.4	(29)
(30)			MCD B	8.7	6.7	7.4	8.7	12.2	15.4	18.7	19.0	17.8	14.5	12.4	10.4	(30)
(31)		5%	WB	6.9	5.5	6.2	7.9	10.3	14.1	17.5	18.0	16.7	13.6	11.5	9.4	(31)
(32)			MCD B	7.2	5.8	6.5	8.0	10.9	14.5	17.7	18.2	17.0	13.8	11.6	9.6	(32)
(33)		10%	WB	5.0	4.3	5.0	7.0	9.5	13.3	16.8	17.4	16.0	12.9	10.9	8.0	(33)
(34)			MCD B	5.8	4.7	5.4	7.3	10.1	13.6	17.0	17.7	16.3	13.2	11.1	8.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	5.7	4.4	3.0	3.2	3.5	3.7	3.5	2.8	2.9	3.9	5.4	(35)
(36)			MCDBR	6.6	6.3	4.5	3.8	4.8	5.1	5.0	4.3	3.8	3.1	3.9	5.8	(36)
(37)			MCWBR	7.0	7.1	5.5	3.3	3.7	4.0	4.2	3.5	3.3	3.6	4.2	7.1	(37)
(38)		5% WB	MCD BR	5.8	6.1	5.1	3.5	4.9	4.6	4.8	3.9	3.3	3.1	3.1	6.4	(38)
(39)			MCWBR	7.2	7.2	5.9	3.2	3.8	4.0	4.2	3.6	3.1	3.9	4.1	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.313	0.332	0.359	0.382	0.419	0.436	0.411	0.367	0.340	0.323	0.306	(40)	
(41)		taud	2.494	2.496	2.476	2.427	2.408	2.329	2.300	2.358	2.456	2.524	2.533	2.510	(41)	
(42)		Ebn at Noon	826	886	909	905	890	854	834	843	859	841	799	789	(42)	
(43)		Edh at Noon	70	83	96	109	115	125	127	116	97	80	68	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.49	2.39	3.64	4.65	5.28	5.72	5.95	5.33	4.33	2.80	1.67	1.21	(44)	
(45)		RadStd	0.12	0.20	0.26	0.48	0.63	0.50	0.42	0.29	0.26	0.26	0.16	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+62	N/A

Nomenclature: See separate page