

DESTRUCTION ISLAND, WA, USAWMO: **994070**Lat: **47.6744N**Lon: **124.4870W**Elev: **70**StdP: **14.66**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.5	34.9	N/A	N/A	N/A	N/A	N/A	N/A	47.7	46.1	43.2	46.2	10.7	60	0.738

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	64.5	N/A	62.8	N/A	61.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.6	38.1	33.3	DB	29.7	73.0	2.7	4.5	27.7	76.2	26.1	78.9	24.6	81.4	22.6	84.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	44.9	44.0	45.4	47.5	51.1	54.5	56.4	56.7	56.2	52.5	47.4	44.3
	DBStd	5.99	4.45	4.09	3.59	3.18	3.44	2.91	2.78	2.66	2.95	3.34	4.11	4.40
	HDD50	886	164	170	148	87	24	1	0	0	0	14	96	182
	HDD65	5440	624	588	607	526	430	315	268	258	265	388	528	643
	CDD50	922	5	2	5	11	60	136	197	207	186	91	18	4
	CDD65	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH74	1	0	0	0	0	1	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.7	15.3	13.9	16.0	15.3	12.9	11.5	11.2	9.9	10.8	13.2	17.1	17.5
Precipitation	PrecAvg	101.2	16.5	9.3	11.0	7.1	4.5	3.3	1.7	2.8	3.9	10.0	15.5	14.5
	PrecMax	130.6	30.3	25.8	23.2	13.3	8.7	7.9	5.0	12.4	13.0	19.5	29.7	24.5
	PrecMin	70.3	9.6	0.0	1.1	1.0	0.8	0.9	0.2	0.0	0.0	0.4	4.1	6.5
	PrecStd	15.4	4.8	6.0	5.1	3.3	2.2	1.7	1.3	3.1	3.0	4.8	7.2	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	54.5	57.4	59.5	66.8	68.3	66.6	66.4	65.7	61.9	58.0	55.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	53.1	52.6	53.5	55.3	59.6	62.5	63.3	63.8	63.2	59.7	55.5	53.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	51.5	50.9	51.9	53.3	57.3	59.9	61.7	62.1	61.8	58.5	54.2	51.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.6	49.4	50.4	51.8	55.8	58.4	60.4	60.6	60.3	57.3	52.9	50.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.1	6.5	6.2	6.1	5.8	5.7	5.9	6.1	6.0	6.2	5.6
		MCDBR	6.5	7.4	8.3	8.2	7.6	7.7	7.4	7.5	7.5	6.8	6.7	6.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.321	0.336	0.364	0.390	0.358	0.348	0.351	0.344	0.338	0.327	0.316	
	taud	2.518	2.543	2.514	2.410	2.350	2.472	2.536	2.528	2.538	2.542	2.501	2.496	
	Ebn at Noon	243	270	282	282	277	287	288	283	276	259	237	229	
	Edh at Noon	20	24	28	34	38	34	31	30	27	23	20	18	
All-Sky Solar Radiation	RadAvg	314	601	927	1374	1665	1820	1838	1571	1237	725	383	266	
	RadStd	42	73	95	119	134	146	135	123	99	80	51	33	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page