

DESTRUCTION ISLAND, WA, USAWMO: **994070**Lat: **47.6744N**Lon: **124.4870W**Elev: **21**StdP: **101.07**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.3	1.6	N/A	N/A	N/A	N/A	N/A	N/A	21.3	7.8	19.3	7.9	4.8	60	0.738

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	18.0	N/A	17.1	N/A	16.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	17.0	14.9	-1.3	22.8	1.5	2.5	-2.4	24.6	-3.3	26.0	-4.1	27.4	-5.2	29.2		
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	7.1	6.7	7.5	8.6	10.6	12.5	13.5	13.7	13.4	11.4	8.6	6.8
	DBStd	3.33	2.47	2.27	1.99	1.77	1.91	1.62	1.55	1.48	1.64	1.86	2.28	2.45
	HDD10.0	492	91	94	82	48	13	1	0	0	0	8	53	101
	HDD18.3	3022	347	327	337	292	239	175	149	143	147	216	293	357
	CDD10.0	512	3	1	3	6	33	76	109	115	103	51	10	2
	CDD18.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	1	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.1	6.8	6.2	7.1	6.8	5.8	5.1	5.0	4.4	4.8	5.9	7.6	7.8
Precipitation	PrecAvg	2570	420	235	280	181	114	85	43	71	98	255	393	368
	PrecMax	3316	769	656	589	338	221	200	127	315	329	496	754	623
	PrecMin	1785	245	0	27	25	21	23	5	0	0	9	104	165
	PrecStd	390	123	152	129	85	55	43	34	78	77	122	184	111
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	12.5	14.1	15.3	19.3	20.2	19.2	19.1	18.7	16.6	14.5	13.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.7	11.4	11.9	12.9	15.3	16.9	17.4	17.7	17.4	15.4	13.1	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.8	10.5	11.0	11.8	14.0	15.5	16.5	16.7	16.5	14.7	12.4	10.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	10.3	9.7	10.2	11.0	13.2	14.7	15.8	15.9	15.7	14.0	11.6	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.1	3.4	3.6	3.5	3.4	3.2	3.2	3.3	3.4	3.3	3.5	3.1
		MCDBR	3.6	4.1	4.6	4.6	4.2	4.3	4.1	4.1	4.2	3.8	3.7	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.321	0.336	0.364	0.390	0.358	0.348	0.351	0.344	0.338	0.327	0.316	
	taud	2.518	2.543	2.514	2.410	2.350	2.472	2.536	2.528	2.538	2.542	2.501	2.496	
	Ebn at Noon	766	851	889	890	874	904	909	893	869	817	746	721	
	Edh at Noon	63	75	89	108	119	106	98	95	86	74	63	57	
All-Sky Solar Radiation	RadAvg	0.99	1.89	2.92	4.33	5.25	5.74	5.79	4.95	3.90	2.29	1.21	0.84	
	RadStd	0.13	0.23	0.30	0.38	0.42	0.46	0.42	0.39	0.31	0.25	0.16	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page