

ARIPEKA, FL, USA

WMO: 994082

Lat: 28.4331N

Lon: 82.6667W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.8	(c) 5.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.6	(k) 15.0	(l) 8.8	(m) 16.1	(n) 2.0	(o) 70	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.5	(c) 35.2	(d) N/A	(e) 34.2	(f) N/A	(g) 32.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.3	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.3	(b) 6.7	(c) 5.7	(e) 1.3	(f) 34.7	(g) 2.0	(h) 2.0	(i) -0.1	(j) 36.1	(k) -1.2	(l) 37.3	(m) -2.3	(n) 38.4	(o) -3.8	(p) 39.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	15.4	16.6	18.4	21.8	24.7	27.0	27.9	28.1	27.1	23.8	19.4	17.4		
	DBStd	5.67	4.90	4.91	4.05	2.83	2.43	1.89	1.70	1.52	1.88	3.44	3.71	4.91		
	HDD10.0	24	12	5	2	0	0	0	0	0	0	0	0	6		
	HDD18.3	371	116	83	51	6	0	0	0	0	0	5	31	78		
	CDD10.0	4524	180	189	262	353	456	511	554	561	513	428	283	234		
	CDD18.3	1830	26	34	53	109	197	261	296	302	263	175	64	49		
	CDH23.3	17333	123	212	239	699	1849	2869	3337	3521	2620	1381	291	192		
	CDH26.7	6318	21	66	32	160	552	1117	1410	1497	1006	383	48	27		
(14) Wind	WSAvg	2.5	2.5	2.4	2.7	2.8	2.9	2.6	2.4	2.6	2.3	2.4	2.4	2.3		
(15) Precipitation	PrecAvg	1304	68	75	77	62	45	185	217	202	170	83	38	68		
	PrecMax	1622	139	244	189	151	213	387	313	307	344	210	119	309		
	PrecMin	1022	21	8	8	5	4	35	127	108	44	3	9	15		
	PrecStd	176	36	60	51	39	45	77	61	50	83	48	30	89		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.1	31.5	29.4	33.0	34.9	36.0	36.1	35.9	35.9	34.8	30.5	29.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	26.6	28.9	27.7	30.2	33.2	34.0	35.0	34.4	34.5	32.1	27.9	27.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	24.4	25.7	26.1	28.4	31.4	32.3	33.3	32.7	32.5	30.0	26.3	25.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	22.4	23.2	24.7	26.8	29.5	30.8	31.3	31.4	30.8	28.7	25.0	24.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	8.6	8.5	8.3	7.6	6.5	6.7	6.5	7.1	8.0	8.7	8.6		
		MCDBR	10.2	10.7	10.1	10.5	9.9	8.2	8.8	8.0	8.9	8.5	9.4	9.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.356	0.367	0.391	0.426	0.455	0.482	0.464	0.423	0.389	0.353	0.341		
	taud		2.516	2.490	2.448	2.351	2.310	2.306	2.236	2.301	2.385	2.459	2.505	2.549		
	Ebn at Noon		899	916	923	905	869	839	815	829	856	868	879	885		
	Edh at Noon		91	101	111	126	132	132	141	131	117	102	91	84		
(44) All-Sky Solar Radiation	RadAvg		3.46	4.16	5.32	6.41	6.83	6.14	5.77	5.58	5.08	4.68	3.80	3.19		
	RadStd		0.24	0.29	0.47	0.36	0.39	0.48	0.35	0.35	0.35	0.30	0.22	0.27		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-5	-51	+164	+115

Nomenclature: See separate page