

POINT ARENA, CA, USA

WMO: 994120

Lat: 38.9549N

Lon: 123.7410W

Elev: 17

StdP: 101.12

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.0	5.2	N/A	N/A	N/A	N/A	N/A	N/A	17.6	11.2	15.6	10.9	3.0	70	0.698

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.5	16.7	N/A	15.6	N/A	14.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.9	12.5	11.1	DB	2.0	20.9	1.2	2.8	1.1	22.9	0.3	24.6	-0.4	26.1	-1.3	28.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	9.9	9.7	9.8	9.9	10.5	11.2	11.7	12.2	12.3	11.9	10.8	9.8
	DBStd	1.87	1.89	1.91	1.63	1.34	1.27	1.06	1.20	1.25	1.38	1.68	1.96	2.19
	HDD10.0	148	24	25	24	18	8	1	1	0	1	2	13	31
	HDD18.3	2743	260	241	266	254	243	213	204	191	182	198	225	266
	CDD10.0	449	23	18	16	14	23	39	54	68	68	62	39	24
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	0	0	1	1	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	5.1	5.4	6.2	6.0	6.5	6.4	5.3	5.0	4.7	4.9	4.9	5.2
Precipitation	PrecAvg	1232	236	223	142	78	50	12	1	3	2	53	125	277
	PrecMax	1911	719	685	436	266	178	64	4	33	13	145	321	625
	PrecMin	686	3	12	4	12	0	0	0	0	0	0	1	63
	PrecStd	367	170	164	126	67	56	17	1	7	3	41	92	195
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	15.9	15.2	14.5	16.2	15.1	16.0	16.8	17.0	19.0	17.7	15.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	14.0	14.2	13.9	13.2	13.9	14.1	15.0	15.7	15.7	16.4	15.2	14.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.4	13.3	13.1	12.5	13.0	13.4	14.2	14.7	14.9	14.9	14.3	13.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	12.8	12.5	12.3	11.9	12.4	12.9	13.6	14.1	14.2	14.0	13.6	13.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.9	3.8	3.4	2.8	2.2	2.1	2.1	2.3	2.5	3.4	3.8	4.1
		MCDBR	4.6	4.4	4.5	3.9	3.2	3.0	2.7	3.2	3.7	4.9	4.4	3.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.325	0.332	0.334	0.359	0.357	0.353	0.354	0.344	0.338	0.334	0.317	0.326	
	taud	2.557	2.540	2.551	2.439	2.483	2.497	2.503	2.531	2.528	2.574	2.598	2.554	
	Ebn at Noon	854	896	929	918	921	922	917	922	911	881	858	824	
	Edh at Noon	74	86	93	111	108	107	105	100	94	82	71	70	
All-Sky Solar Radiation	RadAvg	2.16	3.06	4.36	5.82	6.84	7.53	6.93	6.02	5.19	3.78	2.54	1.84	
	RadStd	0.33	0.42	0.40	0.44	0.48	0.39	0.37	0.33	0.31	0.28	0.23	0.30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	-1.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page