

POINT ARGUELLO, CA, USA

WMO: 994210

Lat: 34.5771N

Lon: 120.6470W

Elev: 32

StdP: 100.94

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.7	8.6	N/A	N/A	N/A	N/A	N/A	N/A	23.5	11.3	21.2	11.5	6.8	0	0.773

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	3.8	22.5	N/A	20.3	N/A	18.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.0	15.8	14.4	5.5	27.6	1.5	2.2	4.4	29.2	3.6	30.4	2.8	31.7	1.7	33.3		
			DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	13.1	12.3	12.2	11.6	11.9	12.7	13.7	14.0	14.5	15.2	14.2	12.7
	DBStd	2.20	2.41	2.15	1.95	1.51	1.54	1.16	1.55	1.39	1.75	2.58	2.37	1.96
	HDD10.0	11	2	3	2	2	1	0	0	0	0	0	1	2
	HDD18.3	1895	162	170	190	202	201	169	144	133	117	106	127	176
	CDD10.0	1174	99	67	71	50	59	81	114	125	135	161	127	85
	CDD18.3	16	1	1	1	0	1	0	1	0	1	8	3	0
	CDH23.3	39	1	1	1	1	4	0	1	0	3	19	8	0
	CDH26.7	3	0	0	0	0	0	0	0	0	1	2	0	0
Wind	WSAvg	7.6	6.3	6.9	7.5	8.3	9.0	8.5	8.0	8.6	8.0	6.8	6.6	6.6
Precipitation	PrecAvg	422	91	93	68	29	11	2	1	0	2	20	33	71
	PrecMax	828	415	398	320	109	62	17	7	2	11	101	114	236
	PrecMin	158	5	3	1	3	1	0	0	0	0	1	4	6
	PrecStd	167	90	84	72	28	14	5	2	1	3	24	28	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	21.4	20.4	19.3	22.8	16.8	21.3	18.8	21.9	25.6	24.6	19.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	19.8	18.2	17.4	15.5	15.9	15.6	17.7	17.6	19.0	22.6	20.7	17.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	18.0	16.2	15.7	14.3	14.4	15.0	16.6	17.0	17.5	20.0	18.6	16.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	16.3	14.9	14.6	13.4	13.6	14.4	15.8	16.3	16.6	18.4	16.9	15.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.0	3.3	3.3	2.7	2.2	2.2	2.1	2.3	2.8	3.8	3.9	3.5
		MCDBR	6.8	6.1	6.0	4.5	4.2	3.0	2.9	3.1	5.0	8.2	6.9	4.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.319	0.330	0.343	0.353	0.351	0.360	0.344	0.344	0.342	0.310	0.311	
	taud	2.600	2.575	2.541	2.490	2.486	2.485	2.518	2.531	2.535	2.543	2.603	2.599	
	Ebn at Noon	910	934	946	942	931	928	917	929	917	893	898	883	
	Edh at Noon	76	87	97	107	109	109	105	102	97	89	75	73	
All-Sky Solar Radiation	RadAvg	3.03	3.88	5.25	6.51	7.10	7.19	6.68	6.21	5.50	4.33	3.36	2.70	
	RadStd	0.23	0.38	0.33	0.40	0.51	0.38	0.29	0.35	0.35	0.35	0.20	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.60	N/A	-1.32	+0.81	N/A	N/A	N/A	-162	+223	+66

Nomenclature: See separate page