

VENICE PIER, FL, USA

WMO: 994220

Lat: 27.0725N

Lon: 82.4528W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.7	45.7	25.9	19.9	48.1	31.6	25.9	50.8	32.8	57.4	29.8	58.6	10.6	20	0.421

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	88.4	76.5	87.1	77.3	86.3	77.4	82.0	84.0	80.8	84.0	79.8	84.1	10.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.5	164.0	83.1	80.0	155.6	82.8	78.4	147.7	82.6	45.7	83.8	44.3	83.9	43.2	84.0	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Extreme Max WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	28.0	23.9	19.9	DB	35.0	91.4	3.7	1.1	32.4	92.2	30.2	92.8	28.2	93.4	25.5	94.2
(5)				WB	30.2	81.9	4.1	1.7	27.2	83.1	24.8	84.1	22.4	85.1	19.4	86.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.3	60.6	62.6	66.4	70.6	76.0	79.4	81.1	81.5	80.2	75.9	68.2	64.1
	DBStd	8.71	7.02	6.40	5.46	3.86	2.68	2.30	1.79	1.66	1.94	4.40	5.93	6.84
	HDD50	19	11	4	0	0	0	0	0	0	0	0	0	4
	HDD65	468	164	106	51	7	0	0	0	0	0	4	38	98
	CDD50	8151	340	357	510	618	806	883	963	978	906	803	546	441
	CDD65	3125	28	40	95	175	341	433	498	513	456	342	133	71
	CDH74	26807	30	46	140	646	2602	4306	5493	5782	4434	2668	526	134
	CDH80	7260	0	3	5	27	320	1126	1848	2049	1332	508	39	3
Wind	WSAvg	9.8	10.3	10.5	11.3	11.1	10.1	9.5	8.3	8.6	8.5	9.6	10.0	9.9
Precipitation	PrecAvg	55.3	2.6	2.6	3.0	2.8	2.5	9.3	8.4	8.5	8.0	3.7	1.6	2.3
	PrecMax	76.5	7.3	7.4	9.4	8.0	6.6	24.9	15.4	14.5	14.2	10.2	7.8	9.4
	PrecMin	37.8	0.1	0.1	0.4	0.4	0.3	3.7	4.1	4.0	2.4	0.5	0.0	0.1
	PrecStd	9.8	1.9	1.9	2.5	2.0	1.9	5.7	3.1	3.1	3.2	2.4	1.9	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	78.6	80.1	83.0	87.1	88.9	90.1	90.6	89.7	87.8	83.1	80.2
		MCWB	68.1	69.6	67.0	70.2	71.7	75.5	76.3	76.5	74.8	74.6	73.1	70.5
	2%	DB	74.4	75.1	77.2	80.3	84.4	86.5	87.2	88.1	87.7	85.7	81.1	77.4
		MCWB	67.8	70.1	69.0	72.8	72.0	77.3	77.9	78.0	75.7	74.5	73.2	70.5
	5%	DB	72.2	73.1	75.4	78.9	82.9	85.5	86.4	87.0	86.3	84.2	79.3	75.3
		MCWB	67.5	68.8	70.4	72.4	73.4	77.7	77.8	78.3	76.6	74.9	71.3	70.3
	10%	DB	70.2	71.2	74.2	77.6	81.8	84.5	85.8	86.3	85.3	82.8	77.3	73.5
		MCWB	66.6	68.0	70.1	71.8	74.1	77.5	77.8	78.2	77.1	74.9	70.3	69.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	73.5	75.5	77.9	80.5	83.3	83.7	82.3	82.0	79.4	77.4	74.5
		MCDB	73.8	74.4	76.3	79.9	80.7	83.6	84.1	85.7	84.9	82.3	80.5	76.2
	2%	WB	70.8	71.9	73.7	76.4	78.5	82.0	81.9	81.2	79.8	78.2	76.0	73.4
		MCDB	72.7	73.4	74.5	78.6	80.0	82.9	83.8	85.4	84.4	82.0	79.1	75.1
	5%	WB	69.1	70.4	72.5	74.9	77.3	80.3	80.3	80.3	78.9	77.4	74.2	72.1
		MCDB	71.3	72.1	73.8	77.4	80.0	83.0	84.1	85.1	83.8	81.8	77.1	74.0
	10%	WB	67.6	69.1	71.2	73.7	76.3	79.0	79.1	79.4	78.2	76.6	72.4	70.8
		MCDB	69.7	70.8	73.0	76.4	79.7	83.1	84.1	84.9	83.3	81.1	75.5	73.1
Mean Daily Temperature Range	5% DB	MDBR	13.2	11.6	11.3	10.5	10.0	9.0	9.1	9.5	10.3	11.7	13.3	13.2
		MCDBR	14.3	12.7	13.0	13.3	13.2	11.0	10.2	10.6	11.9	12.6	13.9	13.6
		MCWBR	8.7	8.0	7.7	7.6	6.6	5.6	5.3	4.7	4.6	5.1	7.1	8.0
	5% WB	MCDBR	10.6	8.5	8.6	8.3	9.0	8.5	9.3	8.7	9.4	9.1	10.0	10.1
		MCWBR	8.6	6.3	7.4	7.2	6.5	6.5	6.2	5.0	4.8	5.0	7.2	8.0
Clear-Sky Solar Irradiance	taub	0.346	0.360	0.371	0.394	0.422	0.443	0.464	0.446	0.422	0.394	0.357	0.350	
	taud	2.535	2.505	2.460	2.364	2.346	2.365	2.307	2.379	2.409	2.470	2.516	2.551	
	Ebn at Noon	286	291	292	287	277	269	264	268	273	276	280	280	
	Edh at Noon	29	32	35	40	40	39	42	39	36	33	29	27	
All-Sky Solar Radiation	RadAvg	1165	1422	1772	2103	2217	2010	1933	1853	1666	1536	1272	1080	
	RadStd	89	92	134	90	126	173	115	105	107	91	67	83	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.77	+1.53	N/A	N/A	N/A	N/A	-5	-76	+301	+209

Nomenclature: See separate page