

VENICE PIER, FL, USA

WMO: 994220

Lat: 27.0725N

Lon: 82.4528W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.4	7.6	-3.4	2.8	8.9	-0.2	3.7	10.4	14.7	14.1	13.3	14.8	4.8	20	0.421

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	31.3	24.7	30.6	25.2	30.2	25.2	27.8	28.9	27.1	28.9	26.6	28.9	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.4	28.4	26.7	22.2	28.2	25.8	21.1	28.1	88.4	28.8	85.2	28.8	82.6	28.9	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	10.7	8.9	1.7	33.0	2.0	0.6	0.2	33.4	-1.0	33.8	-2.1	34.1	-3.6	34.6
			-1.0	27.7	2.3	0.9	-2.7	28.4	-4.0	28.9	-5.3	29.5	-7.0	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.4	15.9	17.0	19.1	21.4	24.4	26.4	27.3	27.5	26.8	24.4	20.1	17.8
	DBStd	4.84	3.90	3.56	3.03	2.15	1.49	1.28	0.99	0.92	1.08	2.45	3.29	3.80
	HDD10.0	11	6	2	0	0	0	0	0	0	0	0	0	2
	HDD18.3	260	91	59	28	4	0	0	0	0	0	2	21	54
	CDD10.0	4528	189	198	283	343	448	491	535	543	503	446	303	245
	CDD18.3	1736	16	22	53	97	189	241	277	285	253	190	74	39
	CDH23.3	14893	17	26	78	359	1446	2392	3052	3212	2463	1482	292	74
CDH26.7	4033	0	2	3	15	178	626	1027	1138	740	282	22	2	
Wind	WSAvg	4.4	4.6	4.7	5.1	5.0	4.5	4.3	3.7	3.8	3.8	4.3	4.5	4.4
Precipitation	PrecAvg	1405	65	65	77	72	63	236	214	216	202	94	41	58
	PrecMax	1942	185	187	240	202	168	632	392	368	361	260	198	238
	PrecMin	961	2	3	9	9	8	95	105	101	60	12	0	3
	PrecStd	250	48	47	63	50	48	144	79	79	82	62	48	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	25.9	26.7	28.3	30.6	31.6	32.3	32.6	32.0	31.0	28.4	26.8
		MCWB	20.1	20.9	19.4	21.2	22.1	24.2	24.6	24.7	23.8	23.7	22.8	21.4
	2%	DB	23.5	24.0	25.1	26.8	29.1	30.3	30.7	31.1	30.9	29.8	27.3	25.2
		MCWB	19.9	21.2	20.5	22.7	22.2	25.2	25.5	25.5	24.3	23.6	22.9	21.4
	5%	DB	22.3	22.8	24.1	26.1	28.3	29.7	30.2	30.6	30.2	29.0	26.3	24.1
		MCWB	19.7	20.4	21.3	22.4	23.0	25.4	25.5	25.7	24.8	23.8	21.8	21.3
	10%	DB	21.2	21.8	23.5	25.3	27.7	29.2	29.9	30.2	29.6	28.2	25.2	23.1
		MCWB	19.2	20.0	21.2	22.1	23.4	25.3	25.4	25.7	25.0	23.8	21.3	21.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.0	24.2	25.5	26.9	28.5	28.7	27.9	27.8	26.4	25.2	23.6
		MCDB	23.2	23.6	24.6	26.6	27.1	28.7	28.9	29.8	29.4	27.9	26.9	24.5
	2%	WB	21.5	22.2	23.2	24.7	25.8	27.8	27.7	27.3	26.6	25.7	24.4	23.0
		MCDB	22.6	23.0	23.6	25.9	26.7	28.3	28.8	29.7	29.1	27.8	26.2	24.0
	5%	WB	20.6	21.3	22.5	23.8	25.2	26.8	26.8	26.8	26.0	25.2	23.4	22.3
		MCDB	21.8	22.3	23.2	25.2	26.6	28.3	28.9	29.5	28.8	27.7	25.1	23.4
	10%	WB	19.8	20.6	21.8	23.2	24.6	26.1	26.2	26.4	25.6	24.8	22.4	21.5
		MCDB	20.9	21.6	22.8	24.7	26.5	28.4	28.9	29.4	28.5	27.3	24.2	22.8
Mean Daily Temperature Range	5% DB	MDBR	7.3	6.4	6.3	5.8	5.6	5.0	5.1	5.3	5.7	6.5	7.4	7.3
		MCDBR	8.0	7.1	7.2	7.4	7.3	6.1	5.7	5.9	6.6	7.0	7.7	7.6
		MCWBR	4.8	4.4	4.3	4.2	3.7	3.1	2.9	2.6	2.6	2.8	3.9	4.4
	5% WB	MCDBR	5.9	4.7	4.8	4.6	5.0	4.7	5.2	4.8	5.2	5.1	5.5	5.6
		MCWBR	4.8	3.5	4.1	4.0	3.6	3.6	3.4	2.8	2.7	2.8	4.0	4.4
Clear-Sky Solar Irradiance	taub	0.346	0.360	0.371	0.394	0.422	0.443	0.464	0.446	0.422	0.394	0.357	0.350	
	taud	2.535	2.505	2.460	2.364	2.346	2.365	2.307	2.379	2.409	2.470	2.516	2.551	
	Ebn at Noon	903	916	922	905	874	849	831	846	861	869	883	883	
	Edh at Noon	90	100	111	125	127	124	131	122	115	103	91	86	
All-Sky Solar Radiation	RadAvg	3.67	4.48	5.59	6.63	6.99	6.33	6.09	5.84	5.25	4.84	4.01	3.40	
	RadStd	0.28	0.29	0.42	0.28	0.40	0.54	0.36	0.33	0.34	0.29	0.21	0.26	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	+0.43	+0.85	N/A	N/A	N/A	N/A	-3	-42	+167

Nomenclature: See separate page