

CAPE ARAGO, OR, USA

WMO: 994240

Lat: 43.3412N

Lon: 124.3750W

Elev: 59

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	35.4	37.5	26.7	20.7	41.9	31.2	25.5	41.9	56.9	48.9	50.4	49.2	10.4	140	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	65.6	59.6	63.5	59.0	62.0	58.4	60.5	61.7	59.5	60.7	58.5	59.7	9.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	77.8	61.0	59.0	74.6	60.0	57.8	71.6	58.9	26.8	61.9	26.0	60.9	25.3	59.8	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.3	36.3	31.0	DB	31.6	71.7	3.7	5.6	28.9	75.7	26.7	79.0	24.6	82.1	21.9	86.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	48.1	47.5	47.7	48.7	51.8	54.3	54.9	56.2	55.1	53.4	50.4	47.7
	DBStd	4.88	4.46	3.90	3.56	3.11	3.06	2.48	3.25	3.50	3.80	3.55	4.16	4.62
	HDD50	491	90	85	88	58	15	1	1	0	2	8	43	100
	HDD65	4983	524	489	536	488	409	320	312	273	296	360	438	538
	CDD50	986	31	16	17	20	71	131	154	193	156	114	56	27
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH74	4	0	0	0	0	1	0	0	0	1	2	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.3	14.0	13.6	15.3	14.0	13.3	11.4	9.4	8.6	9.8	11.6	13.1	14.2
Precipitation	PrecAvg	59.1	9.1	7.0	7.4	5.2	3.1	1.7	0.4	0.5	1.2	4.3	8.4	10.7
	PrecMax	99.3	20.0	14.6	13.0	10.7	8.3	4.3	2.1	2.1	5.3	13.7	18.6	21.4
	PrecMin	32.3	2.2	2.8	3.0	2.8	0.1	0.2	0.0	0.0	0.0	0.4	2.6	2.9
	PrecStd	13.9	5.2	3.3	2.9	2.3	2.0	1.0	0.4	0.5	1.4	2.9	4.1	4.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	59.8	60.2	60.1	64.5	63.2	65.6	69.0	68.6	66.2	62.5	60.4
		MCWB	52.5	50.3	51.6	51.0	55.8	58.9	61.8	58.2	59.6	57.5	57.8	55.0
	2%	DB	57.8	56.7	56.9	56.4	59.5	61.0	63.2	65.7	64.6	62.3	59.9	58.0
		MCWB	52.6	49.6	50.2	52.0	55.4	57.5	59.8	61.1	60.5	57.2	56.4	53.7
	5%	DB	56.0	54.8	54.5	54.4	57.5	59.5	61.4	63.2	62.4	60.0	57.9	56.0
		MCWB	51.7	49.7	49.6	51.0	54.2	56.4	58.7	60.0	60.1	56.3	54.9	52.5
	10%	DB	54.5	53.0	52.8	53.2	56.1	58.3	59.8	61.4	60.8	58.6	56.2	54.2
		MCWB	50.8	49.2	49.1	50.2	53.3	55.5	57.8	59.1	59.1	55.6	53.5	51.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	53.4	53.3	54.6	57.5	59.9	61.9	61.5	62.4	60.8	59.5	57.2
		MCDB	57.8	54.9	55.0	55.8	60.3	60.7	63.5	62.9	62.9	61.7	61.4	59.4
	2%	WB	54.3	51.8	51.5	52.7	55.4	57.8	59.8	60.0	60.6	58.8	57.6	55.2
		MCDB	55.7	53.6	52.9	54.3	57.6	59.2	61.1	61.4	61.3	59.6	58.9	57.1
	5%	WB	52.7	50.7	50.4	51.3	54.2	56.8	58.6	59.0	59.2	57.2	55.7	53.6
		MCDB	54.4	52.7	52.0	52.9	56.0	58.2	59.9	60.2	60.2	58.3	57.3	55.3
	10%	WB	51.0	49.5	49.5	50.3	53.0	55.8	57.4	57.8	57.5	55.8	53.7	51.7
		MCDB	52.9	51.6	51.2	52.0	54.7	57.3	58.6	58.7	58.4	56.9	55.1	53.2
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.1	7.7	7.1	6.2	6.0	5.7	6.5	6.8	7.8	7.9	8.3
		MCDBR	8.8	10.1	9.6	8.8	8.0	7.8	7.8	9.4	9.5	9.8	9.1	9.3
		MCWBR	6.9	7.1	6.8	6.4	5.3	4.7	5.1	6.3	7.5	6.4	6.6	6.6
	5% WB	MCDBR	7.8	8.2	7.7	7.0	7.1	6.3	6.5	7.4	8.8	7.5	7.5	7.8
		MCWBR	6.8	6.3	6.4	5.7	5.3	4.7	5.0	5.7	6.9	6.2	6.1	6.7
Clear-Sky Solar Irradiance	taub	0.321	0.322	0.330	0.361	0.367	0.355	0.347	0.351	0.343	0.333	0.323	0.327	
	taud	2.556	2.562	2.555	2.422	2.442	2.487	2.524	2.530	2.539	2.570	2.570	2.522	
	Ebn at Noon	260	280	291	287	287	290	291	287	282	272	256	245	
	Edh at Noon	22	25	28	35	35	34	32	31	29	24	21	21	
All-Sky Solar Radiation	RadAvg	478	736	1084	1538	1915	2093	2212	1856	1486	932	539	393	
	RadStd	69	84	118	111	122	133	115	132	95	84	67	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	-0.97	N/A	N/A	-1.93	N/A	N/A	N/A	+400	N/A	N/A
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+9

Nomenclature: See separate page