

CAPE ARAGO, OR, USA

WMO: 994240

Lat: 43.3412N

Lon: 124.3750W

Elev: 18

StdP: 101.11

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	3.0	-3.0	3.0	5.5	-0.4	3.6	5.5	25.5	9.4	22.5	9.6	4.6	140	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	18.7	15.3	17.5	15.0	16.6	14.7	15.8	16.5	15.3	15.9	14.7	15.4	4.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	11.1	16.1	15.0	10.7	15.5	14.4	10.2	15.0	44.5	16.6	42.7	16.0	41.0	15.4	19.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	16.2	13.9	-0.2	22.0	2.1	3.1	-1.7	24.3	-3.0	26.1	-4.1	27.8	-5.6	30.1		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	8.9	8.6	8.7	9.3	11.0	12.4	12.7	13.5	12.9	11.9	10.2	8.7
	DBStd	2.71	2.48	2.17	1.98	1.73	1.70	1.38	1.80	1.94	2.11	1.97	2.31	2.57
	HDD10.0	273	50	47	49	32	8	1	1	0	1	4	24	56
	HDD18.3	2768	291	272	298	271	227	178	173	152	164	200	243	299
	CDD10.0	548	17	9	9	11	39	73	86	107	87	63	31	15
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	2	0	0	0	0	1	0	0	0	1	1	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	6.2	6.1	6.8	6.2	5.9	5.1	4.2	3.9	4.4	5.2	5.8	6.3
Precipitation	PrecAvg	1500	232	178	189	132	80	42	9	12	31	110	213	273
	PrecMax	2523	507	372	329	272	210	108	53	53	135	347	472	543
	PrecMin	820	57	72	76	70	3	4	0	0	1	9	67	73
	PrecStd	354	133	83	73	59	51	25	11	13	35	73	105	124
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	15.4	15.7	15.6	18.0	17.3	18.6	20.6	20.3	19.0	16.9	15.8
		MCWB	11.4	10.2	10.9	10.6	13.2	14.9	16.5	14.6	15.3	14.2	14.3	12.8
	2%	DB	14.4	13.7	13.8	13.5	15.3	16.1	17.3	18.7	18.1	16.9	15.5	14.5
		MCWB	11.4	9.8	10.1	11.1	13.0	14.2	15.5	16.2	15.8	14.0	13.6	12.1
	5%	DB	13.4	12.7	12.5	12.5	14.2	15.3	16.3	17.3	16.9	15.6	14.4	13.4
		MCWB	11.0	9.9	9.8	10.5	12.3	13.6	14.8	15.5	15.6	13.5	12.7	11.4
	10%	DB	12.5	11.6	11.5	11.8	13.4	14.6	15.4	16.3	16.0	14.8	13.5	12.3
		MCWB	10.5	9.6	9.5	10.1	11.8	13.1	14.3	15.0	15.1	13.1	11.9	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	11.9	11.8	12.6	14.1	15.5	16.6	16.4	16.9	16.0	15.3	14.0
		MCDB	14.4	12.7	12.8	13.2	15.7	15.9	17.5	17.2	17.2	16.5	16.3	15.2
	2%	WB	12.4	11.0	10.8	11.5	13.0	14.4	15.4	15.6	15.9	14.9	14.2	12.9
		MCDB	13.2	12.0	11.6	12.4	14.2	15.1	16.2	16.3	16.3	15.3	14.9	13.9
	5%	WB	11.5	10.4	10.2	10.7	12.3	13.8	14.8	15.0	15.1	14.0	13.2	12.0
		MCDB	12.4	11.5	11.1	11.6	13.3	14.6	15.5	15.7	15.7	14.6	14.0	13.0
	10%	WB	10.5	9.7	9.7	10.2	11.7	13.2	14.1	14.3	14.1	13.2	12.1	10.9
		MCDB	11.6	10.9	10.6	11.1	12.6	14.1	14.8	14.9	14.6	13.9	12.8	11.8
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.5	4.3	3.9	3.4	3.3	3.2	3.6	3.8	4.3	4.4	4.6
		MCDBR	4.9	5.6	5.3	4.9	4.4	4.3	4.4	5.2	5.3	5.5	5.1	5.1
		MCWBR	3.8	3.9	3.8	3.6	3.0	2.6	2.8	3.5	4.2	3.5	3.7	3.7
	5% WB	MCDBR	4.3	4.5	4.3	3.9	3.9	3.5	3.6	4.1	4.9	4.2	4.2	4.4
		MCWBR	3.8	3.5	3.6	3.2	2.9	2.6	2.8	3.2	3.8	3.4	3.4	3.7
Clear-Sky Solar Irradiance	taub	0.321	0.322	0.330	0.361	0.367	0.355	0.347	0.351	0.343	0.333	0.323	0.327	
	taud	2.556	2.562	2.555	2.422	2.442	2.487	2.524	2.530	2.539	2.570	2.570	2.522	
	Ebn at Noon	819	882	916	905	905	915	918	905	890	856	808	772	
	Edh at Noon	68	79	89	110	111	106	102	98	90	77	66	65	
All-Sky Solar Radiation	RadAvg	1.51	2.32	3.42	4.85	6.04	6.60	6.97	5.85	4.69	2.94	1.70	1.24	
	RadStd	0.22	0.27	0.37	0.35	0.39	0.42	0.36	0.41	0.30	0.26	0.21	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	-0.54	N/A	N/A	-1.07	N/A	N/A	N/A	+222	N/A	N/A
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+5

Nomenclature: See separate page