

SABINE PASS, TX, USA

WMO: 994260

Lat: 29.6834N

Lon: 94.0333W

Elev: 3

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.2	36.0	18.2	13.7	38.7	23.6	17.9	43.0	34.1	54.4	28.5	53.3	11.5	0	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.7	89.2	77.3	87.7	77.7	86.8	77.6	80.6	85.4	80.1	85.1	79.5	84.8	9.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.6	83.9	78.4	147.6	83.7	77.9	144.9	83.6	44.2	85.6	43.4	85.1	42.9	84.9	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.4	28.1	23.7	DB	26.9	93.8	3.4	2.8	24.5	95.8	22.6	97.5	20.7	99.0	18.3	101.1	(4)
			WB	23.6	81.8	2.8	0.9	21.6	82.5	20.0	83.0	18.4	83.5	16.3	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.6	51.7	54.8	61.0	68.1	75.3	80.8	82.3	82.5	78.7	71.1	61.6	54.2	(6)
		DBStd	12.56	7.89	7.78	6.99	5.48	4.07	2.70	2.24	2.61	4.09	6.45	7.72	8.12	(7)
		HDD50	190	77	42	10	0	0	0	0	0	0	10	51		(8)
		HDD65	1407	412	290	155	33	2	0	0	0	23	149	343		(9)
		CDD50	6971	131	175	352	542	783	923	1002	1008	860	655	359	181	(10)
		CDD65	2710	0	3	31	125	320	473	537	543	410	212	48	8	(11)
		CDH74	27021	1	1	14	210	2150	5418	6733	6824	4241	1383	45	1	(12)
		CDH80	8587	0	0	2	8	118	1635	2604	2830	1248	141	1	0	(13)
(14)	Wind	WSAvg	12.1	11.4	12.0	12.8	14.4	15.1	13.1	11.6	10.6	10.7	11.7	11.0	11.0	(14)
(15)	Precipitation	PrecAvg	57.8	5.0	3.6	3.8	3.9	4.7	5.9	5.9	5.1	6.1	5.2	4.1	4.8	(15)
(16)		PrecMax	80.3	11.7	7.9	8.2	10.2	10.3	17.4	15.2	12.5	14.4	16.3	10.0	12.2	(16)
(17)		PrecMin	31.7	0.7	1.0	0.6	0.3	0.0	0.7	1.2	0.8	1.3	0.7	0.4	1.1	(17)
(18)		PrecStd	12.1	2.7	2.1	2.0	2.6	3.1	3.4	3.4	2.9	4.5	2.3	2.3	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	68.0	71.4	75.5	80.6	84.4	90.4	89.7	92.4	91.3	85.2	77.3	73.1		(19)
(20)		0.4% MCWB	61.3	66.4	65.3	66.9	73.3	77.7	76.9	76.1	74.7	75.7	70.8	70.8		(20)
(21)		2% DB	65.3	68.5	72.9	77.6	82.3	87.3	87.5	89.5	87.3	83.0	75.3	69.6		(21)
(22)		2% MCWB	62.7	66.7	68.4	71.3	74.6	77.6	77.8	77.6	76.2	75.9	71.5	67.6		(22)
(23)		5% DB	63.7	66.2	71.2	76.3	81.3	86.0	86.9	88.2	86.0	81.5	73.7	68.0		(23)
(24)		5% MCWB	61.9	64.8	68.1	71.3	75.0	77.1	77.7	77.9	76.5	75.9	70.2	66.4		(24)
(25)		10% DB	62.1	64.4	69.7	75.1	80.4	84.9	86.3	87.1	84.9	80.3	72.2	66.1		(25)
(26)		10% MCWB	60.4	62.9	67.1	70.9	74.6	76.9	77.7	78.0	76.6	74.9	68.7	64.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	66.0	70.5	72.6	75.3	78.6	81.3	80.5	82.0	82.3	80.0	74.8	71.2		(27)
(28)		0.4% MCDB	66.4	70.8	73.1	76.9	81.0	86.2	85.4	86.6	84.1	82.3	76.2	72.8		(28)
(29)		2% WB	64.3	68.0	70.8	74.2	77.4	80.1	80.0	80.8	80.1	78.8	72.7	69.0		(29)
(30)		2% MCDB	64.7	68.4	71.6	76.1	80.3	84.8	85.2	86.1	84.0	81.5	74.2	69.8		(30)
(31)		5% WB	62.8	65.9	69.2	73.2	76.5	79.3	79.4	80.2	79.2	77.7	71.2	67.2		(31)
(32)		5% MCDB	63.3	66.3	70.2	75.3	79.7	83.9	85.0	85.8	83.7	80.8	72.9	68.0		(32)
(33)		10% WB	61.2	64.2	68.0	72.3	75.7	78.6	78.9	79.6	78.3	76.3	69.6	65.1		(33)
(34)		10% MCDB	61.8	64.6	69.3	74.5	79.2	83.5	84.7	85.6	83.3	79.7	71.4	66.0		(34)
(35)	Mean Daily Temperature Range	MDBR	11.2	9.9	9.6	8.4	6.7	7.2	7.3	8.7	10.3	11.0	11.5	11.8		(35)
(36)		5% DB MCDBR	11.0	10.4	9.5	9.3	7.9	9.5	8.3	11.1	11.0	9.5	10.0	10.5		(36)
(37)		5% DB MCWBR	9.9	7.7	7.4	6.0	4.8	4.6	4.1	4.8	5.5	6.0	7.9	9.7		(37)
(38)		5% WB MCDBR	9.0	6.9	6.8	5.8	5.5	6.7	7.6	8.5	7.3	7.5	9.5	8.6		(38)
(39)		5% WB MCWBR	9.7	6.9	6.2	5.6	4.5	4.7	4.4	4.6	5.2	6.3	9.2	8.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.361	0.378	0.435	0.479	0.481	0.496	0.478	0.455	0.387	0.374	0.354		(40)
(41)		taud	2.520	2.488	2.432	2.273	2.181	2.230	2.216	2.272	2.298	2.473	2.450	2.503		(41)
(42)		Ebn at Noon	282	287	288	274	261	259	255	259	261	274	269	273		(42)
(43)		Edh at Noon	28	32	36	43	48	45	45	43	40	32	30	28		(43)
(44)	All-Sky Solar Radiation	RadAvg	922	1050	1457	1750	1973	2023	1910	1809	1591	1408	1067	821		(44)
(45)		RadStd	90	172	128	129	129	146	162	148	167	173	105	92		(45)

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (31 neighbors)	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+158	(47)

Nomenclature: See separate page