

ISLE OF SHOALS, NH, USA

WMO: 994270

Lat: 42.9672N

Lon: 70.6233W

Elev: 13

StdP: 101.17

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-11.3	-22.9	0.5	-12.0	-20.8	0.6	-9.8	21.3	-1.1	19.2	-4.6	11.3	300	0.798

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	27.3	20.3	25.5	19.4	24.0	18.9	22.2	24.8	21.3	23.7	20.6	22.7	7.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.1	23.2	20.6	15.3	22.3	19.9	14.6	21.7	65.2	24.7	62.0	23.9	59.3	22.7	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	16.0	14.4	DB	-17.1	31.3	2.8	1.8	-19.1	32.6	-20.7	33.6	-22.3	34.6	-24.3	35.9
			WB	-17.7	23.8	2.5	1.2	-19.5	24.7	-21.0	25.4	-22.4	26.1	-24.3	27.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-2.0	-1.1	2.0	7.0	11.6	16.6	20.1	19.7	16.7	11.6	6.4	1.9	(6)
(7)		DBStd	8.52	5.45	4.65	4.11	3.50	3.50	3.38	2.56	2.28	2.83	3.19	4.08	4.32	(7)
(8)		HDD10.0	1451	372	312	252	102	20	1	0	0	19	121	252		(8)
(9)		HDD18.3	3469	631	545	508	339	211	73	10	11	64	209	359	509	(9)
(10)		CDD10.0	1183	1	0	2	13	71	198	314	302	202	69	12	1	(10)
(11)		CDD18.3	161	0	0	0	0	3	21	66	54	16	1	0	0	(11)
(12)		CDH23.3	483	0	0	1	2	14	83	219	122	39	3	0	0	(12)
(13)		CDH26.7	74	0	0	0	0	2	13	38	16	5	0	0	0	(13)
(14)	Wind	WSAvg	7.3	8.9	8.6	8.2	7.5	6.8	6.3	6.0	5.7	6.1	7.4	8.0	8.7	(14)
(15)	Precipitation	PrecAvg	1210	99	89	113	103	92	99	85	89	102	115	101	115	(15)
(16)		PrecMax	1668	166	216	421	257	427	286	215	202	223	338	202	186	(16)
(17)		PrecMin	861	28	41	18	11	16	13	31	25	41	5	29	37	(17)
(18)		PrecStd	194	31	38	82	55	77	64	49	49	52	82	41	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	11.1	18.6	21.6	25.2	28.6	29.7	28.9	26.8	22.9	17.9	13.4	(19)
(20)		MCWB	10.7	7.0	11.6	13.1	16.1	20.5	22.3	20.5	20.4	16.2	14.2	11.5		(20)
(21)		2%	DB	9.1	8.2	11.8	16.5	22.0	25.8	27.6	26.2	24.2	19.1	14.9	10.7	(21)
(22)		MCWB	7.6	5.3	6.9	10.7	15.6	18.3	21.2	20.1	18.6	15.3	11.6	8.9		(22)
(23)		5%	DB	7.3	6.2	8.8	13.9	19.0	23.5	25.7	24.6	22.3	17.0	13.1	9.4	(23)
(24)		MCWB	5.4	3.7	5.4	9.3	14.8	18.1	20.0	19.5	18.4	14.5	10.6	7.7		(24)
(25)		10%	DB	5.2	4.7	6.8	11.7	16.6	21.7	24.1	23.1	20.6	15.6	11.8	7.9	(25)
(26)		MCWB	3.4	2.7	4.2	7.5	13.2	17.1	19.2	19.1	17.8	13.4	9.8	6.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	8.7	12.8	14.9	19.2	22.2	24.1	22.7	21.8	18.2	15.1	12.1	(27)
(28)		MDCB	12.0	9.9	16.3	18.5	22.5	25.0	27.6	25.2	24.2	19.7	16.9	13.0		(28)
(29)		2%	WB	8.1	5.7	8.2	12.2	17.3	20.6	22.8	21.7	20.7	16.7	12.8	9.9	(29)
(30)		MDCB	8.7	6.8	10.4	15.5	19.8	23.9	25.5	23.9	22.8	18.1	13.7	10.7		(30)
(31)		5%	WB	5.8	4.3	6.0	10.2	15.7	19.2	21.6	21.0	19.7	15.4	11.4	8.4	(31)
(32)		MDCB	6.8	5.5	7.6	12.9	18.0	21.6	24.1	23.0	21.5	16.4	12.5	9.1		(32)
(33)		10%	WB	3.5	2.8	4.8	8.5	14.0	18.0	20.7	20.4	18.5	14.3	10.3	6.6	(33)
(34)		MDCB	5.0	4.3	6.4	10.7	16.0	20.2	22.7	22.3	20.1	15.5	11.7	7.7		(34)
(35)	Mean Daily Temperature Range	MDBR	6.3	6.0	5.4	5.3	5.4	5.5	5.4	5.0	4.8	4.7	5.0	5.6	(35)	
(36)		5% DB	MCDBR	7.6	7.1	8.1	9.3	10.0	9.3	8.2	7.3	7.3	6.5	6.3	6.7	(36)
(37)		MCWBR	7.9	6.3	5.9	6.0	6.0	4.9	4.1	3.9	4.1	4.8	5.7	6.6	(37)	
(38)		5% WB	MCDBR	7.5	6.4	7.1	8.2	8.3	7.8	6.3	5.6	5.9	5.4	5.6	6.7	(38)
(39)		MCWBR	8.2	6.6	6.2	6.6	6.3	5.2	4.3	4.0	4.4	4.9	5.7	7.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.291	0.300	0.321	0.360	0.396	0.445	0.461	0.428	0.376	0.334	0.312	0.295	(40)	
(41)		taud	2.508	2.504	2.502	2.427	2.366	2.265	2.225	2.305	2.433	2.546	2.565	2.564	(41)	
(42)		Ebn at Noon	858	909	926	908	878	833	813	830	853	856	826	823	(42)	
(43)		Edh at Noon	70	83	94	110	120	133	137	123	100	79	67	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.70	2.57	3.62	4.63	5.18	5.58	5.88	5.32	4.26	2.79	1.85	1.38	(44)	
(45)		RadStd	0.11	0.21	0.24	0.50	0.57	0.48	0.38	0.23	0.26	0.24	0.15	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-139	+128	+43
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+86	+34

Nomenclature: See separate page