

CAPE FLATTERY LH, WA, USA

WMO: 994300

Lat: 48.3915N

Lon: 124.7370W

Elev: 101

StdP: 14.64

Time Zone: -8.00 (NAP)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.1	(c) 34.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 60.1	(k) 46.9	(l) 53.0	(m) 43.5	(n) 22.2	(o) 90	(p) 0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.9	(c) 63.7	(d) N/A	(e) 61.7	(f) N/A	(g) 60.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 9.9	(p) 80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 48.7	(b) 40.7	(c) 34.7	(e) 29.3	(f) 71.9	(g) 3.7	(h) 3.6	(i) 26.6	(j) 74.5	(k) 24.5	(l) 76.6	(m) 22.4	(n) 78.7	(o) 19.8	(p) 81.3		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	43.8	43.8	45.0	47.1	50.4	53.5	55.4	56.0	55.0	51.6	46.8	43.8
	DBStd	5.72	4.38	3.90	3.24	3.09	3.03	2.71	2.81	2.34	2.80	3.05	4.06	4.18
	HDD50	975	193	174	158	96	29	3	0	0	1	17	109	195
	HDD65	5696	656	592	620	536	452	347	296	280	300	414	546	657
	CDD50	751	2	1	3	10	42	106	169	185	150	68	12	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.0	19.7	18.5	15.4	13.2	11.5	9.6	10.1	10.0	10.6	14.1	17.2	18.2
Precipitation	PrecAvg	103.9	17.4	10.2	10.4	7.4	3.9	3.0	1.9	2.8	3.8	10.9	16.7	15.7
	PrecMax	136.7	27.3	26.5	20.2	14.3	7.1	6.6	4.6	12.2	10.9	21.5	30.0	25.7
	PrecMin	80.0	10.2	1.2	1.5	1.9	0.7	1.0	0.2	0.2	0.4	1.2	6.6	7.8
	PrecStd	15.2	4.6	5.8	4.6	3.5	1.9	1.5	1.3	2.9	2.5	4.8	7.1	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	53.9	55.1	58.4	63.4	67.2	67.7	65.7	65.3	61.9	57.2	54.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	51.7	51.8	52.4	54.6	57.8	60.4	62.5	62.5	62.2	59.1	55.1	52.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.5	50.2	50.7	52.5	55.5	58.3	60.6	60.8	60.4	57.4	53.6	50.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	49.3	48.8	49.5	50.9	54.2	56.9	59.3	59.5	59.2	56.1	52.1	49.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.1	5.6	5.6	5.4	5.6	5.5	5.9	6.6	5.5	5.0	4.8
		MCDBR	6.4	6.3	7.2	7.7	7.8	7.9	8.2	8.4	9.1	6.9	6.3	6.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.317	0.314	0.333	0.355	0.372	0.354	0.346	0.348	0.339	0.333	0.319	0.311	
	taud	2.525	2.571	2.527	2.455	2.424	2.495	2.495	2.560	2.553	2.569	2.561	2.537	2.507
	Ebn at Noon	242	272	282	285	282	288	289	284	277	259	238	228	
	Edh at Noon	19	23	28	33	35	33	30	29	26	23	19	17	
All-Sky Solar Radiation	RadAvg	292	575	872	1336	1663	1818	1867	1564	1205	687	353	241	
	RadStd	41	81	103	120	128	158	116	128	94	87	57	33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (62 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page