

GALLOO ISLAND, NY, USA

WMO: 994320

Lat: 43.8885N

Lon: 76.4443W

Elev: 344

StdP: 14.51

Time Zone: -5.00 (NAE)

Period: 86-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.8	3.3	N/A	N/A	N/A	N/A	N/A	N/A	60.0	30.1	54.1	34.6	12.9	50	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	78.4	N/A	76.8	N/A	75.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 41.4	35.3	31.5	DB	-7.6	82.6	5.4	3.0	-11.4	84.7	-14.6	86.5	-17.6	88.2	-21.5	90.3	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	25.1	23.3	31.3	41.3	50.7	61.2	69.3	69.3	61.8	51.4	40.5	30.3
	DBStd	17.57	10.50	9.45	8.00	6.33	5.44	5.83	4.07	4.42	5.85	6.19	7.52	10.03
	HDD50	3393	771	748	580	270	58	1	0	0	2	60	293	610
	HDD65	7125	1236	1168	1044	710	443	142	11	13	126	423	734	1075
	CDD50	2098	0	0	0	11	81	338	599	599	358	103	9	0
	CDD65	352	0	0	0	0	0	29	145	147	31	0	0	0
	CDH74	584	0	0	0	7	1	32	230	305	9	0	0	0
	CDH80	30	0	0	0	2	0	1	10	17	0	0	0	0
	WSAvg	14.8	17.9	16.4	14.6	14.4	13.2	11.3	11.1	12.2	14.0	16.1	19.0	17.7
	PrecAvg	47.8	4.3	3.7	3.4	3.7	3.7	3.9	3.6	3.5	3.8	4.9	4.3	5.0
(15) Precipitation	PrecMax	56.6	7.5	5.9	6.1	6.6	7.0	7.0	6.7	6.1	5.7	8.4	6.6	7.3
	PrecMin	39.9	2.3	2.2	1.7	1.1	1.3	1.3	1.5	1.2	2.0	1.2	2.3	2.7
	PrecStd	4.6	1.3	0.8	1.1	1.5	1.6	1.5	1.4	1.4	1.1	1.8	1.2	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	42.7	51.3	66.2	68.3	77.8	81.2	82.3	75.4	67.4	58.5	48.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	42.2	40.2	46.1	57.5	64.1	74.0	78.1	79.1	73.3	64.0	56.7	46.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	39.4	37.8	43.6	53.3	61.0	71.9	76.6	77.3	71.6	62.1	54.2	44.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	37.5	35.8	40.9	49.9	58.6	69.4	75.2	75.6	70.0	60.1	51.5	42.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	12.1	9.8	8.8	9.1	8.3	7.1	7.6	8.5	8.2	9.2	10.2
		MCDBR	10.9	10.0	13.1	16.0	13.6	12.3	9.2	8.6	9.3	9.0	10.7	9.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.294	0.298	0.323	0.357	0.385	0.421	0.425	0.416	0.372	0.350	0.310	0.286
	taud		2.425	2.410	2.430	2.397	2.374	2.303	2.296	2.314	2.418	2.461	2.521	2.508
	Ebn at Noon		265	285	291	288	281	270	267	266	270	262	259	259
	Edh at Noon		23	28	32	36	38	41	40	38	32	27	22	20
(44) All-Sky Solar Radiation	RadAvg		396	658	1073	1418	1734	1839	1874	1656	1314	778	478	310
	RadStd		42	62	91	158	167	148	156	83	109	72	60	42

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page