

SEATTLE WEST POINT, WA, USA

WMO: 994350

Lat: 47.6620N

Lon: 122.4353W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	30.1	33.6	16.8	12.9	33.5	22.2	16.7	36.7	52.2	44.6	41.5	46.1	11.6	10	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	70.4	61.2	68.0	60.4	66.1	59.7	63.0	67.5	61.6	65.9	60.4	64.2	8.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.2	80.9	64.7	59.7	76.4	63.1	58.6	73.5	62.2	28.4	67.8	27.4	66.0	26.6	64.5	70.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.2	31.4	26.5	DB	27.2	76.8	4.3	2.6	24.2	78.7	21.7	80.2	19.3	81.6	16.2	83.5	(4)
(5)			WB	24.3	64.9	4.4	1.3	21.2	65.9	18.6	66.6	16.1	67.4	12.9	68.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	44.0	43.9	46.2	49.1	53.6	57.3	60.7	61.1	58.4	52.9	47.3	43.5	(6)	
	DBStd	7.42	4.72	4.31	3.81	3.49	3.58	3.13	2.91	2.36	2.71	3.35	4.54	4.87	(7)	
	HDD50	873	191	172	128	56	9	0	0	0	0	12	101	204	(8)	
	HDD65	4919	652	590	583	476	355	232	138	123	199	375	531	665	(9)	
	CDD50	1438	4	2	10	30	119	220	332	344	251	102	20	4	(10)	
	CDD65	8	0	0	0	0	0	1	5	2	0	0	0	0	(11)	
	CDH74	12	0	0	0	0	1	1	8	2	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	11.3	13.1	12.8	13.3	12.1	10.6	9.6	8.8	8.5	9.4	11.4	13.3	12.9	(14)	
(15) Precipitation	PrecAvg	40.0	5.7	3.9	4.3	2.8	2.0	1.7	0.7	0.9	1.7	4.1	6.0	6.5	(15)	
	PrecMax	52.3	11.7	9.6	8.3	5.6	3.9	3.0	1.7	3.0	5.1	8.3	14.0	11.7	(16)	
	PrecMin	29.8	2.8	0.4	1.4	0.4	0.5	0.3	0.0	0.0	0.2	0.8	2.2	2.6	(17)	
	PrecStd	6.3	2.3	2.0	1.8	1.5	1.0	0.8	0.5	0.9	1.2	2.0	2.6	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	54.8	59.4	62.3	67.1	71.5	75.0	72.9	69.2	63.2	58.4	55.8	(19)	
		MCWB	50.7	45.8	50.2	52.2	56.9	59.7	63.8	62.9	59.9	56.9	55.0	52.9	(20)	
	2%	DB	52.9	52.3	55.0	58.3	63.5	67.3	70.8	69.5	66.3	60.5	56.2	52.8	(21)	
		MCWB	49.5	46.6	48.7	50.6	56.0	58.6	62.1	61.4	59.4	56.0	53.5	50.1	(22)	
	5%	DB	51.3	50.5	52.8	55.9	60.9	64.4	68.0	67.6	64.3	59.0	54.8	51.2	(23)	
		MCWB	48.5	46.4	48.1	50.0	54.8	57.6	61.0	60.7	58.7	55.1	52.2	48.5	(24)	
	10%	DB	49.9	49.2	51.1	53.9	58.9	62.3	65.8	65.6	62.4	57.4	53.2	49.7	(25)	
		MCWB	47.3	46.0	47.5	49.1	53.8	56.8	60.1	59.9	57.8	54.2	50.6	47.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	49.9	52.4	54.2	59.4	61.7	65.9	65.1	63.1	59.6	56.3	54.1	(27)	
		MCDB	54.0	51.6	55.7	59.1	63.5	67.4	70.5	69.4	65.8	60.7	57.4	55.3	(28)	
	2%	WB	50.7	48.2	50.5	52.2	57.1	59.6	63.2	62.9	60.7	57.3	54.1	50.9	(29)	
		MCDB	51.9	50.0	52.6	55.8	61.5	64.0	68.1	67.3	63.5	59.3	55.6	52.2	(30)	
	5%	WB	49.0	47.1	49.0	51.0	55.4	58.4	61.6	61.6	59.4	55.9	52.5	49.1	(31)	
		MCDB	50.4	49.1	51.3	54.1	59.5	62.7	66.3	65.9	62.5	57.8	54.0	50.6	(32)	
	10%	WB	47.4	46.1	47.8	49.8	54.2	57.2	60.2	60.4	58.4	54.7	51.0	47.5	(33)	
		MCDB	49.2	48.1	50.4	52.9	57.9	61.3	64.4	64.2	61.5	56.7	52.7	49.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.3	7.5	8.3	8.5	8.7	9.8	9.7	7.9	6.2	6.0	5.6	(35)	
		MCDBR	6.9	7.5	9.5	11.0	11.6	12.3	13.3	12.5	10.4	7.8	7.0	7.2	(36)	
	5% WB	MCWBR	5.3	4.9	5.6	5.6	6.1	6.1	6.4	5.9	5.1	4.8	5.6	5.8	(37)	
		MCWBR	6.6	6.2	8.5	9.6	10.3	10.7	11.8	11.5	9.2	7.0	6.7	6.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.328	0.318	0.327	0.355	0.376	0.364	0.351	0.357	0.345	0.331	0.323	0.330	(40)	
		taud	2.491	2.554	2.544	2.437	2.396	2.455	2.509	2.500	2.525	2.566	2.537	2.421	(41)	
	Edn at Noon	Edn at Noon	239	272	285	285	281	285	287	281	275	262	240	219	(42)	
		Edh at Noon	21	23	27	33	36	34	32	31	28	23	19	20	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	315	591	893	1316	1666	1823	2030	1731	1256	705	370	257	(44)	
	RadStd	RadStd	45	79	104	124	135	184	152	115	114	77	50	37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page