

CAPE SAN BLAS, FL, USA

WMO: 994360

Lat: 29.672N

Lon: 85.357W

Elev: 6

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 90-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.0	(c) 40.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 35.7	(k) 44.0	(l) 32.7	(m) 45.2	(n) 11.1	(o) 30	(p) 0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.5	(c) 86.3	(d) N/A	(e) 85.6	(f) N/A	(g) 85.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 8.7	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 29.3	(b) 23.7	(c) 20.0	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(4) 29.3	(5) 23.7	(6) 20.0	(7) WB	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A	(19) N/A	(20) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	53.9	56.0	60.2	65.5	72.0	76.3	76.7	76.3	76.3	69.2	60.6	55.8
	DBStd	11.56	7.26	6.48	7.03	7.25	7.48	7.57	9.39	8.79	7.63	7.28	8.27	7.23
	HDD50	120	45	20	13	2	0	0	0	0	0	1	12	27
	HDD65	1544	347	255	171	80	40	30	39	33	29	48	179	293
	CDD50	6200	165	188	329	468	683	788	826	828	789	597	331	208
	CDD65	2148	2	2	22	97	259	367	400	396	367	179	48	9
	CDH74	19110	0	0	1	134	1503	3669	4727	4517	3596	878	85	0
	CDH80	4548	0	0	0	2	80	630	1502	1392	859	83	0	0
(14) Wind	WSAvg	9.0	9.3	10.0	9.9	9.5	9.4	9.3	8.8	8.0	7.8	8.1	8.7	9.0
(15) Precipitation	PrecAvg	55.3	4.4	4.3	5.0	3.3	2.1	5.9	7.0	7.5	5.9	3.3	3.4	3.4
	PrecMax	79.8	18.7	10.3	11.0	9.9	10.1	19.6	13.3	13.7	20.2	10.6	13.0	8.5
	PrecMin	34.5	0.6	0.4	0.0	0.3	0.0	0.4	3.2	2.2	0.1	0.0	0.2	1.5
	PrecStd	11.0	3.4	2.6	2.9	2.5	2.0	3.8	2.8	3.1	4.0	2.7	2.6	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.2	69.7	73.8	79.8	84.1	86.0	87.4	87.4	86.7	83.9	77.9	71.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	67.3	67.6	71.5	77.4	82.1	84.4	86.2	86.3	85.6	82.3	76.3	70.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	65.4	66.3	70.0	75.3	80.7	83.6	85.4	85.6	84.6	80.7	74.9	68.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	63.8	64.9	68.7	73.9	79.7	82.9	84.7	85.0	84.0	78.8	72.4	66.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	9.5	8.4	7.7	6.9	6.6	5.8	6.5	8.1	9.4	11.1	10.0
		MCDBR	9.3	9.1	7.9	8.3	8.3	8.4	7.1	7.8	9.1	9.2	9.7	9.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.349	0.358	0.369	0.396	0.434	0.462	0.487	0.481	0.434	0.389	0.358	0.348
	taud		2.513	2.495	2.466	2.387	2.313	2.292	2.239	2.263	2.367	2.478	2.496	2.534
	Ebn at Noon		281	288	291	285	273	264	257	258	267	274	275	276
	Edh at Noon		29	31	34	38	42	42	44	43	37	32	29	27
(44) All-Sky Solar Radiation	RadAvg		1006	1222	1629	1951	2177	2004	1868	1741	1615	1448	1132	900
	RadStd		83	148	134	162	132	137	129	119	109	104	84	83

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days		
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	-158	+277	+180

Nomenclature: See separate page