

SETTLEMENT POINT, Bahamas

WMO: 994390

Lat: 26.7045N

Lon: 78.9947W

Elev: 5

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.7	60.2	39.5	35.6	59.0	42.4	39.9	61.0	45.9	68.1	35.6	66.0	18.9	300	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.8	88.2	80.2	87.0	79.2	86.1	78.4	81.7	87.8	80.8	86.7	80.0	85.6	9.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	155.6	86.0	79.1	150.9	85.5	78.2	146.6	84.7	45.3	88.0	44.4	86.7	43.5	86.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.7	30.4	25.7	54.8	89.0	3.4	2.2	52.4	90.5	50.4	91.8	48.4	93.0	46.0	94.6
			46.4	81.7	2.8	2.0	44.4	83.2	42.8	84.4	41.2	85.5	39.2	87.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.4	69.2	70.4	71.5	74.3	77.6	80.8	82.6	82.9	81.6	79.1	74.7	71.7	(6)
(7)		DBStd	5.74	4.53	4.29	3.89	2.86	2.32	2.06	1.93	1.87	1.94	2.65	3.13	4.34	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	38	17	10	4	0	0	0	0	0	0	0	0	7	(9)
(10)		CDD50	9637	597	572	666	728	857	925	1010	1019	948	902	742	671	(10)
(11)		CDD65	4198	148	161	205	278	392	475	545	554	498	437	292	213	(11)
(12)		CDH74	35444	243	307	548	1142	2974	5160	6614	6883	5741	3972	1263	597	(12)
(13)		CDH80	8566	1	1	7	22	221	1235	2287	2511	1636	581	56	8	(13)
(14)	Wind	WSAvg	12.5	14.2	14.4	15.0	13.8	12.3	10.0	9.3	9.1	11.0	13.4	14.1	14.0	(14)
(15)	Precipitation	PrecAvg	50.4	2.5	3.3	3.1	2.0	3.9	6.4	5.5	6.3	7.9	4.5	2.4	2.7	(15)
(16)		PrecMax	69.6	6.3	8.2	8.8	6.8	8.6	17.4	10.9	13.9	16.7	8.1	5.9	9.2	(16)
(17)		PrecMin	33.6	0.6	0.2	0.2	0.0	0.0	0.0	0.8	1.3	2.4	0.7	0.2	0.0	(17)
(18)		PrecStd	9.8	1.7	2.0	2.4	1.8	2.4	4.5	3.1	3.7	4.7	2.3	1.6	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	79.5	79.4	81.0	81.9	85.2	87.6	89.4	90.0	88.7	86.4	83.2	81.0	(19)	
(20)		MCWB	73.6	73.6	75.9	75.5	79.1	79.7	80.9	81.4	80.4	79.1	76.3	74.8	(20)	
(21)		DB	77.8	78.0	79.3	80.6	83.0	86.1	87.9	88.4	87.1	84.9	81.5	79.6	(21)	
(22)		MCWB	72.4	72.6	73.9	74.2	76.4	78.4	80.1	80.4	79.3	77.7	75.4	74.2	(22)	
(23)		DB	76.5	77.0	78.1	79.6	81.9	85.2	86.7	86.8	85.8	83.7	80.4	78.3	(23)	
(24)		MCWB	71.4	72.0	72.6	73.6	75.1	77.8	78.9	79.0	78.3	76.5	74.8	73.6	(24)	
(25)		DB	75.3	76.0	77.0	78.7	81.2	84.4	85.8	85.9	84.7	82.7	79.3	77.2	(25)	
(26)		MCWB	70.7	71.1	71.4	72.9	74.4	77.2	78.0	78.1	77.5	75.9	73.8	72.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	75.8	76.1	78.1	78.7	80.8	81.5	82.5	82.8	81.9	81.4	79.1	77.0	(27)	
(28)		MCDWB	77.9	78.0	80.0	79.7	85.4	86.3	88.9	89.5	87.6	85.2	81.1	79.6	(28)	
(29)		WB	74.1	74.5	76.2	77.2	78.3	80.1	81.3	81.8	80.8	80.3	77.4	75.5	(29)	
(30)		MCDWB	76.9	77.1	78.8	79.0	82.8	85.4	87.7	88.7	86.7	83.5	80.0	78.5	(30)	
(31)		WB	72.8	72.9	74.3	75.8	76.9	79.2	80.3	80.6	79.8	78.9	76.4	74.4	(31)	
(32)		MCDWB	76.0	76.2	77.7	78.5	81.6	84.3	86.6	87.4	85.4	82.8	79.5	77.7	(32)	
(33)		WB	71.4	71.5	72.7	74.3	75.6	78.3	79.4	79.6	78.8	77.6	75.3	73.5	(33)	
(34)		MCDWB	74.9	75.0	76.7	78.0	80.6	83.5	85.4	85.9	84.0	82.0	78.9	76.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.8	5.7	5.5	5.4	5.1	5.8	6.0	5.8	5.5	4.4	4.7	5.2	(35)	
(36)		MCDBR	7.3	6.4	6.8	6.7	6.3	7.1	7.4	7.0	6.9	6.3	6.5	6.7	(36)	
(37)		MCWBR	6.6	6.8	6.4	6.5	5.4	5.3	5.5	5.3	5.5	5.1	5.7	5.7	(37)	
(38)		MCDBR	7.5	7.2	7.4	6.9	7.3	8.6	8.9	8.7	7.8	6.8	6.5	6.9	(38)	
(39)		MCWBR	6.8	7.4	7.4	6.9	6.1	6.4	6.3	6.2	6.0	5.7	6.0	6.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.360	0.374	0.384	0.405	0.430	0.454	0.461	0.451	0.422	0.406	0.375	0.365	(40)	
(41)		taud	2.550	2.518	2.477	2.396	2.369	2.373	2.358	2.406	2.478	2.489	2.528	2.562	(41)	
(42)		Ebn at Noon	283	286	289	284	275	266	264	267	273	272	275	276	(42)	
(43)		Edh at Noon	29	32	35	38	39	39	40	37	34	32	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1121	1384	1729	2000	2067	1956	1940	1878	1625	1444	1203	1045	(44)	
(45)		RadStd	88	97	101	91	169	172	117	111	102	115	64	63	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (15 neighbors)	+0.68	+1.48	N/A	N/A	N/A	N/A	N/A	-32	+232	+184	(47)

Nomenclature: See separate page