

MOLASSES REEF, FL, USA

WMO: 994430

Lat: 25.0118N

Lon: 80.3765W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	52.6	56.1	N/A	N/A	N/A	N/A	N/A	N/A	42.7	68.9	37.4	68.1	22.1	0	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.7	(c) 86.3	(d) N/A	(e) 86.0	(f) N/A	(g) 85.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 9.4	(p) 110

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
40.4	32.6	27.6	46.9	87.9	4.4	0.9	43.7	88.5	41.1	89.1	38.6	89.6	35.4	90.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	69.5	71.0	72.2	75.3	78.6	81.5	82.8	83.3	82.3	79.7	75.2	72.2
	DBStd	6.08	6.15	5.25	4.55	3.09	2.13	1.79	1.61	1.55	1.61	2.68	4.15	5.71
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	81	35	18	9	0	0	0	0	0	0	0	2	17
	CDD50	9859	605	589	689	760	886	946	1016	1033	969	922	755	689
	CDD65	4463	175	186	233	310	421	496	551	568	519	457	307	240
	CDH74	41139	417	460	740	1645	3660	5769	6922	7344	6391	4698	1965	1128
CDH80	10382	0	0	1	15	250	1579	2515	2924	2164	864	69	1	
Wind	WSAvg	14.1	16.2	14.9	15.8	15.6	13.7	11.4	10.5	10.7	11.7	15.6	17.1	16.5
Precipitation	PrecAvg	58.1	1.9	2.0	2.1	2.8	5.3	9.4	6.9	8.3	8.5	6.1	2.5	2.1
	PrecMax	72.4	6.0	5.8	5.8	5.5	12.5	18.6	10.8	12.3	13.1	14.6	8.0	12.4
	PrecMin	48.1	0.4	0.0	0.3	0.3	0.6	3.1	3.7	3.3	3.7	1.5	0.4	0.3
	PrecStd	6.9	1.3	1.4	1.3	1.4	2.8	4.2	2.1	2.4	2.5	3.6	2.2	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.4	78.4	80.0	81.8	83.6	86.1	86.9	87.2	86.4	84.9	82.3	80.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	77.8	77.9	78.9	80.3	82.6	85.3	86.1	86.4	85.8	84.1	81.6	79.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	77.1	77.3	78.1	79.5	82.1	84.7	85.5	86.1	85.3	83.5	80.9	79.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	76.3	76.8	77.3	78.9	81.4	84.2	85.1	85.7	84.8	83.1	80.2	78.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	6.2	5.3	4.7	3.6	3.0	3.5	3.5	3.7	3.9	3.7	4.8	5.4
		MCDBR	4.4	3.6	3.8	3.6	3.3	3.5	3.5	4.0	4.0	3.6	3.5	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDWR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.364	0.380	0.387	0.401	0.429	0.453	0.463	0.445	0.428	0.416	0.382	0.374	
	taud	2.545	2.504	2.473	2.415	2.386	2.383	2.346	2.424	2.454	2.464	2.511	2.532	
	Ebn at Noon	284	286	289	285	275	267	264	269	273	271	275	275	
	Edh at Noon	29	32	35	38	39	39	40	37	35	33	30	29	
All-Sky Solar Radiation	RadAvg	1216	1479	1813	2048	2052	1899	1954	1877	1662	1491	1284	1135	
	RadStd	83	88	73	91	178	153	87	86	73	109	60	86	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (22 neighbors)	+0.68	+1.57	N/A	N/A	N/A	N/A	N/A	-29	+214	+191

Nomenclature: See separate page