

SOMBRERO KEY LH, FL, USA

WMO: 994450

Lat: 24.6279N

Lon: 81.1108W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.2	14.1	2.9	4.7	13.4	5.7	5.7	15.0	16.3	18.4	15.1	19.5	8.4	10	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.9	31.3	26.5	30.7	26.1	30.3	26.0	28.0	29.4	27.5	29.3	27.1	29.2	2.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.6	28.9	27.0	22.7	28.8	26.5	22.0	28.7	89.3	29.3	87.0	29.3	85.0	29.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.8	14.8	12.8	DB	9.7	32.6	2.5	0.5	7.8	32.9	6.4	33.2	4.9	33.5	3.1	33.9	
			WB	5.5	28.4	2.5	1.0	3.7	29.1	2.2	29.7	0.8	30.3	-1.0	31.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	21.1	21.6	22.8	24.7	26.5	28.0	28.7	29.1	28.3	26.8	23.8	22.5
	DBStd	3.52	3.29	3.09	2.49	1.74	1.19	1.14	1.12	1.03	1.01	1.74	2.38	3.08
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	37	15	10	3	0	0	0	0	0	0	0	1	8
	CDD10.0	5599	344	324	397	439	512	540	581	591	551	521	414	386
	CDD18.3	2593	100	102	142	189	253	290	323	332	301	262	164	135
	CDH23.3	24321	286	278	507	1139	2341	3394	4053	4319	3702	2704	976	621
	CDH26.7	6866	1	1	6	37	292	1066	1608	1863	1344	599	44	6
Wind	WSAvg	6.5	6.7	6.4	7.7	7.2	6.4	5.6	5.3	5.4	5.8	6.8	7.5	6.9
Precipitation	PrecAvg	1036	50	43	39	50	73	117	93	150	179	150	45	46
	PrecMax	1406	209	154	90	156	231	373	212	491	385	437	169	137
	PrecMin	706	0	1	8	2	12	6	21	27	92	39	0	1
	PrecStd	187	51	40	25	38	61	85	47	85	62	105	46	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.5	26.8	27.5	28.6	29.8	31.5	31.9	32.1	31.5	30.4	28.4	27.4
		MCWB	23.8	24.3	24.5	24.8	25.6	26.5	26.8	26.9	26.6	26.1	24.6	24.6
	2%	DB	25.8	25.8	26.6	27.6	29.1	30.5	30.9	31.3	30.6	29.6	27.8	26.8
		MCWB	23.1	23.3	23.6	24.3	25.2	25.9	26.3	26.5	26.0	25.4	24.4	24.2
	5%	DB	25.4	25.5	26.0	27.0	28.5	30.0	30.5	30.8	30.2	29.1	27.2	26.3
		MCWB	22.7	23.0	23.0	23.8	24.8	25.7	26.1	26.2	25.8	25.3	24.1	23.8
	10%	DB	24.9	25.0	25.5	26.6	28.0	29.6	30.1	30.4	29.8	28.8	26.7	25.9
		MCWB	22.2	22.6	22.5	23.4	24.4	25.5	25.9	26.0	25.6	25.2	23.7	23.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	25.6	25.6	26.5	26.8	27.6	28.5	28.5	28.6	27.9	26.0	26.1
		MCDB	25.7	25.9	26.7	27.0	28.8	29.4	30.0	30.0	29.1	28.9	26.8	26.5
	2%	WB	24.3	24.6	24.6	25.4	25.8	26.9	27.8	27.9	27.9	27.1	25.3	25.2
		MCDB	25.2	25.3	25.9	26.7	28.1	29.1	29.6	29.8	28.9	28.3	26.6	26.1
	5%	WB	23.5	23.7	23.8	24.7	25.2	26.6	27.2	27.4	27.3	26.6	24.9	24.7
		MCDB	25.0	24.9	25.4	26.4	27.7	29.0	29.4	29.6	28.9	28.2	26.5	25.8
	10%	WB	22.7	22.9	23.0	24.0	24.8	26.2	26.7	26.9	26.7	26.0	24.2	24.0
		MCDB	24.7	24.7	25.1	26.1	27.4	28.9	29.4	29.6	28.9	28.1	26.4	25.6
Mean Daily Temperature Range	5% DB	MDBR	3.5	3.3	2.8	2.3	2.3	2.7	2.7	2.9	2.8	2.5	2.9	3.0
		MCDBR	2.8	2.8	2.9	2.6	2.9	3.2	3.0	3.0	3.1	2.6	2.5	2.5
		MCWBR	2.9	2.7	2.7	2.6	2.6	2.6	2.7	2.6	2.5	2.2	2.4	2.6
	5% WB	MCDBR	2.8	2.9	3.1	2.9	2.8	2.9	3.0	3.0	3.1	2.5	2.7	2.5
		MCWBR	3.2	3.0	3.2	3.3	2.5	2.8	3.1	2.8	2.9	2.5	2.7	3.0
Clear-Sky Solar Irradiance	taub	0.363	0.378	0.384	0.402	0.425	0.444	0.452	0.434	0.422	0.409	0.379	0.371	
	taud	2.549	2.510	2.478	2.407	2.393	2.411	2.388	2.461	2.461	2.486	2.519	2.547	
	Ebn at Noon	897	906	915	900	872	849	842	859	866	862	872	873	
	Edh at Noon	92	102	110	120	122	119	121	113	110	103	94	89	
All-Sky Solar Radiation	RadAvg	3.91	4.83	5.94	6.70	6.76	6.28	6.42	6.10	5.40	4.83	4.17	3.68	
	RadStd	0.29	0.32	0.24	0.29	0.60	0.48	0.31	0.24	0.25	0.34	0.21	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	+0.36	+0.86	N/A	N/A	N/A	N/A	N/A	-13	+116	+104	

Nomenclature: See separate page