

SAND KEY LH, FL, USA

WMO: 994570

Lat: 24.4539N

Lon: 81.8775W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.4	58.3	N/A	N/A	N/A	N/A	N/A	N/A	35.2	63.7	33.2	63.1	18.4	0	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	87.4	N/A	86.6	N/A	86.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.5	100

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
34.9	30.7	27.0	DB	50.1	90.0	4.2	2.4	47.1	91.7	44.7	93.1	42.3	94.4	39.3	96.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.3	69.1	70.7	72.6	75.5	79.3	81.9	83.6	84.0	82.8	80.3	75.2	72.0
	DBStd	6.21	5.52	5.11	4.36	2.97	1.87	1.91	1.61	1.61	1.77	2.54	3.99	5.03
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	60	28	14	7	0	0	0	0	0	0	0	1	10
	CDD50	9957	593	579	700	766	907	958	1040	1053	984	938	757	682
	CDD65	4542	156	173	242	316	442	508	575	588	534	473	308	227
	CDH74	41990	333	441	801	1629	3942	5830	7188	7636	6607	4848	1822	913
	CDH80	11371	1	2	1	31	341	1621	2755	3199	2346	968	101	5
Wind	WSAvg	13.6	14.4	13.3	15.0	15.0	12.9	11.7	10.8	10.4	11.5	14.7	17.0	16.8
Precipitation	PrecAvg	40.8	2.0	1.7	1.5	2.0	2.9	4.6	3.7	5.9	7.0	5.9	1.8	1.8
	PrecMax	55.4	8.2	6.1	3.5	6.1	9.1	14.7	8.3	19.3	15.2	17.2	6.7	5.4
	PrecMin	27.8	0.0	0.0	0.3	0.1	0.5	0.2	0.8	1.1	3.6	1.5	0.0	0.0
	PrecStd	7.4	2.0	1.6	1.0	1.5	2.4	3.3	1.9	3.3	2.4	4.1	1.8	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	79.3	79.9	82.5	84.4	88.4	89.0	89.0	88.2	86.4	83.0	80.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	78.0	78.2	78.8	80.9	83.1	86.2	87.0	87.4	86.7	84.8	82.1	79.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	77.1	77.4	78.1	79.5	82.4	85.1	86.2	86.7	86.1	84.1	81.3	79.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	76.0	76.7	77.4	78.9	81.8	84.4	85.5	86.2	85.4	83.5	80.4	78.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.2	4.2	3.5	3.1	4.0	3.9	4.2	4.5	3.7	4.1	4.9
		MCDBR	5.3	4.4	4.0	4.1	4.0	5.2	4.8	4.9	5.2	4.1	3.4	4.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.364	0.377	0.383	0.402	0.425	0.439	0.451	0.433	0.417	0.410	0.378	0.372	
	taud	2.549	2.514	2.477	2.407	2.393	2.422	2.393	2.464	2.479	2.484	2.522	2.547	
	Ebn at Noon	285	288	291	285	277	271	267	273	276	273	277	277	
	Edh at Noon	29	32	35	38	39	37	38	36	34	33	30	28	
All-Sky Solar Radiation	RadAvg	1230	1540	1896	2139	2167	2017	2063	1961	1719	1534	1331	1171	
	RadStd	98	115	82	90	186	159	98	69	92	104	74	102	

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	+0.63	+1.55	N/A	N/A	N/A	N/A	N/A	-23	+160

Nomenclature: See separate page