

SAND KEY LH, FL, USA

WMO: 994570

Lat: 24.4539N

Lon: 81.8775W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	14.6	N/A	N/A	N/A	N/A	N/A	N/A	15.7	17.6	14.9	17.3	8.2	0	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	30.8	N/A	30.3	N/A	30.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.9	100

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	13.7	12.0	10.1	32.2	2.3	1.3	8.4	33.2	7.0	33.9	5.7	34.7	4.0	35.6		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	20.6	21.5	22.5	24.2	26.3	27.7	28.6	28.9	28.2	26.8	24.0	22.2	
	DBStd	3.45	3.06	2.84	2.42	1.65	1.04	1.06	0.89	0.89	0.98	1.41	2.21	2.79	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	33	16	8	4	0	0	0	0	0	0	0	1	6	
	CDD10.0	5532	329	322	389	426	504	532	578	585	547	521	421	379	
	CDD18.3	2523	87	96	134	176	246	282	319	327	297	263	171	126	
	CDH23.3	23328	185	245	445	905	2190	3239	3993	4242	3671	2693	1012	507	
	CDH26.7	6317	1	1	1	17	189	901	1531	1777	1303	538	56	3	
Wind	WSAvg	6.1	6.4	6.0	6.7	6.7	5.8	5.2	4.8	4.6	5.2	6.6	7.6	7.5	
Precipitation	PrecAvg	1036	50	43	39	50	73	117	93	150	179	150	45	46	
	PrecMax	1406	209	154	90	156	231	373	212	491	385	437	169	137	
	PrecMin	706	0	1	8	2	12	6	21	27	92	39	0	1	
	PrecStd	187	51	40	25	38	61	85	47	85	62	105	46	35	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	26.3	26.6	28.0	29.1	31.3	31.7	31.7	31.2	30.2	28.3	26.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	25.6	25.6	26.0	27.2	28.4	30.1	30.6	30.8	30.4	29.3	27.8	26.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	25.1	25.2	25.6	26.4	28.0	29.5	30.1	30.4	30.0	29.0	27.4	26.1	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	24.4	24.8	25.2	26.0	27.7	29.1	29.7	30.1	29.6	28.6	26.9	25.7	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.1	2.9	2.3	2.0	1.7	2.2	2.2	2.4	2.5	2.0	2.3	2.7	
		MCDBR	2.9	2.4	2.2	2.3	2.2	2.9	2.7	2.7	2.9	2.3	1.9	2.3	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.364	0.377	0.383	0.402	0.425	0.439	0.451	0.433	0.417	0.410	0.378	0.372		
	taud	2.549	2.514	2.477	2.407	2.393	2.422	2.393	2.464	2.479	2.484	2.522	2.547		
	Ebn at Noon	897	908	916	900	872	853	843	861	871	862	874	873		
	Edh at Noon	92	101	110	120	122	117	121	112	108	103	94	89		
All-Sky Solar Radiation	RadAvg	3.88	4.86	5.98	6.74	6.83	6.36	6.50	6.18	5.42	4.84	4.20	3.69		
	RadStd	0.31	0.36	0.26	0.28	0.58	0.50	0.31	0.22	0.29	0.33	0.23	0.32		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	+0.35	+0.86	N/A	N/A	N/A	N/A	N/A	-13	N/A	+89

Nomenclature: See separate page