

LONG KEY, FL, USA

WMO: 994620

Lat: 24.844N

Lon: 80.864W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 51.6	(c) 55.2	(d) 40.0	(e) 36.3	(f) 55.9	(g) 44.5	(h) 43.2	(i) 59.7	(j) 30.7	(k) 60.0	(l) 28.1	(m) 60.0	(n) 17.5	(o) 0	(p) 0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.8	(c) 87.7	(d) 78.7	(e) 87.1	(f) 78.5	(g) 86.5	(h) 78.3	(i) 81.3	(j) 85.1	(k) 80.6	(l) 84.9	(m) 80.2	(n) 84.7	(o) 4.5	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	156.6	83.7	79.4	152.3	84.1	78.6	148.7	83.9	44.7	85.2	44.2	85.1	43.6	84.8	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	24.7	22.1	DB	47.5	90.6	4.7	0.7	44.1	91.1	41.4	91.6	38.7	92.0	35.3	92.5
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.9	67.9	70.4	72.0	75.5	79.2	82.4	83.7	84.1	82.9	80.0	74.0	70.5
	DBStd	6.95	6.44	5.72	5.04	3.51	2.38	2.05	1.77	1.87	1.80	3.44	4.87	6.09
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	111	48	22	12	0	0	0	0	0	0	0	4	25
	CDD50	9831	556	572	683	766	905	973	1044	1058	986	930	721	637
	CDD65	4466	138	174	230	316	440	523	579	593	536	465	275	197
	CDH74	42637	270	485	807	1800	3986	6268	7469	7870	6629	4811	1534	708
CDH80	12696	0	0	16	69	468	2068	3049	3449	2389	1073	111	4	
Wind	WSAvg	11.6	12.5	12.0	13.5	13.4	12.3	10.5	9.3	9.1	9.8	12.0	12.3	12.5
Precipitation	PrecAvg	43.8	2.1	1.6	2.4	1.9	3.0	6.2	4.1	5.6	7.6	5.2	2.5	1.9
	PrecMax	55.1	7.7	7.6	7.0	5.4	6.3	13.3	8.0	8.9	13.2	13.8	7.6	5.4
	PrecMin	27.4	0.3	0.0	0.7	0.2	0.0	0.0	1.9	3.0	3.5	0.9	0.2	0.4
	PrecStd	7.6	1.7	1.9	1.5	1.3	2.1	3.9	1.7	1.7	2.6	3.5	2.2	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.5	79.4	81.8	84.0	85.2	87.9	88.5	89.1	88.2	86.3	83.5	80.4
		MCWB	73.3	74.0	75.0	76.8	77.7	77.8	78.4	78.9	79.0	79.0	77.2	75.6
	2%	DB	77.7	78.4	80.3	81.9	83.9	86.6	87.4	87.8	86.9	85.1	82.5	79.5
		MCWB	73.0	73.2	74.2	75.5	76.9	77.3	78.3	78.8	78.7	78.2	76.7	74.9
	5%	DB	76.8	77.7	79.0	80.5	83.0	86.0	86.7	87.2	86.2	84.3	81.5	78.7
		MCWB	72.4	72.7	73.6	74.5	76.2	77.2	78.2	78.7	78.4	78.0	76.2	74.2
	10%	DB	75.6	77.0	77.9	79.8	82.3	85.3	86.2	86.7	85.5	83.7	80.1	77.8
		MCWB	71.5	72.2	72.9	74.0	75.6	77.1	78.1	78.4	78.1	77.9	75.4	73.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.1	77.0	77.4	78.2	80.1	80.3	81.2	81.5	82.1	82.1	78.5	77.6
		MCDB	76.1	77.8	78.4	82.9	85.2	85.5	86.1	86.6	86.0	83.0	81.5	78.5
	2%	WB	74.2	74.8	76.3	77.2	78.1	79.5	80.4	81.1	81.1	81.1	77.8	76.2
		MCDB	76.0	77.3	78.0	81.7	82.4	82.9	85.7	86.4	85.2	82.8	81.6	78.2
	5%	WB	73.4	74.0	75.2	76.4	76.9	78.9	80.1	80.5	80.3	80.3	77.0	75.2
		MCDB	75.8	77.1	77.7	80.9	81.3	83.0	85.6	86.0	84.7	82.9	81.2	77.9
	10%	WB	72.8	73.3	73.9	75.3	75.9	78.4	79.5	79.9	79.6	79.4	75.8	74.4
		MCDB	75.2	76.9	77.3	79.8	80.9	83.1	85.3	85.7	84.3	82.9	80.1	77.1
Mean Daily Temperature Range	5% DB	MDBR	6.1	5.7	5.2	4.2	3.5	4.3	4.4	4.8	4.6	4.1	5.1	5.7
		MCDBR	4.0	4.6	5.3	4.5	4.4	4.7	4.8	4.9	5.2	4.2	3.9	4.5
		MCWBR	3.4	3.8	4.3	4.3	3.6	3.7	3.3	3.4	3.5	3.1	2.6	3.3
	5% WB	MCDBR	4.3	4.3	4.7	4.8	3.9	4.9	4.1	4.7	4.9	3.6	3.9	4.2
		MCWBR	5.5	4.6	4.9	5.3	3.9	4.3	3.3	3.7	3.8	3.2	3.7	4.0
Clear-Sky Solar Irradiance	taub		0.364	0.379	0.385	0.401	0.427	0.448	0.455	0.438	0.426	0.410	0.380	0.371
	taud		2.545	2.504	2.475	2.407	2.389	2.397	2.375	2.447	2.452	2.481	2.513	2.543
	Ebn at Noon		284	287	290	285	276	268	266	272	273	273	276	277
	Edh at Noon		29	32	35	38	39	38	39	36	35	33	30	28
All-Sky Solar Radiation	RadAvg		1229	1509	1852	2091	2103	1949	1991	1899	1686	1515	1308	1153
	RadStd		88	95	76	93	183	154	94	80	78	106	63	93

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.68	+1.57	N/A	N/A	N/A	N/A	N/A	N/A	-23	+209	+187

Nomenclature: See separate page