

CEDAR KEY, FL, USA

WMO: 994640

Lat: 29.1359N

Lon: 83.0293W

Elev: 6

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 36.6	(c) 40.1	(d) 19.5	(e) 14.7	(f) 41.1	(g) 24.6	(h) 18.7	(i) 44.4	(j) 25.6	(k) 61.4	(l) 22.5	(m) 59.6	(n) 9.0	(o) 350	(p) 0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.7	(c) 88.3	(d) 77.9	(e) 87.4	(f) 77.8	(g) 86.6	(h) 77.6	(i) 81.7	(j) 84.6	(k) 80.4	(l) 84.4	(m) 79.6	(n) 84.3	(o) 8.7	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	160.5	83.5	79.3	152.2	83.2	78.2	146.5	82.9	45.2	84.3	43.9	84.4	43.0	84.2	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.6	(b) 21.3	(c) 18.7	(e) 30.0	(f) 90.5	(g) 3.4	(h) 1.3	(i) 27.6	(j) 91.4	(k) 25.5	(l) 92.1	(m) 23.6	(n) 92.8	(o) 21.1	(p) 93.7		
			DB													
			WB													
				26.1	80.9	3.7	1.3	23.5	81.8	21.3	82.6	19.3	83.3	16.6	84.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	55.2	58.3	63.2	69.2	76.0	80.8	82.0	82.3	79.8	73.2	63.8	59.0
	DBStd	11.07	8.01	7.07	6.38	4.98	3.71	2.48	2.16	2.26	2.78	5.69	6.79	7.67
	HDD50	84	45	15	4	0	0	0	0	0	0	0	3	17
	HDD65	961	312	200	107	22	0	0	0	0	0	13	98	209
	CDD50	7492	205	248	412	577	805	924	992	1002	895	718	417	297
	CDD65	2894	7	13	50	149	341	474	527	537	445	267	61	23
	CDH74	26343	1	12	21	336	2325	5127	6240	6306	4267	1552	148	8
	CDH80	7261	0	0	0	5	231	1414	2136	2238	1070	163	4	0
(14) Wind	WSAvg	9.2	8.3	8.6	10.1	10.5	10.0	9.9	8.7	8.9	10.0	8.8	8.7	8.4
(15) Precipitation	PrecAvg	54.3	4.2	3.3	4.3	3.1	2.3	6.5	8.4	8.2	5.7	3.3	2.1	2.9
	PrecMax	71.2	9.6	11.8	15.0	8.6	5.4	16.1	19.3	16.6	16.1	8.2	4.8	7.9
	PrecMin	35.9	1.2	0.6	0.5	0.4	0.1	2.2	4.2	4.2	1.9	0.4	0.1	0.6
	PrecStd	9.4	2.2	2.4	3.1	2.1	1.5	2.4	3.2	3.2	3.6	2.0	1.3	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.2	76.0	76.5	80.7	85.8	88.5	89.5	89.6	88.7	85.4	80.3	75.1
		MCWB	66.0	69.4	68.1	71.4	74.2	77.3	77.6	79.0	75.9	76.7	73.9	68.2
	2%	DB	69.3	72.4	74.5	78.6	83.8	87.3	88.0	88.3	87.1	83.4	77.9	72.7
		MCWB	65.7	68.8	67.6	71.1	74.1	77.9	77.9	78.6	76.3	75.6	73.0	67.8
	5%	DB	67.6	69.2	73.0	77.3	82.4	86.3	87.0	87.4	86.0	81.9	75.5	70.8
		MCWB	65.4	66.1	67.0	70.6	73.6	77.6	77.9	78.3	76.4	74.8	70.5	67.0
	10%	DB	65.5	66.9	71.4	76.1	81.3	85.3	86.2	86.6	84.7	80.4	73.1	68.9
		MCWB	63.0	64.2	66.2	69.7	73.2	77.2	77.6	78.1	76.3	74.1	68.2	65.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	71.3	72.4	75.2	78.5	84.0	81.9	82.4	82.5	82.4	76.0	71.2
		MCDB	69.9	74.0	73.3	78.4	81.8	85.5	84.7	85.4	83.8	82.5	78.6	73.3
	2%	WB	67.2	69.7	70.4	73.4	77.0	80.9	80.4	81.2	80.8	78.0	74.5	69.7
		MCDB	68.5	72.3	72.4	76.8	80.8	84.6	84.8	85.3	82.8	80.1	77.4	71.4
	5%	WB	65.8	67.6	69.0	72.5	75.8	79.4	79.6	80.3	79.2	76.7	72.3	68.3
		MCDB	67.5	69.3	71.4	75.9	80.1	83.9	84.7	85.1	82.3	79.8	75.3	70.1
	10%	WB	64.0	65.8	67.8	71.3	74.8	78.3	78.9	79.5	78.0	75.4	69.6	66.6
		MCDB	65.7	67.1	70.5	74.9	79.5	83.2	84.4	84.9	82.2	79.4	72.0	68.6
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.3	10.1	9.4	8.2	7.3	7.6	7.7	9.0	10.5	12.4	11.8
		MCDBR	10.8	9.8	10.4	9.8	9.3	8.0	8.1	8.2	10.3	9.9	11.7	10.8
		MCWBR	7.4	6.3	6.5	5.7	4.8	4.4	4.2	3.9	4.5	5.1	7.3	6.8
	5% WB	MCDBR	8.9	7.3	7.6	7.6	6.7	7.0	7.5	7.6	8.1	7.6	8.9	8.0
		MCWBR	7.7	5.8	6.7	6.7	5.1	4.7	4.8	4.4	5.2	5.4	7.4	6.8
(40) Clear-Sky Solar Irradiance	taub		0.342	0.351	0.367	0.388	0.425	0.456	0.493	0.471	0.427	0.387	0.355	0.341
	taud		2.525	2.504	2.457	2.371	2.323	2.309	2.211	2.284	2.384	2.474	2.503	2.551
	Ebn at Noon		285	292	292	288	276	266	256	261	270	275	277	280
	Edh at Noon		28	31	35	39	41	42	46	42	37	32	29	26
(44) All-Sky Solar Radiation	RadAvg		1067	1279	1669	2007	2167	1963	1850	1760	1603	1465	1181	972
	RadStd		75	116	153	130	123	132	122	121	131	103	73	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-13	-99	+283	+202

Nomenclature: See separate page