

KEATON BEACH, FL, USA

WMO: 994650

Lat: 29.8187N

Lon: 83.5935W

Elev: 6

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.4	36.0	15.2	11.9	37.5	20.9	15.7	42.1	28.2	58.4	25.1	60.7	6.3	30	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	87.9	76.9	86.7	77.1	85.9	77.1	80.3	85.4	79.5	84.8	78.7	84.2	9.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	148.8	84.5	77.9	144.9	83.9	77.1	141.1	83.2	43.8	85.5	42.9	85.1	42.2	84.3	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.1	21.0	18.5	DB	26.0	91.4	3.4	1.9	23.5	92.7	21.5	93.8	19.5	94.9	17.0	96.3
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	52.3	55.4	60.1	65.9	72.9	78.4	79.8	79.9	77.8	70.6	60.7	55.7	(6)
	DBStd	11.46	8.54	7.44	6.48	4.91	4.00	2.49	2.10	2.41	2.92	5.87	7.32	8.08	(7)
	HDD50	164	78	31	9	0	0	0	0	0	0	0	9	37	(8)
	HDD65	1377	396	275	169	47	3	0	0	0	0	22	165	300	(9)
	CDD50	6564	150	181	323	478	710	851	925	927	835	640	329	215	(10)
	CDD65	2305	3	6	19	75	248	401	460	462	385	197	36	13	(11)
	CDH74	20220	1	3	8	143	1654	4016	5028	4865	3292	1090	115	5	(12)
	CDH80	5347	0	0	0	1	135	995	1627	1592	878	118	1	0	(13)
(14) Wind	WSAvg	8.8	8.3	8.6	10.0	9.9	10.0	9.6	8.6	8.3	8.1	7.5	7.8	8.6	(14)
(15) Precipitation	PrecAvg	54.3	4.2	3.3	4.3	3.1	2.3	6.5	8.4	8.2	5.7	3.3	2.1	2.9	(15)
	PrecMax	71.2	9.6	11.8	15.0	8.6	5.4	16.1	19.3	16.6	16.1	8.2	4.8	7.9	(16)
	PrecMin	35.9	1.2	0.6	0.5	0.4	0.1	2.2	4.2	4.2	1.9	0.4	0.1	0.6	(17)
	PrecStd	9.4	2.2	2.4	3.1	2.1	1.5	2.4	3.2	3.2	3.6	2.0	1.3	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.9	74.3	75.2	78.4	85.3	88.3	89.4	89.3	89.3	85.3	79.8	74.7	(19)
		MCWB	66.0	68.3	63.8	69.7	73.1	75.9	76.6	77.8	74.6	74.0	70.1	65.2	(20)
	2%	DB	69.0	70.8	73.0	77.1	83.0	86.2	87.4	87.4	87.2	82.9	77.6	72.1	(21)
		MCWB	64.9	67.1	66.3	70.4	73.0	76.6	78.2	78.1	74.8	74.5	71.3	64.9	(22)
	5%	DB	66.8	68.0	71.3	75.8	81.5	85.3	86.3	86.5	85.6	81.3	74.7	70.2	(23)
		MCWB	63.6	64.4	66.0	69.8	73.5	76.9	77.7	77.9	75.3	73.8	68.2	64.6	(24)
	10%	DB	64.4	65.8	69.8	74.5	80.2	84.3	85.4	85.8	84.3	79.6	72.0	68.2	(25)
		MCWB	61.5	63.3	65.2	68.6	72.9	76.6	77.3	77.8	75.4	73.0	66.3	64.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.4	70.4	71.3	74.5	78.0	80.9	81.3	81.6	80.3	78.3	75.9	68.7	(27)
		MCDB	70.1	72.4	72.2	77.0	82.4	84.8	86.7	86.5	85.1	81.5	78.3	69.5	(28)
	2%	WB	66.2	68.4	69.1	73.1	76.3	79.8	80.0	80.4	78.6	77.0	72.8	66.8	(29)
		MCDB	68.1	70.4	70.9	76.0	80.4	84.3	85.5	85.7	83.7	80.6	75.2	68.1	(30)
	5%	WB	64.4	66.2	67.9	71.5	75.3	78.7	79.1	79.6	77.5	75.6	69.6	65.5	(31)
		MCDB	66.2	67.5	70.0	74.4	79.3	83.6	84.8	85.2	83.0	79.7	72.4	67.2	(32)
	10%	WB	62.5	64.2	66.5	70.3	74.4	77.7	78.3	78.7	76.8	74.4	67.6	64.0	(33)
		MCDB	64.0	65.5	68.9	73.3	78.7	82.9	84.1	84.5	82.4	78.4	70.9	66.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	12.9	13.1	12.6	11.6	9.9	10.0	9.9	12.0	13.8	15.9	14.6	(35)
		MCDBR	13.1	12.6	13.3	13.8	13.1	11.8	11.5	11.4	14.2	13.6	14.9	13.6	(36)
	5% WB	MCWBR	9.5	9.1	8.5	8.8	7.5	6.1	5.8	5.6	5.7	6.5	9.5	9.8	(37)
		MCWBR	10.0	9.1	8.8	10.0	9.3	8.8	9.1	9.2	10.5	10.4	11.9	12.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.341	0.346	0.364	0.389	0.430	0.467	0.497	0.480	0.434	0.384	0.354	0.339	(40)
		taud	2.515	2.504	2.461	2.370	2.304	2.267	2.196	2.248	2.357	2.477	2.491	2.546	(41)
	Ebn at Noon		284	292	293	287	274	263	254	258	267	275	276	279	(42)
		Edh at Noon	28	31	35	39	42	43	46	44	38	32	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		1035	1242	1648	1976	2172	1977	1897	1758	1605	1455	1158	930	(44)
	RadStd		72	135	148	149	121	123	124	127	133	109	77	80	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	-38	-140	+288	+198

Nomenclature: See separate page