

POTATO POINT, AK, USA

WMO: 994660

Lat: 61.0564N

Lon: 146.6982W

Elev: 23

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	15.3	N/A	N/A	N/A	N/A	N/A	N/A	48.5	21.0	46.1	21.1	38.3	30	0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	65.0	N/A	62.2	N/A	60.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
43.1	39.5	35.3	10.0	71.0	3.3	6.6	7.6	75.7	5.7	79.6	3.8	83.3	1.3	88.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.7	28.1	29.9	31.6	38.4	46.5	52.0	54.6	53.4	48.5	41.6	32.8	30.7		
	DBStd	10.77	7.21	5.61	5.53	4.50	4.52	3.75	3.37	3.46	3.14	3.82	6.40	5.58		
	HDD50	3757	678	564	570	350	129	19	3	4	64	260	517	599		
	HDD65	8862	1143	984	1035	799	575	391	323	360	496	725	967	1064		
	CDD50	370	0	0	0	1	19	78	146	109	17	0	0	0		
	CDD65	2	0	0	0	0	0	1	0	1	0	0	0	0		
	CDH74	8	0	0	0	0	0	3	2	3	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	15.5	25.8	22.5	21.3	12.1	7.7	5.4	6.1	8.8	11.9	17.2	23.8	23.7		
	PrecAvg	44.3	4.0	3.7	2.7	2.2	2.0	2.2	3.3	4.6	6.0	5.0	3.9	4.4		
Precipitation	PrecMax	55.2	10.4	9.3	5.8	4.4	4.4	3.9	5.2	11.1	10.2	12.6	9.4	10.0		
	PrecMin	30.4	0.4	0.0	0.6	0.5	0.5	0.7	1.7	0.6	2.7	2.2	0.1	1.0		
	PrecStd	6.4	2.3	2.1	1.7	1.1	1.1	0.8	1.0	2.5	2.1	2.7	2.6	2.2		
	PrecStd	6.4	2.3	2.1	1.7	1.1	1.1	0.8	1.0	2.5	2.1	2.7	2.6	2.2		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	40.4	45.3	55.3	62.6	68.1	68.3	69.4	60.5	52.4	46.4	41.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	39.9	38.6	41.9	50.2	59.0	62.7	64.7	64.7	56.6	49.5	43.4	39.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	38.1	37.3	40.1	46.7	55.7	59.9	62.3	61.4	54.6	47.8	41.5	38.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	36.3	36.3	38.3	44.3	53.1	57.7	60.3	59.1	52.9	46.3	40.1	37.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	5.2	4.8	5.6	6.7	7.8	7.9	8.2	8.1	6.8	5.2	4.8	4.9		
		MCDBR	6.1	5.6	7.3	10.3	12.0	11.7	12.0	12.0	9.6	7.2	5.6	6.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.267	0.327	0.333	0.386	0.410	0.398	0.409	0.403	0.348	0.326	0.282	0.263		
	taud		2.006	2.020	2.058	1.965	2.029	2.196	2.221	2.226	2.343	2.188	1.989	1.904		
	Ebn at Noon		134	193	242	250	255	262	255	245	241	195	121	76		
	Edh at Noon		14	26	35	47	48	41	39	36	27	22	14	10		
All-Sky Solar Radiation	RadAvg		89	305	793	1355	1712	1786	1591	1210	782	357	127	48		
	RadStd		11	45	83	112	132	102	106	121	105	40	22	5		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	N/A	+2.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page