

DRIFT RIVER TERMINAL, AK, USA

WMO: 994690

Lat: 60.5537N

Lon: 152.1360W

Elev: 52

StdP: 14.67

Time Zone: -9.00 (NAK)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	5.6	-9.4	3.3	8.3	-6.2	3.9	10.1	33.6	25.6	28.3	34.6	9.4	0	0.782

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	64.4	53.6	61.2	53.2	58.9	52.8	56.4	60.3	55.3	58.7	54.5	57.6	9.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.5	63.2	57.0	53.6	61.3	56.1	52.9	59.7	55.5	24.0	61.0	23.3	59.1	22.8	57.7	63.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.5	24.8	21.3	-1.4	69.5	4.9	3.7	-4.9	72.1	-7.8	74.3	-10.6	76.4	-14.1	79.0
			-2.5	59.0	5.2	2.2	-6.2	60.6	-9.2	61.9	-12.1	63.1	-15.9	64.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.4	23.2	25.6	27.5	36.0	45.3	50.0	54.0	54.3	49.0	40.3	28.7	25.7
	DBStd	13.19	10.87	8.12	7.39	5.70	4.54	3.61	3.31	2.99	3.80	5.34	8.46	8.83
	HDD50	4584	829	683	699	421	158	40	3	1	58	301	638	753
	HDD65	9716	1294	1103	1164	870	612	449	341	333	479	765	1088	1218
	CDD50	343	0	0	0	0	12	41	127	133	29	1	0	0
	CDD65	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.8	9.7	9.5	10.2	9.3	10.2	10.0	9.5	8.5	9.6	10.5	10.7	10.4
Precipitation	PrecAvg	35.5	3.1	2.7	1.9	1.7	1.7	1.9	2.6	3.9	5.0	4.1	3.4	3.6
	PrecMax	42.9	5.7	7.1	3.5	3.8	4.1	3.7	4.5	7.0	9.3	8.6	6.9	5.6
	PrecMin	24.3	0.3	0.1	0.3	0.5	0.6	0.6	1.1	1.2	2.2	1.3	0.2	1.0
	PrecStd	3.9	1.5	1.3	0.9	0.7	0.9	0.7	0.7	1.5	1.9	1.6	2.0	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.2	40.8	42.9	55.2	64.7	68.9	69.1	67.3	59.4	53.3	46.9	42.8
		MCWB	39.1	35.9	37.0	43.4	49.3	54.6	55.5	55.7	50.4	48.3	42.5	39.3
	2%	DB	40.5	38.9	40.7	48.7	58.8	61.1	63.7	63.5	56.6	50.5	44.5	41.1
		MCWB	36.8	35.6	36.2	40.4	45.7	51.1	54.3	54.2	50.6	46.5	40.7	38.0
	5%	DB	38.5	37.2	38.5	45.3	55.0	57.1	60.8	60.7	55.2	48.9	42.2	39.0
		MCWB	35.6	34.6	34.5	38.5	44.7	49.8	54.1	54.0	50.1	45.0	38.8	36.1
	10%	DB	36.6	35.5	36.6	43.0	52.3	54.7	58.5	58.7	54.1	47.4	40.1	36.9
		MCWB	34.3	33.2	33.0	37.3	44.1	49.3	53.6	53.6	49.9	43.5	37.0	34.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.4	37.8	38.9	44.7	50.3	55.4	57.5	58.8	53.9	50.8	44.0	40.9
		MCDB	43.3	38.9	41.1	54.5	60.2	64.4	62.3	64.5	55.8	52.5	46.5	42.1
	2%	WB	37.5	36.3	37.2	41.3	48.1	53.3	56.2	56.9	52.8	48.3	41.9	38.4
		MCDB	39.9	37.7	39.8	47.3	55.0	59.0	60.5	60.5	55.0	50.0	44.0	40.6
	5%	WB	36.3	35.0	35.4	39.7	46.6	51.9	55.2	55.5	51.9	46.2	40.0	36.9
		MCDB	38.3	36.6	37.7	43.9	52.2	56.0	59.1	58.3	54.0	48.2	42.2	39.0
	10%	WB	34.8	33.4	33.8	38.4	45.4	50.6	54.4	54.8	51.0	44.4	37.7	35.1
		MCDB	36.7	34.9	36.0	42.2	50.2	53.9	57.8	57.5	53.2	46.6	40.1	36.7
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.6	8.2	8.1	9.0	6.9	6.4	6.7	6.7	6.7	7.1	7.5
		MCDBR	7.6	7.2	8.2	10.9	14.8	11.9	10.9	10.3	7.8	7.1	6.7	7.0
		MCWBR	5.5	4.9	5.4	6.0	6.8	5.4	4.8	5.3	5.3	4.9	5.0	4.9
	5% WB	MCDBR	7.0	6.3	7.2	10.4	12.4	10.2	8.7	8.3	6.5	5.9	6.2	6.6
		MCWBR	5.4	4.9	5.0	5.9	6.1	5.2	4.5	4.8	4.6	4.5	5.0	4.9
Clear-Sky Solar Irradiance	taub		0.260	0.307	0.328	0.365	0.382	0.370	0.385	0.371	0.331	0.316	0.272	0.257
	taud		2.089	2.170	2.162	2.130	2.190	2.355	2.363	2.398	2.483	2.295	2.069	1.938
	Ebn at Noon		151	212	248	260	266	272	264	259	252	208	138	90
	Edh at Noon		13	23	32	40	41	35	34	30	23	20	13	10
All-Sky Solar Radiation	RadAvg		101	317	852	1357	1656	1717	1510	1195	780	365	140	54
	RadStd		14	47	101	145	151	105	115	131	111	45	22	7

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (23 neighbors)	+1.30	+4.09	+3.51	N/A	N/A	N/A	N/A	-450	N/A	N/A

Nomenclature: See separate page