

DRIFT RIVER TERMINAL, AK, USA

WMO: 994690

Lat: 60.5537N

Lon: 152.1360W

Elev: 16

StdP: 101.13

Time Zone: -9.00 (NAK)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-14.7	-23.0	0.5	-13.2	-21.2	0.6	-12.2	15.0	-3.6	12.6	1.5	4.2	0	0.782

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.7	18.0	12.0	16.2	11.8	15.0	11.6	13.5	15.7	12.9	14.9	12.5	14.2	4.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	9.0	13.9	12.0	8.8	13.4	11.6	8.5	13.1	37.9	16.1	36.3	15.0	35.2	14.3	17.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.1	9.5	DB	-18.5	20.8	2.7	2.0	-20.5	22.3	-22.1	23.5	-23.6	24.6	-25.6	26.1	(4)
(5)			WB	-19.2	15.0	2.9	1.2	-21.2	15.9	-22.9	16.6	-24.5	17.3	-26.6	18.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-4.9	-3.6	-2.5	2.2	7.4	10.0	12.2	12.4	9.5	4.6	-1.8	-3.5	(6)
(7)		DBStd	7.33	6.04	4.51	4.10	3.17	2.52	2.01	1.84	1.66	2.11	2.97	4.70	4.90	(7)
(8)		HDD10.0	2547	461	379	388	234	88	22	2	1	32	167	354	418	(8)
(9)		HDD18.3	5398	719	613	647	483	340	249	189	185	266	425	604	677	(9)
(10)		CDD10.0	191	0	0	0	0	7	23	71	74	16	1	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	1	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.4	4.3	4.3	4.5	4.1	4.5	4.2	3.8	4.3	4.7	4.8	4.6	(14)	
(15)	Precipitation	PrecAvg	901	79	68	49	42	47	66	98	128	103	87	92	(15)	
(16)		PrecMax	1090	145	180	90	97	104	93	115	179	237	219	175	142	(16)
(17)		PrecMin	618	7	3	7	12	14	15	29	30	56	34	5	25	(17)
(18)		PrecStd	98	37	33	22	18	23	18	19	37	49	41	50	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	4.9	6.1	12.9	18.2	20.5	20.6	19.6	15.2	11.8	8.3	6.0	(19)
(20)			MCWB	3.9	2.2	2.8	6.4	9.6	12.6	13.0	13.1	10.2	9.1	5.9	4.1	(20)
(21)		2%	DB	4.7	3.8	4.8	9.3	14.9	16.2	17.6	17.5	13.7	10.3	6.9	5.1	(21)
(22)			MCWB	2.7	2.0	2.3	4.6	7.6	10.6	12.4	12.4	10.3	8.1	4.9	3.3	(22)
(23)		5%	DB	3.6	2.9	3.6	7.4	12.8	13.9	16.0	16.0	12.9	9.4	5.7	3.9	(23)
(24)			MCWB	2.0	1.4	1.4	3.6	7.1	9.9	12.3	12.2	10.1	7.2	3.8	2.3	(24)
(25)		10%	DB	2.6	2.0	2.6	6.1	11.3	12.6	14.7	14.8	12.3	8.6	4.5	2.7	(25)
(26)			MCWB	1.3	0.7	0.6	3.0	6.7	9.6	12.0	12.0	9.9	6.4	2.8	1.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	3.2	3.9	7.1	10.1	13.0	14.1	14.9	12.1	10.4	6.7	4.9	(27)
(28)			MCD B	6.3	3.8	5.0	12.5	15.7	18.0	16.8	18.0	13.2	11.4	8.1	5.6	(28)
(29)		2%	WB	3.1	2.4	2.9	5.2	8.9	11.8	13.4	13.8	11.5	9.0	5.5	3.5	(29)
(30)			MCD B	4.4	3.2	4.3	8.5	12.8	15.0	15.8	15.8	12.8	10.0	6.7	4.8	(30)
(31)		5%	WB	2.4	1.6	1.9	4.3	8.1	11.0	12.9	13.1	11.0	7.9	4.4	2.7	(31)
(32)			MCD B	3.5	2.5	3.2	6.6	11.2	13.3	15.0	14.6	12.2	9.0	5.7	3.9	(32)
(33)		10%	WB	1.6	0.8	1.0	3.6	7.4	10.3	12.5	12.7	10.6	6.9	3.1	1.7	(33)
(34)			MCD B	2.6	1.6	2.2	5.7	10.1	12.2	14.3	14.2	11.8	8.1	4.5	2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.2	4.6	4.5	5.0	3.8	3.5	3.7	3.7	3.7	3.9	4.1	(35)
(36)			MCD BR	4.2	4.0	4.6	6.1	8.2	6.6	6.0	5.7	4.3	4.0	3.7	3.9	(36)
(37)			MCWBR	3.0	2.7	3.0	3.4	3.8	3.0	2.7	2.9	3.0	2.7	2.8	2.7	(37)
(38)		5% WB	MCD BR	3.9	3.5	4.0	5.8	6.9	5.7	4.9	4.6	3.6	3.3	3.4	3.7	(38)
(39)			MCWBR	3.0	2.7	2.8	3.3	3.4	2.9	2.5	2.7	2.6	2.5	2.8	2.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.260	0.307	0.328	0.365	0.382	0.370	0.385	0.371	0.331	0.316	0.272	0.257	(40)	
(41)		taud	2.089	2.170	2.162	2.130	2.190	2.355	2.363	2.398	2.483	2.295	2.069	1.938	(41)	
(42)		Ebn at Noon	476	668	783	821	838	859	833	817	796	655	436	283	(42)	
(43)		Edh at Noon	42	72	100	125	128	111	108	96	74	63	42	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	1.00	2.69	4.28	5.22	5.41	4.76	3.77	2.46	1.15	0.44	0.17	(44)	
(45)		RadStd	0.04	0.15	0.32	0.46	0.48	0.33	0.36	0.41	0.35	0.14	0.07	0.02	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (23 neighbors)		+0.72	+2.27	+1.95	N/A	N/A	N/A	N/A	-250	N/A	N/A	

Nomenclature: See separate page