

CAPE ELIZABETH BUOY 46041, USA

WMO: 994980

Lat: 47.353N

Lon: 124.742W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	3.4	N/A	N/A	N/A	N/A	N/A	N/A	16.0	8.1	15.0	7.7	5.5	110	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 1.9	(c) 16.9	(d) N/A	(e) 16.4	(f) N/A	(g) 15.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.5	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	13.7	11.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	7.7	7.4	8.0	9.1	10.8	12.4	13.8	14.1	13.7	12.3	9.8	7.8
	DBStd	2.94	2.02	1.83	1.50	1.50	1.54	1.27	1.24	1.14	1.23	1.44	1.80	2.08
	HDD10.0	347	73	72	64	36	8	0	0	0	0	1	23	71
	HDD18.3	2823	329	305	321	278	233	178	141	131	138	188	256	326
	CDD10.0	566	2	1	2	8	33	72	117	127	112	71	17	3
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.6	7.1	6.0	6.1	6.0	4.9	4.6	4.3	3.8	4.2	5.5	6.5	7.6
Precipitation	PrecAvg	2733	429	273	315	196	114	87	43	69	108	281	412	407
	PrecMax	3473	770	705	564	367	213	191	127	305	317	516	771	668
	PrecMin	1994	263	17	47	47	25	23	7	6	7	28	132	202
	PrecStd	376	109	139	122	82	50	40	29	66	72	125	166	115
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	11.7	12.5	14.1	16.8	16.8	16.9	17.9	17.7	15.7	14.1	12.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.5	10.9	11.2	12.9	15.1	15.4	16.3	17.0	16.6	15.2	13.2	11.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.8	10.4	10.6	11.8	14.1	14.7	16.0	16.5	16.0	14.8	12.6	11.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	10.3	10.0	10.1	11.2	12.9	14.2	15.6	15.8	15.5	14.3	12.0	10.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.4	2.4	2.0	1.7	1.6	1.7	1.9	2.1	2.0	2.3	2.3
		MCDBR	2.3	2.6	2.7	2.4	2.8	2.2	2.0	2.7	2.5	2.2	2.6	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.321	0.323	0.337	0.367	0.394	0.356	0.348	0.350	0.344	0.341	0.326	0.316
	taud		2.528	2.548	2.526	2.410	2.350	2.497	2.552	2.549	2.551	2.543	2.522	2.512
	Ebn at Noon		770	852	890	887	871	907	910	896	870	816	754	728
	Edh at Noon		63	75	88	109	120	104	97	94	85	74	63	57
All-Sky Solar Radiation	RadAvg		1.02	1.93	2.99	4.39	5.26	5.75	5.75	4.95	3.94	2.34	1.25	0.87
	RadStd		0.13	0.22	0.30	0.37	0.43	0.44	0.45	0.39	0.31	0.25	0.16	0.11

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page