

NORTH SEA STATION 62145, United Kingdom

WMO: 994990

Lat: 53.102N

Lon: 2.800E

Elev: 98

StdP: 14.64

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.1	34.1	18.8	14.2	34.4	21.8	16.4	36.0	43.4	44.3	41.0	44.0	17.2	90	0.753

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	70.5	63.2	68.6	62.5	67.0	61.8	64.8	68.4	63.7	67.2	62.6	66.3	12.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.2	66.6	62.1	83.7	65.5	60.8	79.8	65.1	29.9	68.6	29.0	67.2	28.2	66.3	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.8	34.1	30.9	DB	32.1	77.5	2.5	3.7	30.3	80.2	28.8	82.4	27.4	84.5	25.6	87.1	(4)
(5)			WB	28.2	66.0	3.5	1.4	25.7	67.0	23.6	67.8	21.7	68.6	19.2	69.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	43.0	41.2	43.2	47.5	52.3	57.0	61.7	63.4	61.1	56.0	51.2	45.5	(6)
(7)		DBStd	8.49	3.84	4.18	4.28	4.08	3.97	3.83	3.40	3.36	3.66	4.11	3.73	4.24	(7)
(8)		HDD50	976	216	246	212	97	22	1	0	0	0	5	30	147	(8)
(9)		HDD65	4796	681	666	675	526	394	240	114	71	128	281	415	605	(9)
(10)		CDD50	1700	0	0	2	21	93	212	361	417	332	191	64	7	(10)
(11)		CDD65	44	0	0	0	0	0	1	10	22	10	1	0	0	(11)
(12)		CDH74	17	0	0	0	0	0	1	9	6	1	0	0	0	(12)
(13)		CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0	(13)
(14)	Wind	WSAvg	15.5	20.1	16.7	15.9	13.1	13.9	12.3	12.7	13.2	14.2	16.3	18.4	19.4	(14)
(15)	Precipitation	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3	(15)
(16)		PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2	(16)
(17)		PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0	(17)
(18)		PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	51.0	53.8	59.3	64.1	69.3	73.8	74.4	71.7	67.4	62.1	54.9	(19)
(20)			MCWB	49.0	46.9	48.0	52.0	56.1	61.5	64.0	65.3	64.2	61.4	57.5	51.4	(20)
(21)		2%	DB	50.7	49.4	50.7	55.9	61.0	65.8	69.5	70.8	68.7	64.5	59.2	53.8	(21)
(22)			MCWB	48.0	46.1	46.4	50.3	54.8	59.4	62.2	63.5	62.7	60.4	54.8	50.3	(22)
(23)		5%	DB	49.4	48.3	49.2	53.9	58.6	63.1	67.3	69.0	66.9	62.9	57.6	52.8	(23)
(24)			MCWB	46.8	45.1	45.4	49.3	53.6	58.3	61.7	63.0	62.0	59.0	53.7	49.3	(24)
(25)		10%	DB	48.1	46.8	48.0	52.2	56.7	61.2	65.5	67.4	65.5	61.2	56.3	51.4	(25)
(26)			MCWB	45.3	43.8	44.6	48.3	52.6	57.3	60.8	62.2	61.1	57.1	52.5	48.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	48.5	48.9	53.1	58.4	63.5	66.0	66.7	65.5	62.9	57.6	52.6	(27)
(28)			MCDWB	51.4	50.1	52.5	58.2	61.4	66.5	71.4	70.2	68.4	65.9	60.9	54.6	(28)
(29)		2%	WB	48.4	46.7	47.2	51.1	55.7	60.9	63.9	65.3	64.0	60.8	55.8	50.9	(29)
(30)			MCDWB	50.2	48.9	49.8	55.0	59.4	63.9	67.9	68.9	67.3	63.9	58.6	53.2	(30)
(31)		5%	WB	47.2	45.4	46.1	49.8	54.1	59.2	62.5	64.0	62.9	59.5	54.4	49.5	(31)
(32)			MCDWB	49.1	47.7	48.6	53.2	57.6	62.0	66.5	67.6	66.4	62.5	57.0	52.2	(32)
(33)		10%	WB	45.7	44.3	45.1	48.6	53.0	57.9	61.0	62.9	61.6	57.9	53.0	48.3	(33)
(34)			MCDWB	47.7	46.6	47.6	51.8	56.2	60.7	64.8	66.5	65.4	60.9	55.7	50.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	4.0	4.8	6.0	6.0	6.1	6.3	6.0	5.3	4.6	4.5	4.3	(35)
(36)			MCDBR	5.2	4.7	6.5	8.7	9.7	9.9	9.8	9.2	8.0	6.1	5.5	4.9	(36)
(37)			MCWBR	6.1	4.6	4.7	5.2	6.0	6.3	5.2	5.3	5.6	6.0	5.7	5.8	(37)
(38)		5% WB	MCDWB	5.0	4.7	5.9	8.2	8.6	9.3	8.7	8.0	7.6	5.6	5.2	4.8	(38)
(39)			MCWBR	6.2	4.5	4.8	5.1	5.8	6.4	4.9	5.4	5.8	6.3	5.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.348	0.378	0.403	0.402	0.405	0.409	0.398	0.384	0.362	0.337	0.321	(40)	
(41)		taud	2.333	2.369	2.313	2.281	2.359	2.361	2.360	2.401	2.431	2.429	2.375	2.322	(41)	
(42)		Ebn at Noon	202	238	254	263	269	269	265	262	251	230	198	181	(42)	
(43)		Edh at Noon	19	25	32	37	36	37	36	33	29	23	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	206	435	857	1417	1759	1843	1776	1494	1037	557	249	155	(44)	
(45)		RadStd	19	73	75	132	112	98	184	103	76	45	22	16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page