

NORTH SEA STATION 62116, United Kingdom

WMO: 995060

Lat: 57.700N

Lon: 1.400E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (E00)

Period: 04-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.7	34.5	20.8	15.6	36.3	23.5	17.8	37.7	46.6	42.5	43.6	42.4	17.5	120	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	65.9	59.9	64.0	58.6	62.3	57.6	61.5	64.3	60.1	62.5	59.0	61.3	9.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	77.4	62.9	58.8	74.1	61.5	57.8	71.2	60.6	27.5	65.4	26.5	62.5	25.8	61.4	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.4	39.0	34.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.7	42.6	42.2	42.7	45.7	49.7	54.6	58.5	59.2	56.4	51.9	48.2	44.1	
	DBStd	6.85	3.23	3.45	3.85	2.88	3.39	3.17	2.99	2.15	2.41	2.56	2.84	3.83	
	HDD50	1115	228	218	228	131	46	2	0	0	0	11	66	185	
	HDD65	5588	693	638	692	578	475	312	203	179	258	406	505	649	
	CDD50	1004	0	0	1	3	37	140	263	286	192	70	11	1	
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	18.2	22.3	20.3	19.1	16.4	16.0	13.4	13.8	14.3	18.1	20.6	22.5	22.0	
Precipitation	PrecAvg	49.4	5.9	5.0	4.6	2.5	1.9	2.5	3.0	3.6	4.4	5.0	5.3	5.7	
	PrecMax	61.4	8.5	10.4	8.2	4.1	3.6	4.1	5.3	9.1	6.5	8.8	7.2	11.4	
	PrecMin	38.0	2.4	2.4	2.2	1.7	0.8	1.1	1.3	1.5	1.6	1.9	2.5	2.9	
	PrecStd	6.0	1.9	1.9	1.5	0.7	0.6	0.7	0.9	1.3	1.3	1.6	1.3	1.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	51.3	53.1	56.0	62.9	66.6	70.7	67.8	64.8	59.3	55.5	52.3	
		MCWB	46.9	46.6	46.6	49.5	54.2	59.0	62.9	59.2	56.5	54.9	50.5	49.7	
	2%	DB	48.8	48.6	49.7	52.7	58.7	63.1	66.5	64.9	61.4	57.2	53.9	51.2	
		MCWB	45.9	45.5	45.3	47.5	51.6	55.8	61.5	58.7	57.0	53.5	50.8	48.6	
	5%	DB	47.8	47.4	47.7	50.7	56.2	60.5	64.6	63.1	60.3	56.0	52.8	50.2	
		MCWB	45.0	44.6	44.5	46.6	50.6	54.4	59.9	58.1	56.8	52.7	50.1	47.7	
	10%	DB	46.7	46.5	46.8	49.3	54.0	58.6	62.6	61.9	59.3	54.9	51.9	49.1	
		MCWB	43.8	43.8	43.9	46.0	49.3	53.9	58.7	57.8	56.1	51.8	49.4	46.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	48.0	47.8	50.3	55.6	59.8	64.4	61.9	59.7	56.2	52.9	50.3
			MCDB	49.3	50.4	51.5	53.6	60.0	65.2	68.0	64.1	61.4	58.1	53.9	51.6
2%		WB	46.6	46.5	46.3	48.8	53.4	57.5	62.7	60.6	59.0	55.0	51.6	49.2	
		MCDB	48.2	48.2	48.6	51.6	57.1	61.1	66.1	62.7	60.4	56.3	52.6	50.7	
5%		WB	45.5	45.4	45.4	47.6	51.6	56.1	60.9	59.8	58.1	53.9	50.8	48.2	
		MCDB	47.3	47.0	47.5	50.1	54.7	59.1	63.6	61.7	59.6	55.4	52.2	50.0	
10%		WB	44.4	44.4	44.5	46.6	50.4	55.0	59.4	59.0	56.9	52.7	50.0	46.9	
		MCDB	46.2	46.0	46.5	48.9	53.5	57.7	62.4	60.8	58.6	54.3	51.7	48.8	
Mean Daily Temperature Range		5% DB	MDBR	4.4	4.7	5.1	5.8	5.9	6.4	5.6	5.2	4.7	4.3	4.4	4.7
			MCDBR	5.4	6.2	6.6	8.4	10.0	9.9	9.2	7.5	6.4	5.7	5.4	5.2
	MCWBR		5.8	5.3	5.0	5.5	5.9	5.9	5.2	4.8	4.5	5.0	5.4	6.2	
	5% WB	MCDBR	5.2	5.5	5.6	7.3	7.1	8.3	7.8	5.5	4.8	4.9	4.4	5.0	
		MCWBR	6.0	5.3	4.9	5.2	5.1	5.4	5.1	4.6	4.0	5.1	5.3	6.4	
Clear-Sky Solar Irradiance	taub	0.335	0.353	0.370	0.392	0.376	0.379	0.388	0.385	0.372	0.353	0.334	0.311		
	taud	2.175	2.264	2.302	2.286	2.411	2.427	2.416	2.427	2.442	2.363	2.232	2.147		
	Ebn at Noon	155	213	245	259	273	273	267	259	245	212	155	126		
	Edh at Noon	17	24	30	36	34	34	33	31	26	22	16	13		
All-Sky Solar Radiation	RadAvg	116	311	713	1238	1730	1708	1596	1312	863	430	159	77		
	RadStd	12	41	52	101	105	123	153	94	83	32	16	9		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page