

SEAL ROCKS BUOY 46061, AK, USA

WMO: 995160

Lat: 60.238N

Lon: 146.833W

Elev: 0

StdP: 14.70

Time Zone: -9.00 (NAK)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	21.9	24.0	N/A	N/A	N/A	N/A	N/A	N/A	43.1	33.9	39.4	33.5	17.7	340	0.830

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	61.9	N/A	60.2	N/A	59.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.0	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
40.7	36.7	33.1	19.3	65.2	2.3	3.8	17.7	67.9	16.3	70.1	15.1	72.2	13.4	75.0		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	35.2	35.5	34.8	39.3	45.4	50.9	55.1	55.8	51.8	45.8	39.1	37.2	
	DBStd	8.60	5.41	4.39	4.39	3.33	3.56	3.23	2.62	2.49	2.70	3.55	5.11	4.39	
	HDD50	2700	459	407	472	321	147	25	0	0	13	133	326	397	
	HDD65	7707	924	827	937	771	606	423	306	284	395	596	776	862	
	CDD50	468	0	0	0	0	6	52	159	181	68	2	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
	WSAvg	14.8	17.9	18.0	15.7	14.1	11.1	9.5	9.9	11.5	15.3	16.8	19.2	19.2	
	PrecAvg	56.1	5.4	4.7	3.8	2.9	2.9	2.8	3.8	5.2	7.0	6.1	5.4	6.1	
Precipitation	PrecMax	72.1	12.8	10.1	9.6	5.6	5.9	4.5	6.3	9.5	11.9	12.3	12.5	12.0	
	PrecMin	38.8	1.2	0.1	1.1	0.9	0.8	0.8	2.0	1.1	2.8	3.0	0.1	2.0	
	PrecStd	7.0	2.4	2.1	2.1	1.1	1.4	0.9	1.0	2.2	2.4	2.4	2.9	2.4	
	PrecStd	7.0	2.4	2.1	2.1	1.1	1.4	0.9	1.0	2.2	2.4	2.4	2.9	2.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.2	45.0	43.4	50.3	55.9	61.3	64.2	65.0	59.1	53.1	49.1	46.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	44.0	43.2	42.1	47.3	53.5	58.8	61.1	62.5	57.3	51.5	47.9	45.0	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	42.6	41.9	41.3	45.2	51.5	56.8	59.6	61.0	56.4	50.9	46.6	43.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	41.5	40.9	40.4	43.4	50.2	55.3	58.7	59.5	55.5	50.2	45.4	42.7	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.3	4.3	4.0	3.9	3.6	3.2	3.2	3.5	3.7	4.6	4.6	
		MCDBR	5.0	5.1	4.4	5.4	6.0	5.6	4.5	5.0	4.0	3.9	4.9	5.4	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.270	0.306	0.319	0.362	0.371	0.366	0.372	0.365	0.341	0.324	0.273	0.401		
	taud	2.210	2.375	2.422	2.324	2.374	2.455	2.477	2.488	2.525	2.399	2.211	2.686		
	Ebn at Noon	159	223	260	265	271	275	270	263	251	211	153	108		
	Edh at Noon	13	19	25	33	34	32	31	28	23	19	12	10		
All-Sky Solar Radiation	RadAvg	79	255	675	1163	1527	1620	1389	1064	725	330	113	47		
	RadStd	12	59	107	139	171	138	177	169	134	44	27	6		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	+2.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page