

SEAL ROCKS BUOY 46061, AK, USA

WMO: 995160

Lat: 60.238N

Lon: 146.833W

Elev: 0

StdP: 101.33

Time Zone: -9.00 (NAK)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-5.6	-4.5	N/A	N/A	N/A	N/A	N/A	N/A	19.2	1.0	17.6	0.8	7.9	340	0.830

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	16.6	N/A	15.7	N/A	15.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	16.4	14.8	-7.0	18.4	1.3	2.1	-8.0	19.9	-8.7	21.2	-9.4	22.3	-10.3	23.9		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	1.8	1.9	1.5	4.1	7.5	10.5	12.9	13.2	11.0	7.7	4.0	2.9
	DBStd	4.78	3.01	2.44	2.44	1.85	1.98	1.79	1.45	1.38	1.50	1.97	2.84	2.44
	HDD10.0	1500	255	226	262	178	82	14	0	0	7	74	181	221
	HDD18.3	4282	513	459	521	428	337	235	170	158	219	331	431	479
	CDD10.0	260	0	0	0	0	3	29	88	101	38	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.6	8.0	8.1	7.0	6.3	5.0	4.2	4.4	5.2	6.8	7.5	8.6	8.6
Precipitation	PrecAvg	1424	138	120	97	74	73	70	97	133	177	155	137	154
	PrecMax	1832	324	256	243	141	149	115	159	241	303	313	317	304
	PrecMin	985	30	2	28	24	21	21	52	28	71	77	2	51
	PrecStd	178	62	54	54	29	35	22	25	56	60	60	74	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	7.2	6.4	10.2	13.3	16.3	17.9	18.3	15.0	11.7	9.5	8.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	6.6	6.2	5.6	8.5	12.0	14.9	16.1	16.9	14.1	10.8	8.8	7.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	5.9	5.5	5.1	7.3	10.9	13.8	15.3	16.1	13.6	10.5	8.1	6.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	5.3	4.9	4.7	6.3	10.1	12.9	14.8	15.3	13.1	10.1	7.5	6.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.4	2.4	2.2	2.2	2.0	1.8	1.8	1.9	2.0	2.5	2.6
		MCDBR	2.8	2.8	2.5	3.0	3.3	3.1	2.5	2.8	2.2	2.1	2.7	3.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.270	0.306	0.319	0.362	0.371	0.366	0.372	0.365	0.341	0.324	0.273	0.401	
	taud	2.210	2.375	2.422	2.324	2.374	2.455	2.477	2.488	2.525	2.399	2.211	2.686	
	Ebn at Noon	501	704	819	835	855	866	851	828	790	666	481	339	
	Edh at Noon	40	61	79	105	107	101	97	89	72	59	39	30	
All-Sky Solar Radiation	RadAvg	0.25	0.80	2.13	3.67	4.81	5.11	4.38	3.35	2.29	1.04	0.36	0.15	
	RadStd	0.04	0.19	0.34	0.44	0.54	0.44	0.56	0.53	0.42	0.14	0.09	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	+1.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page