

NORTH SEA STATION 62118, United Kingdom

WMO: 995190

Lat: 57.700N

Lon: 0.900E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.1	1.8	-7.0	2.1	2.5	-5.8	2.3	2.9	22.3	4.3	21.0	5.2	9.3	80	0.873

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.0	18.7	17.5	17.6	16.3	16.8	15.5	17.9	18.5	16.7	17.4	15.8	16.6	5.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	18.5	16.3	11.6	17.3	15.4	10.9	16.5	50.3	18.6	46.7	17.4	44.3	16.7	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	17.2	15.3	DB	0.0	19.5	1.4	1.7	-1.0	20.8	-1.8	21.8	-2.6	22.8	-3.6	24.0	(4)
(5)			WB	-2.4	17.6	1.2	1.9	-3.2	19.0	-3.9	20.1	-4.5	21.2	-5.4	22.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	6.0	5.5	6.2	6.9	8.7	11.2	14.0	14.9	13.5	10.7	9.3	6.8
	DBStd	3.73	2.13	2.22	1.81	1.90	2.00	1.63	1.69	1.90	1.62	1.78	1.89	2.18
	HDD10.0	666	124	128	117	95	49	6	0	0	1	14	33	100
	HDD18.3	3227	382	361	375	343	297	214	133	108	145	238	272	358
	CDD10.0	483	1	1	1	2	9	42	125	151	106	34	11	1
	CDD18.3	2	0	0	0	0	0	0	0	2	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.9	9.8	9.7	8.8	7.4	6.7	6.3	5.8	6.1	7.3	9.1	9.3	9.0
Precipitation	PrecAvg	1255	150	126	116	64	47	64	76	92	112	128	135	145
	PrecMax	1559	215	263	209	104	92	105	134	232	166	224	182	290
	PrecMin	964	60	61	57	42	21	29	33	37	41	49	63	73
	PrecStd	153	49	48	39	17	16	19	22	34	34	41	32	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	10.9	11.7	12.0	14.7	17.0	18.6	20.6	17.4	14.9	13.1	11.7
		MCWB	10.2	9.8	8.6	9.2	12.0	14.6	16.8	19.3	15.6	13.6	11.0	10.0
	2%	DB	10.1	10.4	10.0	10.2	13.1	15.2	17.8	19.5	16.8	13.9	12.5	11.0
		MCWB	8.5	9.3	8.1	8.2	11.0	13.5	16.3	18.5	15.4	12.5	10.8	9.5
	5%	DB	9.4	9.5	9.1	9.6	11.8	14.2	17.1	18.5	16.3	13.4	12.1	10.2
		MCWB	7.8	8.3	7.5	7.9	10.2	12.8	15.8	17.5	15.0	12.0	10.7	8.7
	10%	DB	8.8	8.6	8.6	9.0	11.1	13.5	16.4	17.4	15.7	12.9	11.6	9.6
		MCWB	7.3	7.3	7.1	7.7	9.7	12.3	15.1	16.2	14.3	11.5	10.2	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	9.8	9.1	9.4	12.6	15.0	17.7	19.7	16.5	13.7	11.7	10.7
		MCDB	11.6	10.8	10.4	11.1	14.2	16.5	18.0	20.5	17.0	14.4	12.2	11.4
	2%	WB	8.9	9.3	8.5	8.7	11.2	13.8	16.7	18.7	15.9	13.0	11.2	9.7
		MCDB	9.8	10.3	9.5	9.7	12.2	14.6	17.4	19.3	16.6	13.6	12.0	10.6
	5%	WB	8.1	8.4	7.9	8.3	10.5	13.2	16.0	17.7	15.3	12.4	10.9	9.0
		MCDB	9.1	9.3	8.9	9.3	11.5	14.1	16.8	18.4	16.1	13.1	11.8	9.9
	10%	WB	7.5	7.4	7.4	7.9	10.0	12.5	15.4	16.5	14.6	11.8	10.5	8.4
		MCDB	8.6	8.5	8.5	8.9	11.0	13.3	16.2	17.3	15.5	12.6	11.5	9.5
Mean Daily Temperature Range	5% DB	MDBR	2.4	2.4	2.3	2.3	2.2	1.9	2.0	2.0	2.0	2.2	2.1	2.5
		MCDBR	2.8	2.8	2.8	3.5	3.1	2.8	2.8	2.7	2.5	2.4	2.5	2.9
		MCWBR	3.0	3.1	2.4	2.7	2.6	2.3	2.3	2.5	2.3	2.7	2.8	3.3
	5% WB	MCDBR	2.8	2.5	2.7	3.1	2.8	2.5	2.3	2.6	2.1	2.3	2.3	2.6
		MCWBR	3.2	2.9	2.7	2.5	2.5	2.4	2.2	2.5	2.2	2.7	2.7	3.1
Clear-Sky Solar Irradiance	taub	0.333	0.352	0.370	0.392	0.377	0.380	0.389	0.383	0.370	0.353	0.333	0.311	
	taud	2.181	2.269	2.306	2.288	2.409	2.427	2.415	2.433	2.449	2.366	2.235	2.148	
	Ebn at Noon	491	673	773	817	859	860	842	820	773	667	491	398	
	Edh at Noon	54	76	95	112	106	106	105	96	82	68	50	41	
All-Sky Solar Radiation	RadAvg	0.37	0.98	2.25	3.90	5.46	5.38	5.03	4.14	2.72	1.35	0.50	0.24	
	RadStd	0.04	0.13	0.17	0.32	0.33	0.39	0.48	0.30	0.26	0.10	0.05	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page