

NORTH SEA STATION 63101, United Kingdom

WMO: 995280

Lat: 61.117N

Lon: 0.900E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 98-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.3	1.1	N/A	N/A	N/A	N/A	N/A	N/A	22.7	3.4	21.5	3.6	10.6	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	17.9	N/A	16.5	N/A	15.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	17.9	15.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	6.0	5.4	6.2	7.1	9.0	10.7	13.1	13.7	12.2	9.6	8.1	6.2
	DBStd	3.41	1.94	2.43	2.06	2.03	1.78	1.83	1.66	1.44	1.63	1.69	1.89	2.61
	HDD10.0	716	123	128	117	89	41	12	0	0	2	26	58	119
	HDD18.3	3417	382	361	376	338	291	229	162	144	183	270	306	377
	CDD10.0	340	0	0	0	1	9	32	97	114	70	14	2	1
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	8.1	9.9	9.5	8.6	7.6	6.5	6.7	6.6	6.3	8.0	9.2	9.4	9.5
(15) Precipitation	PrecAvg	1341	161	132	127	72	48	65	81	100	117	141	139	156
	PrecMax	1652	252	257	237	123	83	132	153	162	190	216	220	240
	PrecMin	954	76	58	46	26	22	26	40	66	48	58	43	65
	PrecStd	165	48	53	46	23	16	24	22	25	34	41	39	42
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.4	11.5	12.9	15.4	18.8	19.7	20.2	17.3	13.7	12.6	12.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	10.2	10.4	10.5	11.2	13.3	15.7	18.1	17.4	15.8	12.9	11.7	11.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.5	9.7	9.8	10.3	12.3	13.9	16.6	16.3	15.0	12.3	11.0	10.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.7	8.9	9.1	9.5	11.3	12.9	15.3	15.6	14.3	11.7	10.5	9.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	3.0	3.3	3.2	3.0	3.1	2.8	2.6	2.6	2.5	2.5	3.0	3.1
		MCDBR	3.6	3.9	3.9	4.1	4.6	4.3	4.3	3.8	3.3	2.9	3.5	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.338	0.357	0.370	0.382	0.372	0.365	0.382	0.371	0.366	0.348	0.324	0.382
	taud		2.062	2.181	2.260	2.302	2.401	2.463	2.431	2.462	2.422	2.302	2.123	2.280
	Ebn at Noon		341	592	736	808	851	864	836	817	745	605	356	213
	Edh at Noon		45	72	92	106	104	99	100	90	79	63	41	29
(44) All-Sky Solar Radiation	RadAvg		0.19	0.68	1.80	3.51	4.89	4.99	4.53	3.63	2.20	1.03	0.30	0.12
	RadStd		0.03	0.08	0.19	0.27	0.35	0.54	0.41	0.34	0.17	0.12	0.04	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	N/A	+0.65	+0.62	N/A	N/A	N/A	-102	-134	N/A	N/A

Nomenclature: See separate page