

CANAVERAL BUOY 41009, FL, USA

WMO: 995450

Lat: 28.508N

Lon: 80.185W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (W05)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.6	52.8	33.1	27.6	53.4	36.6	31.8	56.5	34.5	59.5	32.5	58.4	21.8	310	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	85.6	78.2	85.0	77.9	84.4	77.5	80.2	83.7	79.5	83.4	79.0	83.2	10.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	150.5	83.2	78.3	146.8	82.9	77.6	143.7	82.7	43.6	83.8	42.9	83.5	42.4	83.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.7	26.1	23.9	DB	45.4	86.8	4.4	1.3	42.2	87.8	39.7	88.6	37.2	89.3	34.1	90.3
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	66.2	66.8	68.8	72.6	76.4	79.7	81.2	81.9	81.1	78.2	73.1	69.3
	DBStd	6.83	6.01	5.59	4.69	3.20	2.24	1.92	1.66	1.57	1.71	2.94	4.31	6.04
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	170	60	44	25	2	0	0	0	0	0	0	5	34
	CDD50	9004	503	471	581	678	820	891	968	989	933	875	694	601
	CDD65	3696	97	95	141	230	355	441	503	524	483	410	248	169
	CDH74	28739	46	33	77	502	2076	4257	5442	6068	5372	3467	1030	369
	CDH80	5165	0	0	0	0	22	557	1221	1724	1283	347	11	0
(14) Wind	WSAvg	13.2	15.5	14.8	14.7	13.6	12.3	10.9	10.0	10.1	11.7	13.9	15.6	15.2
(15) Precipitation	PrecAvg	50.4	2.4	2.2	3.1	2.4	3.4	7.0	6.4	7.2	6.7	4.9	2.2	2.3
	PrecMax	71.1	5.7	7.5	13.3	6.0	13.5	13.1	10.5	17.7	13.3	13.4	8.7	9.3
	PrecMin	37.3	0.0	0.3	0.0	0.4	0.6	0.7	2.1	1.6	3.5	0.8	0.3	0.6
	PrecStd	8.8	1.4	1.5	3.0	1.3	2.6	2.7	2.5	3.0	2.5	2.9	1.9	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.7	76.0	76.7	79.0	81.9	85.7	86.2	86.5	85.4	84.7	81.2	78.4
		MCWB	70.6	71.0	70.7	72.9	75.0	78.8	78.9	78.4	77.7	77.3	74.7	71.4
	2%	DB	75.4	75.1	75.8	78.1	80.5	84.4	85.3	85.9	84.7	83.3	80.2	77.7
		MCWB	69.5	70.6	69.6	72.2	74.3	78.1	78.3	78.2	77.0	76.0	73.7	71.7
	5%	DB	74.4	74.3	75.0	77.3	80.1	83.4	84.4	85.2	84.3	82.5	79.4	77.0
		MCWB	68.5	69.7	68.9	71.5	74.0	77.5	77.8	78.0	76.7	75.1	72.8	71.1
	10%	DB	73.3	73.4	74.1	76.6	79.4	82.6	83.9	84.5	83.8	81.9	78.4	76.2
		MCWB	67.5	68.6	68.1	70.5	73.5	77.0	77.5	77.8	76.3	74.5	71.3	70.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	72.9	72.5	75.4	77.4	80.6	81.1	81.1	80.2	78.8	76.5	74.5
		MCDB	75.3	75.2	75.3	77.8	79.7	83.9	83.8	84.2	83.9	84.0	79.9	77.3
	2%	WB	71.0	71.8	71.3	74.1	76.6	79.5	80.1	80.2	79.2	77.5	75.4	73.7
		MCDB	74.7	74.6	74.5	77.2	79.2	83.1	83.5	83.8	83.6	82.4	79.5	77.1
	5%	WB	69.7	71.0	70.3	73.1	75.9	78.8	79.3	79.5	78.4	76.9	74.6	72.7
		MCDB	73.6	74.1	73.8	76.6	78.8	82.5	83.2	83.5	83.2	82.0	79.1	76.5
	10%	WB	68.6	70.1	69.1	72.2	75.1	78.1	78.7	79.0	77.8	76.0	73.3	71.4
		MCDB	72.9	73.5	73.1	76.0	78.4	82.1	82.8	83.3	82.9	81.2	78.5	75.7
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.0	4.9	4.2	3.6	4.0	4.3	4.3	3.7	3.5	4.4	5.4
		MCDBR	5.0	4.6	4.7	4.2	4.2	4.5	4.5	4.5	3.9	3.7	4.0	3.9
	5% WB	MCWBR	5.7	4.5	5.1	4.5	3.7	3.9	3.6	3.6	3.6	3.3	4.0	4.3
		MCWBR	5.6	4.0	4.8	3.8	4.2	4.7	3.9	4.4	3.8	3.9	3.8	4.6
(40) Clear-Sky Solar Irradiance	taub		0.352	0.363	0.377	0.400	0.430	0.455	0.470	0.461	0.428	0.403	0.367	0.357
		taud	2.547	2.527	2.480	2.393	2.351	2.356	2.313	2.352	2.432	2.472	2.524	2.557
	Ebn at Noon		283	288	290	285	275	266	262	264	270	271	274	275
		Edh at Noon	28	31	34	38	40	40	41	39	36	32	29	27
(44) All-Sky Solar Radiation	RadAvg		1044	1279	1629	1951	2030	1954	1945	1845	1593	1387	1112	954
	RadStd		80	89	111	75	145	191	109	106	113	97	64	64

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-83	+270	+200

Nomenclature: See separate page