

EAST SCOTIA SLOPE BUOY 44137, CanadaWMO: **995480**Lat: **42.260N**Lon: **62.000W**Elev: **10**StdP: **14.69**Time Zone: **-4.00 (W04)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.3	28.6	N/A	N/A	N/A	N/A	N/A	N/A	45.4	41.5	42.4	40.7	21.9	310	0.632

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	77.6	N/A	76.2	N/A	74.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.1	35.8	32.2	DB	22.5	76.6	3.3	1.7	20.1	77.8	18.1	78.8	16.3	79.8	13.8	81.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.1	42.5	40.7	42.1	45.4	52.1	59.1	67.9	70.3	67.2	59.6	53.4	47.4	(6)	
(7)		DBStd	11.77	6.59	7.17	6.97	5.21	6.13	5.58	4.23	3.23	4.31	5.37	6.50	6.84	(7)	
(8)		HDD50	1153	244	272	259	159	45	1	0	0	0	2	38	133	(8)	
(9)		HDD65	4396	698	681	710	589	402	193	18	2	27	180	349	547	(9)	
(10)		CDD50	2632	12	11	14	20	111	274	554	628	515	301	141	51	(10)	
(11)		CDD65	400	0	0	0	0	3	17	107	165	92	14	2	0	(11)	
(12)		CDH74	462	0	0	0	0	3	30	151	211	67	0	0	0	(12)	
(13)		CDH80	2	0	0	0	0	0	0	1	0	1	0	0	0	(13)	
(14)	Wind	WSAvg	15.5	18.9	19.0	19.0	15.2	13.3	12.6	10.8	10.8	12.6	15.9	18.6	19.6	(14)	
(15)	Precipitation	PrecAvg	84.7	8.6	7.7	6.5	6.7	5.6	5.8	6.5	7.0	7.2	8.0	7.0	8.2	(15)	
(16)		PrecMax	98.3	12.8	13.9	8.9	10.2	12.0	10.6	16.1	11.9	28.4	15.1	13.1	12.5	(16)	
(17)		PrecMin	65.7	3.0	4.2	3.3	2.1	2.1	0.7	3.3	2.0	1.8	3.2	2.6	3.3	(17)	
(18)		PrecStd	8.8	2.3	2.1	1.6	2.0	2.6	2.6	2.5	2.6	5.4	3.1	2.6	1.9	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	63.6	62.7	63.6	74.1	77.2	79.9	78.8	78.1	72.8	69.9	66.5	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	58.9	59.8	59.9	60.5	67.0	73.9	77.7	77.6	76.2	71.1	67.8	63.1	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	55.9	56.6	56.8	57.3	63.7	70.0	75.5	76.4	74.4	69.4	65.4	60.5	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)	10%	DB	52.8	52.2	52.9	53.6	61.1	67.3	73.9	75.1	73.1	67.6	63.2	57.6	(25)		
(26)		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MADB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MADB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MADB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
(34)		MADB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	10.2	8.4	6.2	5.1	4.6	3.9	3.9	4.4	5.6	7.6	9.5	(35)	
(36)			MADB	15.9	17.0	14.1	10.8	8.1	5.6	4.3	4.7	5.3	7.5	10.5	13.8	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)		5% WB	MADB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.337	0.330	0.346	0.375	0.387	0.416	0.431	0.401	0.370	0.361	0.339	0.329	(40)		
(41)		taud	2.428	2.495	2.466	2.413	2.423	2.368	2.370	2.446	2.499	2.510	2.518	2.468	(41)		
(42)		Ebn at Noon	253	278	286	284	282	273	267	272	274	263	252	246	(42)		
(43)		Edh at Noon	25	27	31	36	36	38	38	34	30	27	23	22	(43)		
(44)	All-Sky Solar Radiation	RadAvg	388	626	1046	1423	1663	1840	1761	1660	1371	882	529	351	(44)		
(45)		RadStd	44	59	116	119	158	177	139	110	106	86	63	32	(45)		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page