

NORTH SEA STATION 62142, United Kingdom

WMO: 995850

Lat: 53.000N

Lon: 2.100E

Elev: 30

StdP: 100.97

Time Zone: 0.00 (EUW)

Period: 02-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.2	0.9	N/A	N/A	N/A	N/A	N/A	N/A	19.3	4.9	16.5	7.7	7.8	80	0.787

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	22.6	N/A	20.8	N/A	19.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.3	14.7	13.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	5.4	4.6	5.8	8.0	10.7	13.7	16.8	17.6	16.0	12.9	9.7	6.6
	DBStd	4.93	2.18	2.27	2.15	2.25	2.00	2.12	2.02	1.88	2.18	2.11	1.78	2.13
	HDD10.0	637	142	150	130	66	16	1	0	0	0	3	26	105
	HDD18.3	2818	400	383	388	309	237	141	57	38	76	168	259	363
	CDD10.0	891	0	0	0	7	37	111	211	234	180	93	17	1
	CDD18.3	31	0	0	0	0	0	1	10	14	6	0	0	0
	CDH23.3	38	0	0	0	0	0	1	13	18	6	1	0	0
	CDH26.7	4	0	0	0	0	0	0	1	3	0	0	0	0
Wind	WSAvg	7.2	8.6	7.7	7.4	6.7	6.8	5.9	5.9	6.2	6.9	7.8	8.5	8.6
Precipitation	PrecAvg	758	73	56	52	46	51	58	61	67	60	71	82	79
	PrecMax	902	124	95	96	126	123	143	99	138	122	115	125	128
	PrecMin	527	16	18	8	4	14	13	28	10	17	19	36	37
	PrecStd	105	30	20	24	31	24	35	23	29	27	24	24	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	10.4	11.4	15.4	17.5	22.4	25.1	26.1	23.8	19.4	14.5	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.7	9.4	9.7	12.9	14.8	18.7	22.0	22.7	20.7	17.4	13.4	10.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.0	8.3	8.9	11.5	13.7	17.0	20.1	21.1	19.3	16.3	12.7	10.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.4	7.5	8.2	10.5	13.0	15.8	18.7	19.8	18.4	15.5	12.1	9.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.3	2.6	3.1	3.1	3.7	4.4	4.1	3.4	2.7	2.4	2.4
		MCDBR	3.0	3.2	3.6	5.3	4.8	6.4	7.1	6.7	5.5	4.0	3.0	2.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.330	0.347	0.378	0.402	0.401	0.406	0.409	0.398	0.382	0.361	0.335	0.319	
	taud	2.343	2.377	2.310	2.278	2.351	2.351	2.354	2.395	2.431	2.437	2.390	2.331	
	Ebn at Noon	642	754	801	829	849	847	837	825	793	729	633	579	
	Edh at Noon	61	78	102	119	116	117	115	105	90	73	58	51	
All-Sky Solar Radiation	RadAvg	0.67	1.37	2.64	4.30	5.32	5.58	5.36	4.53	3.21	1.76	0.82	0.51	
	RadStd	0.06	0.22	0.24	0.41	0.36	0.33	0.53	0.31	0.25	0.14	0.08	0.05	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page