

WEST TAMPA BUOY 42036, USA

WMO: 995910

Lat: 28.501N

Lon: 84.516W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (W06)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.0	9.6	-0.2	3.7	9.6	1.3	4.2	11.3	13.8	14.0	13.3	14.4	8.5	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.1	30.4	25.9	30.1	25.7	29.8	25.5	26.9	29.1	26.6	29.0	26.3	28.8	3.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.8	28.5	25.8	21.1	28.4	25.5	20.7	28.3	84.5	29.1	82.9	29.0	81.5	28.9	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.6	11.6	10.6	DB	5.6	31.0	1.7	0.6	4.4	31.4	3.4	31.7	2.4	32.0	1.1	32.4
			WB	3.1	27.3	1.2	0.7	2.2	27.8	1.5	28.2	0.9	28.6	0.0	29.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	16.5	16.4	18.5	21.2	24.3	27.2	28.2	28.4	27.4	24.9	21.0	18.7	(6)
(7)		DBStd	4.92	3.48	2.84	2.60	2.05	1.66	1.26	1.05	1.00	1.00	2.18	2.85	3.33	(7)
(8)		HDD10.0	4	3	1	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	218	74	63	29	3	0	0	0	0	0	1	11	37	(9)
(10)		CDD10.0	4662	204	181	264	336	443	515	563	571	523	463	330	269	(10)
(11)		CDD18.3	1836	17	10	36	89	185	265	304	312	273	206	91	48	(11)
(12)		CDH23.3	16376	0	0	1	112	969	2826	3740	3946	3026	1503	203	50	(12)
(13)	CDH26.7	4318	0	0	0	0	18	627	1301	1493	749	126	6	0	(13)	
(14)	Wind	WSAvg	5.4	6.5	6.1	5.6	5.0	4.5	4.1	3.9	4.4	5.5	6.0	6.8	6.7	(14)
(15)	Precipitation	PrecAvg	1456	105	93	113	87	70	179	210	211	154	88	63	85	(15)
(16)		PrecMax	1696	220	336	239	211	173	384	395	318	413	183	144	256	(16)
(17)		PrecMin	1076	34	25	8	24	8	47	128	132	38	15	8	26	(17)
(18)		PrecStd	185	48	61	62	44	46	66	60	53	78	47	37	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	21.9	23.3	25.8	27.8	30.2	30.7	31.0	29.9	29.1	27.4	25.3	(19)
(20)			MCWB	21.8	21.4	21.8	23.8	24.7	25.9	26.1	26.1	25.1	24.5	25.2	23.2	(20)
(21)		2%	DB	21.9	21.4	22.7	25.3	27.2	29.7	30.3	30.5	29.5	28.5	26.5	24.8	(21)
(22)			MCWB	21.1	20.7	21.5	23.7	24.6	25.8	25.9	26.0	25.0	24.3	24.3	22.9	(22)
(23)		5%	DB	21.5	20.8	22.2	24.7	26.8	29.4	30.0	30.2	29.1	27.9	25.4	23.9	(23)
(24)			MCWB	20.5	20.1	20.9	23.1	24.3	25.6	25.7	25.7	24.9	24.1	23.1	22.3	(24)
(25)		10%	DB	20.8	20.2	21.7	24.0	26.4	29.0	29.7	30.0	28.9	27.4	24.4	23.0	(25)
(26)			MCWB	19.5	19.3	20.4	22.2	23.9	25.4	25.5	25.6	24.8	23.9	21.8	21.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	21.8	22.8	25.1	26.0	27.4	27.5	27.4	26.9	26.7	25.7	24.0	(27)
(28)			MCD B	22.6	21.9	22.9	25.4	26.8	28.8	29.6	29.9	28.4	27.6	27.2	24.9	(28)
(29)		2%	WB	21.7	21.2	22.2	24.2	25.3	26.8	26.9	26.8	26.4	25.2	24.7	23.5	(29)
(30)			MCD B	21.8	21.3	22.4	25.0	26.3	28.4	29.4	29.6	28.4	27.1	26.3	24.4	(30)
(31)		5%	WB	20.9	20.5	21.6	23.5	25.0	26.3	26.5	26.5	26.0	24.8	23.8	22.7	(31)
(32)			MCD B	21.3	20.7	21.9	24.3	26.1	28.1	29.3	29.4	28.3	27.0	25.4	23.8	(32)
(33)		10%	WB	20.1	19.7	20.9	22.8	24.5	25.8	26.1	26.2	25.6	24.3	22.7	21.7	(33)
(34)			MCD B	20.8	20.1	21.4	23.7	25.9	27.9	29.1	29.2	28.2	26.8	24.4	23.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.4	3.2	2.4	1.9	1.6	1.8	2.0	2.1	1.8	2.0	2.8	3.2	(35)
(36)			MCDBR	3.1	3.3	2.2	1.9	1.6	1.8	1.9	2.0	1.9	1.7	2.3	2.6	(36)
(37)			MCWBR	4.0	4.3	3.0	2.0	1.9	1.5	1.7	1.7	1.9	2.0	2.8	3.2	(37)
(38)		5% WB	MCD BR	2.7	2.9	2.3	2.0	1.4	1.6	2.1	2.1	2.0	1.9	2.3	2.9	(38)
(39)			MCWBR	3.5	4.0	3.2	2.4	2.0	1.8	2.0	2.0	2.2	2.2	3.2	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.361	0.366	0.372	0.394	0.424	0.448	0.470	0.460	0.430	0.397	0.367	0.355	(40)
(41)		taud		2.497	2.494	2.470	2.405	2.360	2.371	2.310	2.354	2.412	2.476	2.504	2.540	(41)
(42)		Ebn at Noon		878	905	918	902	871	845	825	832	850	860	864	868	(42)
(43)		Edh at Noon		93	100	109	119	125	123	131	124	114	101	91	85	(43)
(44)	All-Sky Solar Radiation	RadAvg		3.34	4.07	5.36	6.47	7.06	6.52	6.11	5.69	5.11	4.71	3.73	3.06	(44)
(45)		RadStd		0.29	0.39	0.50	0.47	0.40	0.45	0.30	0.33	0.44	0.29	0.30	0.27	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.40	N/A	N/A	+0.37	N/A	N/A	N/A	N/A	+137	+102

Nomenclature: See separate page