

CHANNEL LIGHTSHIP, United Kingdom

WMO: 995920

Lat: 49.900N

Lon: 2.900W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	36.6	38.6	24.7	18.8	38.8	27.1	21.1	40.2	50.8	47.3	47.5	47.3	26.1	30	0.870

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	65.2	62.5	64.1	61.7	63.4	61.0	63.3	64.5	62.5	63.6	61.7	62.9	13.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	85.4	64.1	61.8	82.6	63.3	61.0	80.2	62.6	28.7	64.7	28.1	63.7	27.6	63.1	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 44.9	40.8	36.3		(4) 34.4	68.4	2.9	2.9	32.3	70.5	30.6	72.2	28.9	73.8	26.8	75.8	
(5)			DB	(5) 30.9	64.9	2.2	2.4	29.3	66.7	28.0	68.1	26.8	69.4	25.2	71.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	47.6	46.6	47.4	49.3	52.5	56.5	59.9	61.3	60.2	57.5	53.2	49.4	(6)
	DBStd	6.00	4.10	3.82	3.05	2.69	2.37	2.07	1.96	1.59	1.95	2.85	3.48	4.21	(7)
	HDD50	400	91	100	85	42	6	0	0	0	0	1	13	62	(8)
	HDD65	4197	539	515	545	471	386	254	158	114	143	234	354	484	(9)
	CDD50	1677	17	5	5	21	85	196	307	351	307	232	109	42	(10)
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0	(11)
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
	WSAvg	19.3	24.3	22.5	19.9	17.1	16.5	14.6	14.7	14.8	17.9	21.5	23.4	24.6	(14)
(15) Precipitation	PrecAvg	33.0	3.7	2.9	2.2	2.1	2.0	1.8	1.7	2.2	2.2	3.6	4.4	4.2	(15)
	PrecMax	40.6	7.7	5.7	6.5	5.3	4.5	4.1	3.2	5.4	5.7	6.8	8.8	9.6	(16)
	PrecMin	25.0	0.5	0.5	0.2	0.0	0.4	0.2	0.4	0.4	0.2	0.6	1.1	0.8	(17)
	PrecStd	4.4	1.9	1.5	1.3	1.3	1.2	1.0	0.8	1.2	1.2	1.6	1.9	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	54.8	53.8	55.7	60.0	63.5	66.5	67.4	66.0	64.2	60.4	57.6	(19)
		MCWB	53.0	51.4	50.6	52.4	55.7	60.0	63.4	64.6	62.3	61.4	57.8	54.7	(20)
	2%	DB	54.6	53.0	52.2	54.0	57.4	61.3	64.7	65.5	64.3	62.8	59.2	56.7	(21)
		MCWB	52.2	50.3	49.5	51.3	54.6	58.6	62.2	63.0	61.9	60.4	56.7	54.2	(22)
	5%	DB	53.7	52.0	51.5	53.1	56.2	60.1	63.5	64.4	63.5	61.9	58.4	55.8	(23)
		MCWB	51.2	49.4	49.0	50.6	53.8	57.6	61.2	61.9	61.0	59.5	55.8	53.2	(24)
	10%	DB	52.7	51.1	50.9	52.2	55.2	59.2	62.6	63.6	62.8	61.0	57.6	54.9	(25)
		MCWB	50.1	48.5	48.4	49.9	53.1	56.9	60.3	61.2	60.3	58.6	54.9	52.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	52.1	51.7	53.3	56.7	61.1	64.3	65.2	63.6	62.2	58.5	55.8	(27)
		MCDB	54.9	54.1	52.7	54.7	58.4	62.8	65.4	66.9	64.5	63.2	59.9	56.8	(28)
	2%	WB	52.8	51.0	50.4	52.0	55.4	59.4	62.8	63.7	62.6	61.1	57.4	54.8	(29)
		MCDB	54.1	52.6	51.6	53.4	56.7	60.7	64.1	65.0	63.7	62.3	58.9	56.2	(30)
	5%	WB	51.7	50.0	49.7	51.2	54.5	58.3	61.7	62.7	61.8	60.2	56.4	53.9	(31)
		MCDB	53.1	51.6	51.1	52.6	55.7	59.5	63.0	63.8	63.0	61.5	58.2	55.5	(32)
	10%	WB	50.6	49.1	48.9	50.4	53.7	57.3	60.9	61.9	61.0	59.3	55.4	52.7	(33)
		MCDB	52.5	50.9	50.6	51.9	54.9	58.6	62.1	63.1	62.4	60.8	57.4	54.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	4.1	3.6	3.6	3.4	3.5	3.2	3.1	3.3	3.6	3.9	4.5	(35)
		MCDBR	4.7	4.5	3.8	4.2	4.5	5.0	4.5	4.1	4.1	4.0	3.9	4.7	(36)
	5% WB	MCWBR	5.8	5.6	4.2	3.7	3.8	4.1	3.9	3.9	3.9	4.3	5.0	6.1	(37)
		MCWBR	4.6	4.5	3.8	4.0	4.2	4.6	4.3	4.0	4.0	3.7	4.0	4.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.339	0.354	0.388	0.399	0.403	0.396	0.391	0.383	0.375	0.366	0.339	0.331	(40)
		taud	2.382	2.386	2.308	2.308	2.352	2.404	2.421	2.462	2.464	2.450	2.431	2.352	(41)
	Ebn at Noon		219	247	258	268	272	274	273	271	261	240	219	202	(42)
		Edh at Noon	21	27	34	37	37	36	35	32	29	25	20	19	(43)
(44) All-Sky Solar Radiation	RadAvg		268	509	903	1450	1750	1901	1827	1527	1158	650	339	217	(44)
	RadStd		22	60	103	121	113	186	109	118	77	45	31	25	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page